

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: 718th Meeting of the ACRS

Location: Rockville, Maryland

Date: 09-04-24

Work Order No.: NRC-0025

Pages 1-184

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1716 14th Street, N.W.
Washington, D.C. 20009
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

718TH MEETING

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

WEDNESDAY

SEPTEMBER 4, 2024

+ + + + +

The Advisory Committee met via Video-
Teleconference, at 8:30 a.m. EDT, Walter L. Kirchner,
Chairman, presiding.

COMMITTEE MEMBERS:

WALTER L. KIRCHNER, Chairman

GREGORY H. HALNON, Vice Chairman

DAVID A. PETTI, Member-at-Large

RONALD G. BALLINGER, Member

VICKI M. BIER, Member

VESNA B. DIMITRIJEVIC, Member

CRAIG D. HARRINGTON, Member

ROBERT P. MARTIN, Member

SCOTT P. PALMTAG, Member

THOMAS E. ROBERTS, Member

MATTHEW W. SUNSERI, Member

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

ACRS CONSULTANT:

DENNIS BLEY

STEPHEN SCHULTZ

DESIGNATED FEDERAL OFFICIALS:

KENT HOWARD

QUYNH NGUYEN

DEREK WIDMAYER

TABLE OF CONTENTS

1

2

3 Opening Remarks by the ACRS Chair 4

4 X-energy Principle Design Criteria Topical

5 Report 8

6 Committee Deliberation on X-energy Principle

7 Design Criteria 11

8 **Seabrook Alkali-Silica Reaction (ASR) Update . . 61**

9 Public Comment 177

10 Committee Discussion 178

11 Adjourn

12

13

14

15

16

17

18

19

20

21

22

23

P-R-O-C-E-E-D-I-N-G-S

(8:31 a.m.)

CHAIR KIRCHNER: Okay, good morning.

The meeting will now come to order.

This is the first day of the 718th meeting of the Advisory Committee on Reactor Safeguards, ACRS.

I'm Walt Kirchner, Chair of the ACRS.

ACRS Members in attendance today are Ron Ballinger, Vickie Bier, Greg Halnon, Craig Harrington, Robert Martin, Scott Palmtag, Dave Petti, Thomas Roberts, and Matt Sunseri is there, there you are.

I was looking for you over here.

MEMBER SUNSERI: Oh, yes.

CHAIR KIRCHNER: And also joining us virtually is Vesna Dimitrijevic.

Consultants with us today are Dennis Bley, Myron Hecht, and Stephen Schultz.

If I've missed anyone, please speak up.

Quynh Nguyen and Derek Widmayer are the ACRS staff Designated Federal Officers for this morning's full committee meeting.

Member Sunseri has recused himself from this afternoon's discussions due to a potential conflict of interest.

I note that we have a quorum for today's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 meeting.

2 The ACRS was established by statute and is
3 governed under Federal Advisory Committee Act, or
4 FACA.

5 I think we have a live mic out there
6 somewhere. So, if you would silence your mic.

7 Thank you.

8 The ACRS was established by statute and is
9 governed by the Federal Advisory Committee Act, or
10 FACA.

11 The NRC implements FACA in accordance with
12 its regulations found in Title 10, Part 7 of the Code
13 of Federal Regulations.

14 In these regulations and the committee's
15 bylaws, the ACRS speaks only through its publish
16 letter reports.

17 Member comments should be, therefore,
18 regarded as only the individual opinion of that
19 member, not a committee position.

20 All relevant information related to ACRS
21 activities such as letters, rules for meeting
22 participation, and transcripts are located on the NRC
23 public website and can be easily found by typing About
24 Us ACRS in the search field on the NRC's home page.

25 The ACRS, consistent with the agency, is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 valued of public transparency and regulation of
2 nuclear facilities, provides opportunity for public
3 input and comment during our proceedings.

4 We have received no written statements or
5 requests to make an oral statement from the public,
6 although later this afternoon, we will have C-10, a
7 public interest group, providing us an informational
8 presentation.

9 We have also set aside time at the end of
10 this meeting for public comments.

11 The ACRS will gather information, analyze
12 relevant issues and facts, and formulate proposed
13 conclusions and recommendations as appropriate for
14 deliberation by the full committee.

15 A transcript of the meeting is being kept
16 and will be posted on our website.

17 When addressing the committee, the
18 participants should first identify themselves and
19 speak with sufficient clarity and volume so that they
20 may be readily heard.

21 If you are not speaking, please mute your
22 computer microphones, if you're using Teams or your
23 phone, by pressing star six.

24 Please do not use the Teams chat feature
25 to conduct sidebar discussions related to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 presentations, rather limit the use of the meeting
2 chat function to report IT problems.

3 For everyone in the room, please put all
4 your electronic devices in silent mode and mute your
5 laptop microphone and speakers.

6 In addition, as previously said, please
7 keep sidebar discussions in the room to a minimum
8 since the ceiling microphones are live.

9 With that, I'll just remind everyone that
10 the table microphones are unidirectional and you'll
11 need to speak directly in front of the microphones to
12 be heard on the line.

13 Finally, if you have any feedback for the
14 ACRS about today's meeting, we encourage you fill out
15 the public meeting feedback form on the NRC's website.

16 During today's meeting, the committee will
17 consider two topics.

18 In this morning session, we are going to
19 discuss the X-energy principle design criteria topical
20 report.

21 And then, this afternoon at 1:00, we will
22 discuss the Seabrook Station alkali-silica reaction
23 informational updates.

24 During this morning session, we will
25 deliberate on the topical report and the staff's draft

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 safety evaluation for the X-energy's principle design
2 criteria for the Xe-100 small modular reactor.

3 Regarding principle design criteria, we'll
4 refer to these as PDC.

5 And we expect to focus today's discussion
6 on X-energy's process in developing these criteria for
7 their high temperature gas cooled reactor design.

8 And with that, I am going to turn to our
9 lead for the X-energy design center subcommittee, Bob
10 Martin.

11 You have the floor.

12 MEMBER MARTIN: All right, thanks.

13 So, this is a little bit different kind of
14 meeting of the full committee.

15 A few weeks ago, we had, of course, X-
16 energy here to present their PDCs. Of course, the
17 staff was here, too, to present their SE.

18 We came out of that meeting basically
19 recommending that a letter was not necessary. And we
20 were fairly content, satisfied with two presentations
21 of which, being pretty thorough, X-energy had abided
22 by the Reg Guide 1232, which is the guidance on
23 developing principle design criteria for non-light
24 water reactors.

25 And I think it's relevant to note that, in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the afternoon, we also had Westinghouse also
2 presenting on PDCs.

3 So, we had a very interesting day of
4 looking at PDC presentations from two different
5 perspectives.

6 In fact, this is the fourth time we have
7 seen a PDC topical. We've also seen from Atomics last
8 summer and we saw TerraPower not too long -- a few
9 months ago. And I think having seen four different
10 topical reports on this topic, we get to see kind of
11 an interesting variety and interesting contrast
12 between how the different design centers have
13 approached, you know, the different criteria.

14 Now, that's not to say that they're all
15 people. Right? So, subsequent to our meeting two
16 weeks ago where there was a kind of a small dialogue,
17 you know, between mostly, you know, Tom Roberts and I
18 and Walt and some of the staff addressing two PDCs in
19 particular.

20 This is sort of related to PDC 16, 26, 615
21 being emulsion containment and the 26 being reactivity
22 is the reactivity control systems. What I thought I
23 would do was kind of read in my summary.

24 So, that was the recommendation, that we
25 would just have a summary report. And if it's okay

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 with everyone, it's a page long, so you're going to
2 hear me ramble a little bit, I thought I'd also bring
3 it up so y'all can follow along. I think I can do
4 this.

5 It's big enough to read and there we go,
6 perfect. All right, I'd just like to read this in for
7 the record.

8 Our X-energy Subcommittee met on August
9 21st, 2024 to discuss X-energy's Xe-100 topical
10 report, Principle Design Criteria Revision 3, and the
11 associated NRC staff safety evaluation.

12 During these meetings, we had kind of a
13 discussion what staff, representatives of X-energy as
14 well as documents cited in X-energy's topical report
15 and the staff SE.

16 X-energy plans to pursue the risk informed
17 performance based licensing approach described in NEI
18 1804, NEI 2107. These industry documents have been
19 endorsed by the NRC and Regulatory Guides 1.233 and
20 1.253.

21 The NEI Reg Guide documents emphasize the
22 risk informed approach to the selection of licensing
23 basis events, classification of systems, structures
24 and components and the evaluation of defense in depth.

25 They also include expectations for the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 preparation of PDC that begin with the application of
2 Reg Guide 1232, Guidance of Developing Principle
3 Design Criteria for Non-light Water Reactors.

4 Reg Guide 1.232 provides reactor designers
5 the guidance on how to establish PDC that ensure
6 safety while accommodating the innovative features and
7 advance reactor designs. Relevant to the Xe-100, this
8 includes generic modular high temperature gas cool
9 reactor design criteria, MHTGR-DC.

10 X-energy developed the Xe-100 PDC
11 primarily by adapting these MHTGR-DC with changes
12 reflecting design specific details and the licensing
13 process described in Reg Guide 1.233 and Reg Guide
14 1.253.

15 Most of these changes were vernacular in
16 nature. For example, per NEI 1804, safety related and
17 non-safety related with special treatment functions
18 and structure systems components are referred to as
19 safety significant. As such, wherever important to
20 safety appeared in the MHTGR-DC was replaced with
21 safety significant.

22 Another artifact applying to Reg Guide
23 1.253 is that X-energy presented PDCH required
24 functional design criteria and complimentary design
25 criteria.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 RDC and CDC are distinguished as
2 addressing the functional functions provided by safety
3 related and non-safety related with special treatment
4 perspectives.

5 I also, just kind of a side note, say that
6 X-energy is the first design center to implement this
7 through this Reg Guide 1.253.

8 So, this concept of required functional
9 design criteria and design is, at this moment, kind of
10 unique to their PDC topical report.

11 Okay, and to finish the paragraph, in
12 addition, they introduce owner-controlled design
13 criteria, or non-safety-related with no special
14 treatment and functions, NSSEs.

15 Another frequent departure from Reg Guide
16 1.232 was deletion of single failure in favor of
17 liability criteria, an option mentioned in Reg Guide
18 1.233, I say, I wonder if I meant 232 with that one,
19 but I'll go back to that.

20 A concern raised regarding this change was
21 that the applicant may find reliability
22 characteristics, particularly of concern is difficulty
23 to quantify for SSEs for limited industrial
24 application.

25 As such, application of single failure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 criteria might be an acceptable alternative.

2 Reg Guide 232 specifies that the MHTGR-DC
3 applied when certain design characteristics were met.
4 These are the use of TRISO fuel graphite as primary
5 structural material for the core and reflector and the
6 same gas as primary coolant, all of which are credited
7 in the Xe-100.

8 In addition, Reg Guide 1.232 states that
9 designs applying the MHTGR-DC should have operational
10 characteristics addressing anticipated operational
11 occurrences, AOOs, and design basis events, DPEs,
12 applied to MHTGRs.

13 While specific details regarding
14 operational characteristics and the Xe-100's response
15 to AOOs and DPEs will be an outcome of X-energy's
16 limitation of NEI 1804, NRC staff acknowledged the
17 preliminary information provided by X-energy has been
18 sufficient to support X-energy's claim in the context
19 of their review.

20 X-energy's PDC 16 functional containment
21 design departed from Reg Guide 1.232 language by
22 replacing, quote, multiple barriers with a required
23 functional design criteria specific to fuel particle
24 and pebble barriers and a complimentary design
25 criteria specific to the helium pressure boundary.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 The necessity of the word multiple was
2 debated at our meeting, considering it appears in the
3 definition of functional containment used in 8/28/18
4 ACRS letter on functional containment and in SECY 18-
5 296.

6 However, it is not present, as one
7 example, in definition for functional containment
8 appearing in Reg Guide 1.232 rationale for MHTGR-DC.

9 But regardless, between X-energy's RDC and
10 CDC 16, multiple barriers are identified.

11 The identified set of barriers does not
12 mention an external barrier such as are in
13 containment.

14 Rather, prior agency's deliberation on
15 HTGR licensings have deferred to require for external
16 barriers to be determined by specified acceptable
17 radiological release design limits, SARRDLs in RFDC
18 CDC 16 for Xe-100, X-energy substituted the mention of
19 SARRDL with functional containment design limits which
20 was understood to include SARRDLs as well as
21 additional criteria such as fuel temperature.

22 Related to PCD 16, X-energy plans to use
23 a proprietary TRISO partial fuel referred to as TRISO-
24 X from prior engagement between X-energy and the staff
25 on X-energy's fuel qualification methodology, X-energy

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 will evaluate any discrepancies between their fuel and
2 the TRISO fuel specification's performance data from
3 the U.S. Department of Energy's advanced gas reactor
4 DGR program as presented in DPR -- or excuse me, EPRI-
5 AR-1 topical report. I think that was published in
6 2020, 2021, it might have been a Rev or something like
7 that, anyway, to confirm its capability as a
8 functional containment.

9 The other one, other PDC that got some
10 attention was the PDC 26, reactivity control system
11 segregated the PDC into RFDC, DCN, and under control
12 design criteria, the concern was expressed that the
13 language suggested a departure of the defense in depth
14 philosophy that safety will not be wholly dependent on
15 any single element of the design construction,
16 maintenance, or operation of a different facility.

17 X-energy provided assurances that the set
18 of RFDCs, CDC, and other OCDC could collectively serve
19 to meet that standard.

20 The staff's limitations and conditions
21 provide final closure for X-energy -- excuse me -- Xe-
22 100 PDCs.

23 However, these limitations and conditions
24 incorporate language expectant that subsequent
25 development of the Xe-100 safety case engagement with

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the staff will result in their removal potentially
2 requiring a revision to Xe-100 PDC TR.

3 The regulatory precedent of a clean set of
4 design criteria established by general design criteria
5 for LWRs should be a strong motivator for the subject
6 of such well-articulated PDCs provide the best
7 assurance of the building and efficiency of staff
8 design for units.

9 The opinion of the committee is that the
10 staff's SE report is sufficiently complete to
11 recommend that it be issued.

12 It is also recommended that this write up
13 serve as a record of the subcommittee meeting and an
14 ACRS letter report will not be prepared.

15 Again, recommendation only and, obviously,
16 we can proceed specific or general and any manner that
17 would be otherwise.

18 The main issue that came out of the
19 meeting, as I mentioned before, was related to the
20 functional containment.

21 And while, of course, this is a meeting on
22 X-energy, not necessarily the four, obviously, we
23 should kind of focus on, you know, exactly that.

24 At the same time, maybe more actions that
25 come out, we can talk about maybe alternative letter,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 maybe on our observations on functional containment
2 PDCs in general.

3 And maybe -- well, I don't know how much
4 interest in, you know, in that particular one, there
5 might be, but certainly, PDC 16 caught our attention.

6 And given that we've seen the four design
7 centers now, we may want to write something.

8 But I wanted to open it up at this point.

9 My personal impression was this, I felt
10 like the application of Reg Guide 1.253 which brought
11 in the NEI 2107 framework which is just a kind of
12 attached on to the NEI 1803, you know, kind of
13 provided the kind of the anchor to beating the
14 expectations in Reg Guide 232 which is related to the
15 multiple barriers.

16 I thought they were very specific. You
17 know, they mentioned the fuel, you know, the particles
18 and the fuel, the pressure boundary specifically, I
19 think, in the tradition of MHTGRs.

20 They kind of covered the bases.

21 They did depart from the word multiple,
22 but in doing so, I felt their -- the specificity of
23 identifying the barriers was adequate.

24 You know, this staff in their SE, I could
25 read that, too, also acknowledged it and maybe even

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 whether they were sensitive or not, kind of
2 acknowledge the fact that multiple was missing, but
3 that they were satisfied that, indeed, it met the
4 multiple barrier standard.

5 So, with that, I'll open it up and maybe
6 Tom wants to chime in since Tom, Walt, and I were
7 members, at least initially, on this little email and
8 --

9 CHAIR KIRCHNER: I'd also ask Dave if he
10 would -- because Dave went through the NGMP experience
11 which was really the basis for the SARRDLs concept as
12 well as functional containment as was eventually
13 embodied in the Reg Guides.

14 Maybe we could turn to Dave first --

15 MEMBER MARTIN: Okay.

16 CHAIR KIRCHNER: -- for the background.

17 MEMBER PETTI: So, the multiple thing
18 doesn't bother me so much because I see multiple
19 values here.

20 Saying the particle is somewhat short
21 hand. From the NGMP days, we just say the particle
22 had at least three barriers, depending on how you
23 count them.

24 CHAIR KIRCHNER: Right.

25 MEMBER PETTI: Right?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Each of the coating layers and the kernel
2 itself.

3 The kernel itself is a ceramic, is a
4 pretty darn good barrier for some of the fission
5 products.

6 And then, you have the graphite. X-energy
7 says the pebble. It's a little different than
8 structural graphite.

9 But there's diffusion coefficients for
10 both of them, so you can model it. It's not, you
11 know, that big a deal.

12 And then, they have the coolant system
13 pressure boundary.

14 What they don't have is the building.

15 But NGMP was a 600 megawatt, a large
16 reactor.

17 These are small reactors.

18 And so, yes, do you need that to take
19 credit for that?

20 Probably not.

21 As you shrink the size, you know, this
22 whole functional containment study sits around with
23 the source term is at the site boundary.

24 And as you shrink the size, you should --
25 the main new cladding, and that gets you some, you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 know, you can maybe get rid of the one barrier.

2 But the most that it was ever credited
3 for, it's not credited heavily.

4 And in NGMP, in fact, there was lots of
5 concern about how much to credit it. It had, you
6 know, was declared.

7 Furthermore, when you look at Xe-100,
8 which we haven't looked at in detail, but given its
9 size, it probably has peak temperatures and accidents
10 that are not as severe as an MHTGR.

11 So, that, you know, there's also the
12 details in the accident space that will influence what
13 that source term is.

14 So, you know, I don't, you know, they felt
15 they wanted to clarify, I mean, what multiple meant,
16 I guess.

17 VICE CHAIR HALNON: Dave, just one quick
18 question.

19 When I compare what you just said about
20 three barriers in the TRISO fuel and compare that to
21 what we're traditionally used to, which is the clad
22 RCS and containment building.

23 I have the question, is -- and what people
24 are used to seeing is three very distinct, separate
25 different manufacturing processes. You've got the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 fuel plant in one area of the country, you have an
2 RCS, different code, different material, then you had
3 a containment, same thing, different code, different
4 material.

5 Is the TRISO fuel manufacturing process
6 such that you can't get a pebble or defects such that
7 all three of those barriers could have a single defect
8 problem with that that couldn't be -- may not be
9 detected?

10 MEMBER PETTI: Oh, no, I mean it is
11 detected. I mean, that's --

12 Yes, we have -- they have limits on the
13 defects, silicon carbide defect being probably the
14 most important.

15 But there are other defects and they all
16 characterize -- they all have limits and they're down
17 in the, you know, usually the 10 to the minus 5 range.

18 VICE CHAIR HALNON: So, in your opinion,
19 is those three barriers an equivalent level of
20 containment, if you will, as the three barriers that
21 we're traditionally used to seeing because on the
22 different diversity that we have there?

23 MEMBER PETTI: It's at least two of them
24 to the -- compared to the traditional.

25 VICE CHAIR HALNON: I'd hate to make it

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 simplistic --

2 MEMBER PETTI: Yes.

3 VICE CHAIR HALNON: -- case out of it.

4 MEMBER PETTI: Yes.

5 VICE CHAIR HALNON: But that means that if
6 you reduce one barrier, now you're down to just one
7 barrier --

8 MEMBER PETTI: Right, right.

9 VICE CHAIR HALNON: -- for the
10 containment.

11 MEMBER PETTI: And that's not -- I mean,
12 it's -- there's multiple barriers.

13 And this, you know, because there's a
14 functional containment, and I believe there will be a
15 mechanistic source term.

16 The hold up for the different isotopes is
17 different.

18 VICE CHAIR HALNON: You have to take into
19 consideration the different technology --

20 MEMBER PETTI: Right.

21 And then, you know, silicon carbide is,
22 you know, critical for almost all of the
23 radionuclides.

24 And graphite is very important for cesium
25 and stratum which are strong dose contributors.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Right?

2 But iodine, which is the other big -- that
3 graphite until they just go through.

4 So, it's not a barrier there, so you get
5 all these caveats which, when the study gets put
6 together, they should be okay.

7 If we turn to Kairos, right, they had the
8 fuel as one barrier and then, they had their coolant.

9 Their coolant is an amazing barrier.

10 So, what they did was they went and was --
11 were what gas reactor guys would describe as somewhat
12 cavalier, allowed for a tremendous amount of defects
13 and failures of their fuel in the reactor because they
14 have the strength of the second barrier.

15 And these things trade off in design
16 space.

17 And so, it's not surprising that we'll see
18 differences, you know, as they come in.

19 But the real question is, you know, it's
20 more complex than just that. It has to do a lot with
21 the source term which has to do with the size and the
22 site boundary and all of that stuff happening
23 together.

24 MEMBER BURKHART: Excuse me for
25 interrupting, the court reporter just has a message.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 I think he's new and if you could state
2 your name before you speak, at least for a little
3 while.

4 And please, get closer to the microphone.
5 It's -- when you sit back, it's difficult for him to
6 hear.

7 VICE CHAIR HALNON: Yes, this was Greg
8 Halnon was the questioning and Dave Petti was the
9 responder.

10 MEMBER MARTIN: And I will add, you know,
11 you start pulling the thread now, and this probably
12 comes as no surprise, but you know, as I was kind of
13 preparing for the meeting a couple weeks ago, and you
14 know, pulling the thread on the history, yes, it goes
15 back to the '80s. Right?

16 And the language that's even used in the
17 Reg Guides that were not so old go back, you know,
18 that these conversations have been done time and again
19 since the mid, late '80s, maybe farther back with per
20 se brain, you know.

21 But it's not a new topic, you know,
22 containment versus confinement debate, you know,
23 within --

24 (Simultaneous speaking.)

25 MEMBER PETTI: -- did have a containment.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And the fuel they had 10 to the minus 3 fuel quality,
2 so a tenth of a percent of the fuel had defects, you
3 know, but that's not the fuel --

4 MEMBER MARTIN: Was that bi-cell, though?
5 Was that --

6 MEMBER PETTI: No, that was tri-cell.

7 MEMBER MARTIN: It was an early version of
8 tri-sell?

9 MEMBER PETTI: It was carbide fuel. It
10 was highly enriched, but also it's a different means
11 and not made necessarily the same way.

12 So, the other thing, though, that's
13 important is that we always said in NGMP, GA would
14 always say, you cannot take credit just for the powder
15 cladding.

16 For at least a 600 megawatt thermal image
17 TGF, you will never meet the pads at 400 meters if you
18 only account for the particles, that even at what we
19 think is incredibly high quality, the dose is too high
20 and it's all driven by iodine.

21 So, you needed to take credit somewhere
22 else.

23 Again, 600 megawatts as you make them
24 smaller, the story will change and that's why it's
25 going to be really important to understand what the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 source term is as you move forward.

2 But similarly, any of the technologies,
3 whether it be, you know, TerraPower, I mean, there's
4 certain isotopes that you know that you've got to make
5 sure that they understood -- that's all understood.

6 MEMBER ROBERTS: This is Tom Roberts.

7 To some degree, the question on X-energy
8 is more philosophic than technical because what
9 they've done is, they've taken a principle with is
10 currently in the Reg Guide that you shall have
11 multiple barriers for functional containment and
12 define the approach they will take to meet that
13 requirement.

14 So, instead of stating the principle,
15 they're stating an approach that will meet the
16 principle which seems fine, except you wonder, now
17 that the principle is gone, whether there's some, you
18 know, downstream consequence of either somebody
19 leveraging this document, some other, you know,
20 applicant or X-energy themselves say, well, the
21 requirement was to have this fuel, not to meet the
22 multiple barriers criteria.

23 Like Bob said, we've seen four of these
24 PDC topical reports, two of them did not change the
25 language for the multiple barriers.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 The one we're talking about now, they
2 changed the language, but they require, essentially,
3 what the underlying basis was for the multiple
4 barriers.

5 Then, we'll talk about it tomorrow which
6 is, eventually, they took the language out to say,
7 yes, we're going to do whatever the LNP process tells
8 that we need to do which is now even more general in
9 terms of not talking about any sort of deterministic
10 barriers, but whatever the probabilistic approach
11 tells you you need.

12 And they will, in effect, have the same
13 architecture as very similar as X-energy with their
14 fuel choices.

15 But it's just what's stated in the PDC is
16 the question of whether it should be stated as a
17 matter of principle or as a matter of this is exactly
18 what we're going to do and not to state the principle.

19 So, that's the question I'd leave out
20 there.

21 We -- this committee wrote a letter in
22 2018, as Bob alluded to in his comments, that had a
23 recommendation to always have some degree of, you
24 know, redundancy, independence, whatever with the
25 containment barriers, that you should never be down to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 just counting on one thing as your containment barrier
2 which is a deterministic type of criteria.

3 And whether you would allow a
4 probabilistic assessment to convince you that that's
5 not necessary.

6 I mean, it is a different question.

7 And that's a question that is not
8 currently on the table with the approaches intended by
9 these applicants, but it is, you know, on the path to
10 get there without stating the requirement for
11 redundance or multiple barriers and the PSC.

12 So, that's the issue I'd like to discuss,
13 whether that applies better for this one or tomorrow's
14 discussion we talked about, but it's something that's
15 what we're pursuing as a committee, whether the
16 statement of principle, you know, we think should
17 remain in the PDC regardless of the implementation.

18 MEMBER MARTIN: But maybe someone -- I
19 have had a question on this for some time, but the use
20 of general versus principle design criteria, what was
21 the intent of these two words?

22 I mean, I can see back in Appendix A, in
23 the '60s it provided for maybe a lot of design types,
24 you know, under the umbrella of light water reactors.

25 And the, here, for advanced reactors, we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 have a different word here.

2 And I wonder maybe related to the question
3 of where, you know, how functional the criteria are
4 expressed, whether there is a nuance between the use
5 of the word general versus principle where we intended
6 to be more specific.

7 MEMBER PETTI: No, I just always saw it as
8 sort of a synonym, without -- because GDCs mean
9 something in an LWR context.

10 The advanced reactor guys wanted a
11 different terminology.

12 I may mean the same thing at the deck
13 point, right? But it looks different and it flows
14 different because they're very into top down.

15 That's how you make it technology neutral
16 and you go with the functional code.

17 So, that I never thought that there was a
18 difference there.

19 VICE CHAIR HALNON: I think they needed to
20 distinguish between the old way and new way of doing
21 things.

22 But there's also another new way which
23 comes back to the philosophical issue, they're seeing
24 the designs --

25 In the past, you had a very distinct set

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 of general design criteria. You designed your plant
2 to those to make sure that you had the redundancy and
3 single failure proofs and everything else you needed.

4 Today, what we're seeing is sort of an
5 upside down approach where the PDCs are being modified
6 to meet the design rather than the design being met to
7 meet the PDC.

8 And that's --

9 MEMBER PETTI: or at least iterated.

10 VICE CHAIR HALNON: Iterated.

11 And it's -- I don't think that's wrong.
12 I think that's kind of the way it's been the construct
13 is driving the folks to do this.

14 Paradigm in our mind, we've got to get
15 straight that that's not wrong, but we have to make
16 sure that it's effectively meets the need for the
17 safety of the plant now.

18 In this case, and I think since Larry just
19 walked out, Rob, could you guys take PDC 16 and 26 for
20 the four design criterias? Put them next to each
21 other for us and show us the deviations and see -- let
22 us just take a look at those to see all together
23 whether or not we see a philosophical trend or a
24 physical trend that we need to continue to talk about.

25 I think that would be useful for us.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER MARTIN: I mean, I can pull it up.
2 I have it on my scree here.

3 VICE CHAIR HALNON: All four design
4 centers?

5 MEMBER MARTIN: You're not --

6 VICE CHAIR HALNON: Oh, not all four, no
7 just -- no, I'd like to see all four next to each
8 other just so that we can see how these are trending
9 one way or the other, fewer barriers, changing
10 language.

11 Just, you said, Tom, there's a couple of
12 them had not changed.

13 So, I'd like to see it in a chronological
14 way, which one was first, second, third, as we're
15 iterating through these things.

16 Because I think what we'll see is, you
17 know, it's the world of positive plagiarism, you know,
18 what's been accepted before is something where you
19 start with and then, you work from there on these
20 designs.

21 So, that would be useful for us to see
22 that and I think as we go forward, keeping that up to
23 date.

24 And we may expand it to more of the PDC,
25 but those two are right now the ones we're talking

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 about.

2 MEMBER MARTIN: Well, I would say what X-
3 energy did on 16, it's different.

4 Like I mean, in the sense, you know, I
5 think their main goal was to adapt the Reg Guide, you
6 know, the recent 253 Reg Guide, which the others have
7 not done.

8 And so, in doing so, they got a little
9 more specificity than the -- so, I throw it up there
10 real quick.

11 So, you can see the specificity in their
12 statement, which I think is unique among the four that
13 we have seen.

14 And to the point of uniqueness, it's the
15 combination of the required functional design criteria
16 and the complementary which they said to my question
17 as a really in practice, any difference with how you
18 approach demonstrating these criteria is no, not
19 really, they're segregated a little bit by the events
20 that they'll use to basically demonstrate the
21 criteria.

22 MEMBER ROBERTS: I want to take a shot at
23 answering Bob's question to see if I got it right.

24 My understanding is that the PDCs have
25 always existed and the requirement for light water

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 reactors to start with the GDCs.

2 And you had to meet the GDCs and
3 incorporate them into your PDCs for your design. That
4 may be a super set of them and may be identical, it
5 depends on the details of the reactor.

6 And then, when the advanced reactors came
7 about, the NRC, I wrote that Reg Guide 1.232, which
8 was the rough equivalent of the GDCs, but there was
9 still an expectation that the individual applicants
10 would take the ARDCs, the SFRDCs and the CRGRDCs were
11 the three kind of pick lists of substitute for general
12 design criteria.

13 And then, tailor them to their plan to be
14 the PDCs.

15 I don't think anything's materially
16 changed, you know, over the years, I've always had to
17 start with some set of criteria and show how you met
18 them and add them, add whatever you needed to to fully
19 cover your design.

20 I got that right? I see some heads
21 nodding.

22 MEMBER MARTIN: Well, I was hoping, you
23 know, a response kind of like that because there's,
24 you know, they're not just, you know, GDC or PDC,
25 there's always a tier of criteria at the top levels is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 what the conversation is between the design center and
2 the staff.

3 And then, when you get into the weeds on
4 other topical, these other criteria that support the
5 GDC or, in this case, the PDC, you know, are more
6 specific and, you know, and collectively.

7 Then they rise up to address the more
8 general or principle design criteria.

9 We will, you know, we will see criteria or
10 requirements in other topical reports that ultimately
11 percolate up to these high level ones.

12 I think what we might be seeing with the
13 new reactors is that maybe a step down because they
14 know, you know, they know what their design is and
15 they can be more specific.

16 And so, they're highest level design
17 criteria is going to be more specific than we're used
18 to seeing with, say, a GDC or maybe even some of the
19 other designs, you know, that came prior to.

20 But this Reg Guide, the Reg Guide 1.253.

21 MEMBER PETTI: Some of the reorganization
22 in the X-energy stuff sort of made sense.

23 You know, when there was inspection stuff
24 in five different places, they pulled it all into one.

25 I mean, some of that stuff, you can

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 imagine, down the road from an efficiency perspective,
2 demonstrating compliance with it, it'll just make the
3 story easier than, you know, having to pick at five
4 different GDCs.

5 So, you know, but when I went through
6 that, I went -- I mean, it made me wonder why that
7 wasn't kind of the Reg Guide at that stage.

8 You know, I mean, there was a lot of time
9 to develop.

10 MEMBER MARTIN: They put a lot into that.

11 MEMBER PETRI: Yes, they did and, yet --

12 MEMBER SUNSERI: This is Matt Sunseri.

13 I guess, interesting discussion we're
14 having. I've lost focus on what we're trying to
15 achieve, though, here.

16 What are -- what's our purpose?

17 MEMBER MARTIN: Well, I think our purpose
18 is to decide whether we, you know, kind of accept,
19 basically, the recommendation from the subcommittee
20 that the summary was sufficient or do we consider
21 further action, I think, on the subject of functional
22 containment.

23 And, you know, maybe with the tone of
24 informing the staff that maybe we -- there should be
25 more specificity or maybe certain guardrails that need

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 to be highlighted.

2 I don't know, but I think that's up to the
3 committee to decide whether we look at functional
4 containment in a very specific sense.

5 Obviously, in doing so, I think we have to
6 look at four designs centers that we've seen and kind
7 of, you know, pull lessons learned from the four.

8 I think would be -- being a little careful
9 because this is X-energy, right, fundamentally and
10 that we should stay focused a bit on that, but
11 bringing insights from the other experiences is
12 worthwhile.

13 MEMBER SUNSERI: So, I guess I would --
14 that I thought our whole objective of the organization
15 or the way the licensing process works is to be able
16 to tailor this to your specific technology and be
17 inclusive of everything.

18 And we had a good discussion at the
19 subcommittee meeting and I thought we were satisfied
20 that this applicant had met the criteria at that
21 point.

22 So, I thought we were ready to move on
23 despite the fact that there may be some language
24 complexities here, technically, what you're doing is
25 right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER MARTIN: Yes.

2 MEMBER SUNSERI: Is that an actual
3 statement?

4 MEMBER MARTIN: Yes, I guess, to kind of
5 move this slightly in a different topic, but still be
6 on functional containment, one issue I kind of had was
7 the deviation from SARRDL to something more kind of,
8 you know, not defined so well, and that was just the
9 functional containment design limits.

10 I thought it had ambiguity that you needed
11 -- need to be rectified.

12 I just didn't like, you know, and SARRDLs,
13 I guess now, you know, I think we all kind of
14 understand what that's trying to do.

15 And when you kind of use a new term there
16 without, you know, I think good definition, it doesn't
17 help the conversation or it leaves the kind of an open
18 item, you know, to be resolved and, you know, other
19 engagement.

20 And maybe at this state, it's fine. But
21 SARRDLs pops up, you know, time and again in the Reg
22 Guide and it just wasn't in this PDC as such.

23 You know, except, of course, we talked
24 about this, well, okay, because could SARRDL, but it
25 might include other design limits, which is fine, but

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 ultimately, SARRDLs kind of go back to all those
2 SAFDLs or whatever you want to consider.

3 MEMBER PETTI: So, this is Dave.

4 Did they not commit to SARRDLs, thinking
5 it is a lower level issue?

6 Or did you push the SARRDLs in the
7 subcommittee?

8 CHAIR KIRCHNER: Can you show the --

9 MEMBER MARTIN: So, they used, okay, not
10 limits --

11 CHAIR KIRCHNER: Could you go to I think
12 it's PDC Number 10 of the SARRDLs?

13 MEMBER MARTIN: Like I said, the point I
14 was making here is that, you know, I mean, this goes
15 back to the Reg Guides.

16 And they used limits instead of
17 conditions, so I'm not sure if there's any, but the
18 subtlety is there.

19 I don't know why it does that, I can't
20 seem to --

21 PARTICIPANT: We can't see it now.

22 MEMBER MARTIN: Yes, exactly.

23 There we go, that's a little better just
24 so you can see the words.

25 So, yes, SARRDLs are there, but I just,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 you know, the conversation where on -- and maybe this
2 is just me, but on 16, you know, we don't have
3 SARRDLs, we have just something kind of --

4 And I'm not sure what the subtlety of
5 conditions versus limits are.

6 It seems in practice and I have little
7 experience on practice.

8 It's the SARRDL that we focus on for
9 functional temperature and functional containment and
10 criteria related to meeting SARRDLs goes back to also
11 some say traditional SAFDLs.

12 CHAIR KIRCHNER: So, Dave, when you --
13 this is Walt Kirchner.

14 Dave, when you -- when NGMP first was
15 developing these, then I presume you mentioned, you
16 know, mechanistic source term.

17 So, behind this then, the test really was
18 the dose at the boundary was within the 10 CFR 50 or
19 52 limits.

20 MEMBER PETTI: Well, usually that was
21 easily met. It was usually the pads, the EPA pads on
22 rem at the -- I mean, we certainly had flat as the
23 most stringent dose requirement.

24 But here, I mean, SARRDLs are -- SARRDLs
25 have less -- have to do with knowing that your

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 functional containment is intact.

2 CHAIR KIRCHNER: Intact, right.

3 MEMBER PETTI: Right?

4 You're measuring radionuclides in the
5 helium, and that tells you how good the fuel is,
6 whether something has failed or not above what you
7 assumed in your SARRDL.

8 CHAIR KIRCHNER: But then, in
9 implementation, then there was a tech spec limit --

10 MEMBER PETTI: Correct, it will be tech
11 specs, absolutely.

12 CHAIR KIRCHNER: -- that you worked
13 against and then --

14 MEMBER PETTI: Right.

15 And in --

16 CHAIR KIRCHNER: -- if you passed that
17 threshold, then you --

18 MEMBER PETTI: Right.

19 CHAIR KIRCHNER: -- effectively had to
20 some remedial action --

21 MEMBER PETTI: Right.

22 CHAIR KIRCHNER: -- on some documents.

23 MEMBER ROBERTS: Yes, Bob, let me try
24 this.

25 This confused me, too.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 The SARRDLs are tied to ALOs and normal
2 operation and the PDCs.

3 Containment is not there for ALOs or
4 normal operations, they're for accident conditions.

5 But what Dave said earlier is, the key
6 parameter is dose at the whatever boundary you're
7 calculating dose at.

8 So, I think there's an either unstated or
9 implied limit in PDC 16 which is the dose of the
10 boundary, but the SARRDL concept wasn't intended to
11 apply to containment type of assessments.

12 Is that right, Dave?

13 MEMBER PETTI: Yes, I think you're right.

14 MEMBER ROBERTS: So, I think that's where
15 the SARRDL was there to come up with a way to estimate
16 ALO consequences for a fuel type that doesn't really
17 have, you know, fuel limits that are challenged by
18 ALOs.

19 And so, it gave you something meaningful
20 to calculate for ALOs, at least that's my
21 understanding.

22 MEMBER MARTIN: So, you feel that the
23 functional containment design conditions or limits are
24 kind of more restrictive, covering a broader set of
25 events, not necessarily beyond design basis as the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 focus, the tradition of GDCs kind of stopped at
2 design.

3 CHAIR KIRCHNER: If I could -- this is
4 Walt Kirchner.

5 Just enter in here to Matt, at a higher
6 level, I think one of the important things as we look
7 at these submittals, these TRs on NMPDC, is to
8 remember the important role that --

9 Let me go back to GDCs, and if you think
10 through how the agency -- the staff goes through
11 reaching a reasonable assurance conclusion, it's by
12 and large, it's not limited just to the GDCs, but one
13 of the important steps in making that finding is to
14 test the design against the GDCs to determine adequacy
15 of the design.

16 So, the ensemble of the GDCs is an
17 important aspect in reaching the reasonable assurance
18 that there's no undue risk to the health and safety of
19 the public.

20 So, but it's the entire set of GDCs and,
21 hence, you will -- what we see, we take it for
22 granted, but it actually provides structure for the
23 staff's review and they systematically go and make an
24 assessment.

25 In 0800, the standard review plan or a, I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 think it's a tailored review plan, essentially,
2 systematically used the GDCs as the basis for making
3 a determination of adequacy of the safety systems, et
4 cetera.

5 So, in the course of reviewing these, what
6 I have been looking at is, are they -- this is perhaps
7 not the best word -- but are -- when you come down
8 from, as Tom said earlier, from the higher set of
9 criteria to tailoring to the specific design, do you
10 still fully meet the intent that was there in the Reg
11 Guide to being with for that particular safety
12 function?

13 And that's the -- so, I'm looking at these
14 and you say what's in a word?

15 If you strike the plural from barriers, so
16 you -- if there aren't multiple barriers for a
17 functional containment, that would be of concern
18 because the whole idea is to provide a robust system
19 -- a containment system that isn't reliant on just one
20 single barrier to accomplish the function.

21 And we were pretty explicit about this in
22 our letter report back in 2018.

23 And if I -- if you'll indulge me, I'll
24 just read this.

25 Item Number Four, that a functional

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 containment should include multiple barriers as a
2 defense in depth feature that -- and that they should
3 be minimally dependent on each other and diverse in
4 nature.

5 And I think the latter clause was you
6 didn't want to have consequential failure of the
7 barriers.

8 So, there -- that introduces some
9 diversity and the concept of multiple barriers.

10 MEMBER MARTIN: Right.

11 And I think -- and maybe I'm not
12 remembering this correctly, but the whole concept of
13 the TRISO fuel enables the concept of a functional
14 containment because of the multiple inherent barriers
15 in the design of those particles.

16 And then, when you combine that with
17 energy that's available to distribute the
18 radionuclides much different than a PWR at 1,000
19 pounds pressure and 500-something degrees.

20 Then, you know, these are reasonable
21 expectations.

22 And I thought we had come, you know, back
23 to this specific example how we could come to the
24 conclusion that this design met that criteria.

25 That's all I was saying. So, I'm not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 disagreeing with your little optical umbrella that you
2 painted here.

3 I think it is our responsibility to make
4 sure that we've done this review.

5 But it seems to me that we have done that
6 review, that's all I'm saying.

7 MEMBER PETTI: I think the issue gets much
8 foggier as we move away from the concepts for which
9 functional containment were developed which is gas
10 reactor, right, eVinci, there's some real uniqueness
11 there.

12 Let's talk about a dissolved fuel system.

13 We know the multiple barriers, you know,
14 I mean, then things get much, much cloudier on the
15 spectrum.

16 MEMBER MARTIN: I think everyone would
17 agree that this should be the easy one. The four
18 we've seen, this should be an easy one.

19 MEMBER ROBERTS: Yes, Tom Roberts.

20 I don't know if we'll get to the
21 comparison of the four topical reports, that cracking,
22 that's about a while ago. We can talk about that
23 tomorrow.

24 But I think it's more of a general
25 question of looking at any of the trend and the types

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 of language and how it's potentially setting precedent
2 for the next one that may be, like Dave said, is
3 considerably different from it was when it was
4 evaluated before, but out of the precedent is well,
5 you just go, use LMP and LMP tells you, you know,
6 what's good enough in terms of containment, which is
7 certainly a part of it.

8 But that doesn't -- it doesn't seem like
9 all of it.

10 But I agree with you, Matt, that the X-
11 energy, they've simply described how they're going to
12 meet the requirement in place of the requirement.

13 It's, from a technical perspective, kind
14 of hard to argue, but the adequacy because whether we
15 say have multiple barriers to the exact language of,
16 you know, MHTGR 16 or what they've written, they'll
17 get to the same place.

18 So, it's really kind of setting up the
19 discussion for your expectation in general.

20 The other technical question was 26.

21 You know, you want to go to that one, Bob?

22 I wasn't sure I understood the issue in
23 26.

24 My recollection from the subcommittee
25 meeting was that there was a staff slide that implied

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that the natural temperature feedback was the backup
2 means. And I think staff agreed that that slide was
3 wrong.

4 (Simultaneous speaking.)

5 MEMBER ROBERTS: And you see in the slide
6 --

7 MEMBER MARTIN: So, let's just recall that
8 some of this was in closed session, right? So, just
9 --

10 MEMBER ROBERTS: Okay.

11 If you assume the slide is wrong and it
12 seems like the text of the -- of their recommended PDC
13 is just fine.

14 So, I'm wondering if there's any -- if
15 you're seeing any remaining issue.

16 MEMBER MARTIN: Oh, absolutely not.

17 You know, we got the clarification of
18 there's specific design and strategy in the closed
19 session.

20 And I think that that might have been
21 where we got the acknowledgment that maybe that the
22 slide was incorrect, the staff slide or not specific
23 enough.

24 MEMBER PETTI: Well, being that, you may
25 not be able to answer the question.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 The second diverse means of shutdown is
2 not the inherent temperature coefficient?

3 MEMBER MARTIN: Yes, that's correct.

4 MEMBER PETTI: Yes, that would be
5 additional defense in depth.

6 MEMBER MARTIN: Right.

7 And that was, you know, the inherent
8 really what addresses is 11 -- PDC 11 I believe that's
9 --

10 MEMBER PETTI: That's a big -- I mean,
11 it's been an issue with gas reactors for a very long
12 time, whether they could do that and not need a second
13 system.

14 MHTGR always had a second system.

15 MR. MOORE: To the members, this is Scott
16 Moore, the Executive Director.

17 We can prepare the side by side comparison
18 of the four PDCs for tomorrow morning, I think.

19 We're not going to have that during
20 today's discussion.

21 CHAIR KIRCHNER: Thank you, Scott.

22 MEMBER PETTI: And again, I would just,
23 you know, say again that this is all iterative, right?

24 I mean, if you look at NEI 1804, you look
25 at LMP, you go through and you may have to come back,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that once you've done your PLA and you have to adjust
2 things and change things.

3 I mean, designs go through iterations, we
4 just tend not to see them.

5 MEMBER MARTIN: Right, right.

6 MEMBER PETTI: Right here at ACRS, that's
7 all in the background.

8 While here, all this stuff is looped with
9 it so --

10 VICE CHAIR HALNON: And I think that --
11 this is Greg -- that's part of the issue is the
12 design's iterative, but the PDC should not be because
13 they set the design criteria.

14 MEMBER PETTI: But it's hard to see what
15 the right propagate --

16 (Simultaneous speaking.)

17 VICE CHAIR HALNON: And that was my point
18 earlier, is that as we come through the designs, that
19 might have a better way of doing it to change this
20 language in the PDC, which means I have to go back
21 through it.

22 So, that whole aspect is we have to be
23 nimble enough to be able to accept that when it makes
24 sense and it's good for safety and not fall back on
25 our old ways of thinking on some of these.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 But so, on the table right now is a
2 question. Do we stay with the subcommittee
3 recommendation to enter -- and we can play with the
4 words if you want to, with the summary that Bob read
5 or do you think we need to write a letter that
6 encompasses the bigger question?

7 I would offer up, there's another option
8 which is to accept the subcommittee's recommendation
9 at this point and open up a topic based on the action
10 to continue to watch these critical PDCs that are
11 changing in time and having a potential meeting down
12 the road where we have determined that there is now a
13 bigger question that is erupting that may cause us a
14 safety concern.

15 At this point, I haven't heard a safety
16 concern. I've heard a lot of questions and a lot of
17 concerns from the standpoint of trends and whatnot.

18 But until we get the data in front of us,
19 we don't really know we see maybe a couple more PDCs,
20 we may not see a trend.

21 I think it's a fruitful discussion to have
22 philosophically, but, at this point, my
23 recommendation, and I'll put the motion, you know, I
24 guess Walt has to put the motion, but I would say,
25 make a motion that we accept the subcommittee write-up

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 and trend and track -- and maybe, Bob, you and Tom,
2 since you've taken an interest in this, kind of take
3 the lead on looking at these two PDCs and how they are
4 trending down the road. And then, also make -- decide
5 whether or not we need to expand it to other things as
6 well.

7 That would be my motion to accept it and
8 then open up the top kind of a small task with you two
9 guys watching the trend in the PDCs.

10 CHAIR KIRCHNER: So, we have a motion on
11 the table.

12 Do we have a second?

13 MEMBER SUNSERI: Yes, I would second that.

14 CHAIR KIRCHNER: Someone seconds?

15 MEMBER PETTI: Matt did.

16 MEMBER SUNSERI: Matt Sunseri, second.

17 CHAIR KIRCHNER: So, discussion?

18 Vicki, you raised your hand?

19 MEMBER BIER: Yes, I agree with Greg's
20 recommendation.

21 It seems to me that there are not a lot of
22 serious issues with the PDCs that we just reviewed in
23 subcommittee, but that the general trend of whether we
24 are on a slippery slope of accepting things that
25 might, you know, reduce safety margin, you know,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 deserves some awareness going forward.

2 So, I think that's a sensible manner in
3 which to handle this.

4 CHAIR KIRCHNER: Any other --

5 MEMBER SUNSERI: Yes, this is Matt again.
6 I would -- just following up with Greg's point, I
7 agree with, you know, trending the lessons we learned
8 from the various applications we're reviewing.

9 And I just want to be cautious not to undo
10 all the good work that was done to create the PDCs for
11 the advanced designs because the idea was to move away
12 from a reactor specific set of GDCs like the PWR ones.

13 And if we try to force the language back
14 to make them all look the same, then we will have the
15 same problem as we had with the light water reactors,
16 is that you have to have all the, you know, take all
17 these exceptions to the GDCs when the new things come
18 around.

19 So, I just want to be mindful that, you
20 know, we don't inadvertently through wanting to retain
21 institutional knowledge or our decisions that we, you
22 know, create a bad situation going forward.

23 That's all.

24 CHAIR KIRCHNER: Well, one thing that I
25 think we should be looking at, though, is the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 perception that there was a lot of work put into
2 developing those appendices to that Reg Guide.

3 And there was a lot of thought and there
4 was a lot of experience behind those, particularly for
5 the MHTGR, but also for the sodium fast reactors that
6 codified a lot of experience that the agency had in
7 reviewing earlier designs.

8 And so, when the applicant has -- it's
9 just guidance that's understood -- but if there is a
10 deviation to accommodate the specifics of a design,
11 one should be asking some hard questions in terms of
12 justification for why there is this variance from,
13 let's just pick Appendix A of 1.232 to start with,
14 which was meant to be just what you said, Matt,
15 technology kind of neutral or inclusive.

16 And by codify -- but experience had, you
17 know, have been accumulated over time looking at the
18 development of surrogate general design criteria for
19 advanced reactors.

20 And what I've seen is that, yes, the
21 changes appear to be justified.

22 Of course, we're in the early part, we
23 haven't reviewed the details of the design. So, we're
24 kind of a little bit under informed, I would say.

25 So, we're looking at these, so, I'm

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 thinking, does the ensemble, the totality of these
2 PDCs provide a level of safety, if you will, that is
3 comparable to what is required of the current
4 generation of LWRs?

5 The advanced reactor policy statement is
6 pretty explicit on some of these things.

7 It said, regarding advanced reactors, the
8 Commission expects, as a minimum, at least the same
9 degree of protection of the environment and public
10 health and safety and the common defense and security
11 that is required at the current generation light water
12 reactors now.

13 So, from my perspective, the PDCs are an
14 important first step and demonstrating that the
15 concept is going to provide and comparable or, what is
16 the worry again that I just -- the same degree of
17 protection as is provided with the LWR fleet.

18 And that's primarily derivative of -- it's
19 not just the general design criteria, it's a lot of
20 other things.

21 But its' very important first step.

22 So, that's my concern at a high level that
23 in the tailoring, Matt, that there's not a dilution of
24 the fundamental objection of that particular
25 requirement.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 You know, and 26 is -- and there are a few
2 key ones, 10, 16, and 26 because they get at the
3 basic, the three basic safety functions, essentially.

4 When you think about it, it's, you know,
5 we've got 26, is controlled reactivity.

6 And you know, the fuel 10 and 16 bear on
7 the fission product barriers.

8 And then, the others, and one way or
9 other, of course, need to be tailored, but it's
10 control of decay heat.

11 MEMBER MARTIN: I mean, I know we're in
12 theory in discussion from the motion, maybe I should
13 ask this as a question rather than an observation.

14 So, with light water reactors, you, of
15 course, you have the general design criteria, they
16 have a hole, you know, regulatory framework that would
17 just establish for LWRs and ultimately, you know,
18 people fall back to NUREG 0800 as, if we follow NUREG
19 0800, we meet all the GDCs.

20 But you don't have, at least in my
21 experience as someone just explicitly tracing work,
22 you know, from, all right, I do this analysis. It's
23 addressing this particular GDC and you see it map all,
24 you know, you see how it maps back to, you know,
25 Appendix A.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 There's a lot of similarity and there's a
2 lot of differences between the new reactors and light
3 water reactors.

4 What I wonder may be missing in regard to
5 PDCs is some, you know, and maybe in other Reg Guides
6 where it says, you really need to have that
7 traceability in all the documentation so it doesn't
8 get lost because we don't have a NUREG going on. We
9 don't have settled law on everything that is X-energy
10 or TerraPower or, you know, et cetera, et cetera.

11 Some effort needs to be made by the
12 applicant to say, I do this work to meet these
13 criteria. And you can trace it all our documents.

14 VICE CHAIR HALNON: Just real quick, Bob,
15 and all due respect, the PSARs in each of the sections
16 have this satisfies PDC, empty spot, empty spot, empty
17 spot.

18 So, if you -- in each of the sections of
19 the PSAR does map.

20 Now, it may not be directly as direct as
21 what you're saying, but it is -- there is a conscious
22 effort to show PDC and this what meets it.

23 MEMBER MARTIN: For LWRs.

24 VICE CHAIR HALNON: No, for the -- for
25 what we've been looking at.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER MARTIN: You mean like in the Regs?
2 So, Reg Guide -- the 233 that --

3 VICE CHAIR HALNON: Well, I may go back
4 and forth, didn't Kairos, you won't have this, does
5 this satisfy PDC something.

6 MEMBER MARTIN: So, they were sensitive,
7 you know, but are they doing it because they know
8 that's how you -- that's the best way to present the
9 information or are they doing it because, you know,
10 somewhere they -- a seasoned licensing manager will
11 know to do these things. Right?

12 So, there's a difference between, you
13 know, being good at your job and, you know, following
14 instructions. Right?

15 And that's what I'm saying is that, do you
16 need to have the specificity in the Reg Guides to say
17 that you, you know, we expect that this kind of thing
18 because before it was kind of understood if you're
19 following NUREG, you know, 0800, that you were
20 meeting, you know, all the GDCs.

21 That's my point is that it's not in black
22 and white.

23 Someone that's done this over and over
24 again I snot going to know to do that.

25 New reactors, you're going to have a

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 different -- maybe different path to get -- to show
2 that traceability.

3 MEMBER ROBERTS: Okay, if I could comment
4 on the motion?

5 I agree with Greg. I agree with Matt.

6 I think both of them are expressed, you
7 know, important concerns that shouldn't be tied to the
8 language that's in the current Reg Guide DCs of the
9 Appendix A for technology that doesn't apply to it.

10 But it all starts with the principle and
11 then, deriving from that principle and whatever the
12 language that derives from the principle ought to be
13 clear to, you know, trace to the principle is, which
14 I think we get there with this one.

15 So, I'm not very concerned with the E-
16 energy PDC document.

17 So, you know, I'm going to agree with the
18 motion.

19 The only caveat is, I think there's some
20 parts of the summary report that probably ought to be
21 tweaked. I don't know what your right is in terms of
22 making comments to Bob and then coming up with some
23 mutually agreed upon version to present tomorrow or
24 what --

25 CHAIR KIRCHNER: Yes, yes, can you --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MEMBER ROBERTS: But I would, I'd like the
2 chance to, you know, have some input into the write
3 up.

4 CHAIR KIRCHNER: Sure, can you --

5 MEMBER MARTIN: We'll do that tomorrow
6 anyway.

7 CHAIR KIRCHNER: Yes.

8 Can you distribute that to everyone?

9 If there's no --

10 Are there any -- we've already showed that
11 so there's no proprietary restrictions. Okay.

12 So, all right, we have a motion on the
13 table and we've had discussion.

14 All those in favor?

15 Vesna, are you with us?

16 MEMBER DIMITRIJEVIC: Yes, and I am in
17 favor.

18 CHAIR KIRCHNER: Thank you very much.

19 Okay, with that, I think we are finished
20 with the morning session.

21 Any other comments?

22 (No response.)

23 CHAIR KIRCHNER: We will be engaged at
24 1:00 and we will have the Seabrook informational
25 presentations at that time.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Okay, thank you, everyone.

2 For the court reporter, we will sign off
3 now and come back on at 1:00 Eastern Time.

4 (Whereupon, the above-entitled matter went
5 off the record at 9:40 a.m. and resumed at 1:00 p.m.)

6 CHAIR KIRCHNER: This is the afternoon
7 session of the first day of the 718th Meeting of the
8 Advisory Committee on Reactor Safeguards. I'm Walt
9 Kirchner, Chair of the ACRS.

10 The ACRS members in attendance in person
11 are Ron Ballinger, Vicki Bier, Greg Halnon, Craig
12 Harrington, Robert Martin, Scott Palmtag, Dave Petti,
13 and Thomas Roberts. Matthew Sunseri has recused
14 himself from these discussions due to a potential
15 conflict of interest.

16 We also have Vesna Dimitrijevic online
17 with us.

18 Good afternoon, Vesna.

19 Consultants attending, I believe --

20 MEMBER DIMITRIJEVIC: Good afternoon.

21 CHAIR KIRCHNER: -- thank you -- are
22 Dennis Bley and Stephen Schultz.

23 If I've missed anyone, please speak up
24 now.

25 Kent Howard of the ACRS staff is the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Designated Federal Officer for the full Committee
2 meeting this afternoon. And I note that we have a
3 quorum for our meeting.

4 During this second session today, the
5 Committee will receive an informational briefing and
6 update from Region I staff on the status of the NRC's
7 oversight of the alkali-silica reaction, commonly
8 referred to as ASR, at the Seabrook Station.

9 And now I'll just go on to make the
10 following note that the ACRS was established by
11 statute and is governed by the Federal Advisory
12 Committee Act, FACA. The NRC implements FACA in
13 accordance with its regulations found in Title 10 Part
14 7 of the Code of Federal Regulations.

15 Per these regulations and the Committee's
16 Bylaws, the ACRS only speaks through its published
17 letter reports. Therefore, note that all member
18 comments should be regarded as only the individual
19 opinion of that member and not a Committee position.

20 All relevant information related to ACRS
21 activities, such as letters, rules for meeting
22 participation, and transcripts, are located on the NRC
23 public website and can be easily found by typing About
24 Us ACRS in the search field on NRC's homepage.

25 The ACRS, consistent with the Agency's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 value of public transparency in regulation of nuclear
2 facilities, provides opportunity for public input and
3 comment during our proceedings.

4 I note today we have C-10, a public
5 interest group, with us to make a presentation later
6 in the session. Other than C-10, we have received no
7 written statements, comments, or requests to make an
8 oral statement from the public, but we will set aside
9 time at the end of this meeting for that purpose.

10 The ACRS will gather information, analyze
11 relevant issues and facts, and formulate proposed
12 conclusions and recommendations, as appropriate. A
13 transcript of the meeting is being kept and will be
14 posted on our website.

15 When addressing the Committee,
16 participants should first identify themselves and
17 speak with sufficient clarity and volume so that they
18 may be readily heard. If you're not speaking, please
19 mute your computer on Teams or your phone by pressing
20 star-6.

21 Please do not use the Teams chat feature
22 to conduct sidebar discussions related to the
23 presentations. That is limited to the use of
24 reporting IT problems.

25 I go on to ask everyone to mute any

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 electronic devices, put them in silent mode, and point
2 out for our presenters today that these microphones
3 that we're using are rather unidirectional. So you'll
4 need to speak directly into the front of the
5 microphone to be heard online and as well by our court
6 reporter.

7 With that, I am now going to turn the
8 Committee's deliberations over to our Plant Operations
9 Subcommittee Chair, Greg Halnon, and Co-Chair Ron
10 Ballinger.

11 Greg, go ahead.

12 VICE CHAIR HALNON: Thank you, Chair
13 Kirchner. The ACRS has been involved with this topic,
14 which is unique to this nuclear plant, since 2018.

15 After being briefed on multiple occasions
16 by members of the NRC staff and the Seabrook licensee
17 staff, all with ASR expertise, the ACRS issued letters
18 to the Commission regarding the ASR-related license
19 amendment and issuance of a renewed license for
20 Seabrook with two separate letters.

21 Most recently, the ACRS last met with the
22 staff on April 27, 2022, when they provided an update
23 on the status of ASR at Seabrook and on the Seabrook
24 licensee's implementation of its ASR Monitoring
25 Program since that program's establishment by the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 license amendment in 2019.

2 As an independent advisory committee, the
3 ACRS continues to engage the NRC staff and others with
4 ASR expertise on this issue as appropriate, with the
5 goal of advising the Commission accordingly.

6 Today the Committee will hear from the NRC
7 staff, including Region I staff and inspectors, to
8 discuss the most recent staff evaluation of the
9 progression and impacts of the ASR phenomenon at
10 Seabrook.

11 We will also hear, as Chair Kirchner
12 mentioned, from C-10, a public interest group that has
13 been following this issue very closely for many years.
14 The committee are focused on the overall safety in
15 Seabrook Station and how the ASR situation is being
16 managed.

17 At this time, the Committee will hear from
18 the staff and others, and it will discuss how to
19 proceed in the future.

20 This could include the Committee writing
21 a letter report on this topic with any relevant
22 recommendations to the Commission. There is not yet
23 any schedule for such a letter report. The Committee
24 will discuss next steps at the conclusion of this
25 meeting.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 I'll ask Member Ballinger, do you have any
2 other opening remarks?

3 MEMBER BALLINGER: No, that's fine. Thank
4 you.

5 VICE CHAIR HALNON: With that, I would
6 like to turn over the presentation to the NRC staff,
7 specifically Mel Gray, Branch Chief, Engineering
8 Branch 1, Region I.

9 Mel?

10 MR. GRAY: Thank you.

11 Thank you, Chair Kirchner and members of
12 ACRS for this opportunity to be here today on behalf
13 of the folks who have traveled from Region I Office of
14 the NRC with me, and our partners in the NRR Office
15 that are here today also.

16 My name is Mel Gray. I'm Branch Chief in
17 the NRC Region I Office in the Division of Operating
18 Reactor Safety. I have oversight of the region-based
19 engineering inspectors, the specialists who go
20 periodically to Seabrook Station and perform
21 ASR-related inspections.

22 Also here today is my branch chief
23 counterpart, Matt Young, who oversees the resident
24 inspectors. We work very closely together on
25 oversight of specifically the Seabrook Station, which

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the licensee and owner is NextEra Energy Corporation.
2 Our slides will simply refer to them as NextEra, for
3 your information.

4 Our presentation will pick up where we
5 left off with ACRS from April 2022. We are looking to
6 be responsive to your requests. And so to that end,
7 we intend to move sufficiently through our oversight,
8 some history of ASR at the Seabrook Station and what
9 the NRC has concluded there.

10 And then we will move on to our inspection
11 results with a focus on the containment internal
12 structure, trying to be responsive to your lines of
13 questioning and interest at our last meeting.

14 Next slide, please.

15 Here with me are the actual folks who do
16 the inspections day to day. Nik Floyd is to my left
17 over here. He joined the NRC in 2010 as a reactor
18 engineer in our Region I Office as part of the Nuclear
19 Safety Professional Development Program right out of
20 school.

21 Upon completion of that program, he was a
22 reactor inspector in Region I Division of Reactor
23 Safety, conducting a full range of inspections with a
24 focus on in-service inspection and design reviews. In
25 2018, he was promoted to a senior reactor inspector.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 He's also served the Agency at Indian
2 Point in 2020 and 2021, in its last year of operation,
3 as a senior resident inspector. He holds a bachelor's
4 and master's degree in materials science and
5 engineering for Virginia Polytech Institute and State
6 University.

7 I have next to me Travis Daun. He's the
8 Senior Resident Inspector at Seabrook, there every
9 day. He's been there since June 2023, every workday.
10 Prior to his current role, he served as a resident
11 inspector at Seabrook Station since June 2019, and
12 prior to that at Susquehanna Station in Pennsylvania.

13 Travis joined the NRC in 2012 as a reactor
14 engineer in our Region III office. He previously
15 served for 11 years in the Navy as a submarine
16 officer.

17 He has a bachelor's degree in electrical
18 engineering from Marquette University, a master's
19 degree in cybersecurity from Syracuse University, and
20 a master's in business management from American
21 InterContinental University. It's good to have staff
22 who are smarter than you.

23 Finally, George Thomas is with us. He has
24 been with us on inspections from NRR office on-site
25 about every six months. George Thomas is a senior

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 civil structural engineer and a reactor technical
2 reviewer in the Division of Engineering and External
3 Hazards, Office of Nuclear Reactor Regulation.

4 He has been with the NRC since 2006, and
5 worked in the US nuclear power industry with Bechtel
6 for over ten years prior to that. He was one of the
7 technical reviewers for the Seabrook License Amendment
8 Request and License Renewal Programs related to ASR
9 and building deformation.

10 He has also supported Region I, as I've
11 said, since 2011 in our inspections. He holds a PhD
12 degree in civil engineering from Texas Tech University
13 and is a Registered Professional engineer in the State
14 of Maryland.

15 Next slide, please.

16 I'll go over our agenda briefly.
17 Considering that maybe some stakeholders here may not
18 be as familiar with ASR and the Seabrook plant and the
19 phenomena, we intend to go through just sprightly
20 quickly the background, and then move through what our
21 inspection and assessment of ASR is.

22 Travis Daun will provide the background
23 and describe the requirements we've placed on the
24 facility. Then Nick Floyd will pick up with our
25 inspection and assessment results. Finally, he'll

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 focus on the containment internal structure. And I'll
2 close there with thoughts and next steps.

3 So with that, I will turn it over. Next
4 slide, please, and turn it over to Travis. Thank you.

5 MR. DAUN: All right. Thanks, Mel.

6 As Mel mentioned, I am Travis Daun. I'm
7 the Senior Resident Inspector at Seabrook. I'm going
8 to just cover a brief background on ASR, the history
9 of ASR at Seabrook, and then how Seabrook monitors ASR
10 progression and building deformation, as well as the
11 licensing actions taken to date.

12 First and foremost, resident inspectors
13 must be cognizant of the ASR degradation mechanisms
14 present at the site and how the effects manifest
15 throughout the structures. This gets factored into
16 our daily and quarterly inspection planning for
17 ASR-specific samples or integrated into normal
18 quarterly samples with an ASR flavor.

19 So a background on ASR. If anyone has
20 additional questions, please feel free to stop me
21 while we're going through them. I'm going to hit the
22 highlights at a fairly high level, but if you need
23 more detail.

24 First of all, ASR is a slow, expansive
25 chemical reaction in hardened concrete, which occurs

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 in the presence of water. That chemical reaction is
2 between the alkaline cement and the reactive silica
3 found in some aggregates. The expansion can cause
4 various material impacts, which we'll look at on the
5 next slide.

6 Next slide, please.

7 Okay. Here are some of the visual
8 indications of ASR that the residents see throughout
9 the plant. The gel expansion starts off as micro-
10 cracking and can later be observed as macro-cracking
11 on the surface.

12 The visual appearance is typically in the
13 form of what is known as pattern cracking, which you
14 can see on the image to the right, where you see the
15 deposits in the cracks and gel staining around the
16 cracks.

17 I just want to make a note, ASR is not
18 new. While Seabrook may be the only known nuclear
19 power plant in the United States where ASR is
20 impacting safety-related Category I structures, there
21 is a lot of experience with ASR in other industries,
22 such as Department of Transportation.

23 The Federal Highway and Transportation
24 Authority has extensive experience with ASR in the
25 transportation infrastructure, but the design is not

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 a one-for-one. Bridges are not designed the same way
2 that nuclear power plants are, and there are
3 significant differences.

4 The expansion and cracking of concrete
5 from ASR can potentially impact both structural
6 capacities, so the load carrying capacity of the
7 structure, and the demand, i.e. the load put on that
8 structure. So it can affect both sides of that
9 demand-to-capacity ratio on that structure.

10 VICE CHAIR HALNON: Travis?

11 MR. DAUN: Go ahead.

12 VICE CHAIR HALNON: This is Greg Halnon.
13 Since it's not new and it is elsewhere, how does it
14 fail? What does the failure look like when we say,
15 it's done, it's failing?

16 MR. DAUN: Do you want to take that, Nik?

17 MR. FLOYD: Yes, I can. Can you hear me
18 okay?

19 VICE CHAIR HALNON: Yes.

20 MR. FLOYD: So based on our discussions
21 with our Office of NR Research, there aren't really a
22 lot of data points on what failure looks like because
23 structures are either remediated or taken out of
24 service prior to failure.

25 A lot of the failures that have been seen

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 are in unreinforced concrete. Essentially, you get
2 expansion, you get the microcracks, and it will fall
3 apart.

4 It's a lot different when you throw in the
5 reinforcement. Once it's reinforced, it behaves
6 significantly different. Right now, this is why
7 Seabrook went through the test program, just to see,
8 hey, what is the capacity that the concrete can
9 handle?

10 As far as that ultimate limit state, what
11 we consider unacceptable is, you shall remain under
12 the demand-to-capacity ratio of 1. Beyond that, it's
13 unanalyzed, and that's unacceptable. So what failure
14 actually looks like, we have not seen it.

15 VICE CHAIR HALNON: Okay. So we haven't
16 seen in these other applications a catastrophic
17 failure, even in unreinforced, because it's either
18 remediated in time because it's visible and noticeable
19 so we know we have to remediate it, or it's reinforced
20 and hasn't gotten to that failure point; is that
21 correct?

22 MR. FLOYD: That's our understanding.
23 Correct.

24 VICE CHAIR HALNON: Okay. Thank you.

25 MR. DAUN: Okay. Next slide, please.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Okay. So here's a brief history of ASR at
2 Seabrook. In 2009, in preparation for NextEra's
3 submission of their license renewal application, it
4 was identified that the aggressiveness of the
5 groundwater chemistry on Seabrook concrete structures
6 that were in contact with groundwater needed to be
7 determined.

8 Therefore, testing was performed. In
9 August 2010, NextEra confirmed through a petrographic
10 analysis the presence of ASR in concrete and
11 below-grade walls of several Category I structures.

12 NextEra then initiated a prompt
13 operability determination to assess the safety
14 significance of the issue and the basis for continued
15 operation. NextEra identified several causes for the
16 ASR issue and several reasons for why it was not
17 identified until the license renewal review.

18 One cause was that concrete mix for
19 initial construction unknowingly utilized an
20 ASR-susceptible aggregate. ASTM standard screening
21 tests at the time have been determined to have limited
22 ability to screen very slow-reactive aggregates for
23 ASR.

24 Because of this, NextEra mistakenly
25 assumed that the original cement and aggregate

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 selection would preclude ASR development, and
2 therefore did not initially consider that the observed
3 cracking could be caused from ASR. So initially,
4 NextEra characterized the cracking as shrinkage
5 cracking.

6 Just a note, new ASTM test standards have
7 since been developed -- this is since the early to
8 mid-80s -- that now better detect this type of slow-
9 reacting aggregate.

10 And then the NRC did issue an information
11 notice in 2011 -- it's 2011-20 -- on the operating
12 experience identified at Seabrook with ASR
13 identification and ASR confirmation.

14 Next slide, please.

15 Okay. NextEra performed an extent-of-
16 condition review and prompt operability determination,
17 as I said on the previous slide, and concluded that
18 from a regulatory standpoint, the affected structures
19 were operable, but degraded and non-conforming,
20 because ASR was not initially taken into account in
21 the current licensing basis.

22 The prompt operability determinations were
23 based on the material properties and the margins that
24 were seen. Regional inspectors and Headquarters
25 experts -- Mel has mentioned a lot of those --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 reviewed the operability determinations and concluded
2 that ASR-affected structures remained capable of
3 performing their safety functions.

4 In 2012, the NRC increased oversight to
5 ensure structures remained functional while NextEra
6 developed their corrective actions.

7 Next slide, please.

8 Okay. To resolve the open operability
9 determinations related to ASR, NextEra chose to
10 perform a large-scale test program at Ferguson
11 Structural Engineering Laboratory at the University of
12 Texas at Austin to better understand ASR's impact on
13 the structural performance of ASR-affected structures.

14 The concrete test specimens were designed
15 to replicate the reinforced concrete walls at
16 Seabrook, and then the ASR growth was accelerated to
17 allow testing in a reasonable time frame.

18 Basically, the test was designed to
19 determine how much ASR could occur in a concrete
20 structure before impacting its structural strength,
21 and determine the best way to measure and track ASR
22 progression in a structure similar to the walls at
23 Seabrook.

24 During the test program, the NRC conducted
25 several audits and inspections with NRR and Region I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 staff at the test facility, which were focused really
2 on ensuring quality test standards were followed
3 during the testing. This was especially important
4 knowing that the test results would be used to update
5 Seabrook's current licensing basis as part of future
6 license amendments.

7 Next slide, please.

8 Okay, the large-scale testing program
9 results. They showed no reduction in structural
10 capacity at the expansion levels tested, and the code
11 equations can be used to the tested levels.

12 The test results were used to develop
13 expansion limits and monitoring techniques which were
14 incorporated into Seabrook's current licensing basis
15 via a license amendment.

16 As long as Seabrook stays between the
17 identified expansion limits, they can continue to use
18 the original design equations and material properties
19 to determine the capacity of the impacted concrete.

20 If they go outside these limits, it does
21 not mean that they have a firm safety limit, but they
22 have gone outside the boundaries of the test program
23 and would need to reanalyze the structures and
24 demonstrate operability.

25 So basically, the Texas test program, as

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 we refer to it, put guardrails on -- this is how much
2 ASR expansion you can see and confirm the structural
3 capacity of the structures.


4 Based on the licensee's ASR expansion rate
5 evaluations for September 2022 and March 2023, several
6 of the extensometer locations were projected to exceed
7 the licensed through-thickness expansion limit before
8 the expiration of a renewed Seabrook operating license
9 in 2050. Based on the rates at the time, the
10 projected time to exceed was greater than ten years.

11 The NRC has tools available to ensure
12 appropriate oversight as they continue that monitoring
13 program to ensure that they're still within those
14 guardrails that we discussed.

15 VICE CHAIR HALNON: Travis?

16 MR. DAUN: Yes.

17 VICE CHAIR HALNON: This is Greg again.
18 Relative to the guardrails of the testing, there is
19 obviously a margin on the upper side from what would
20 be completely unacceptable even by an analysis.

21  Is there a magnitude that you can
22 articulate about how much margin? Is it a lot, a
23 little? Is it tight? Have they had trouble
24 evaluating cracks a little bit bigger than the
25 guardrails, or is there still a lot of margin there?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. DAUN: The guardrails are really set
2 for ASR expansion limits.

3 So I'll probably either kick that -- Nik,
4 do you want to take it, or George, just on the margin
5 from the Texas testing program that's there?

6 MR. FLOYD: One of the things we look for
7 when we go on-site is always looking at the monitoring
8 data. We want to see what are the current expansion
9 levels.

10 It's not consistent across all structures.
11 Some structures have what I'll call moderate
12 expansion. Some have little to no expansion. If you
13 looked at a graph, it would look almost flat. So it's
14 hard to put an exact margin number that's universal to
15 the site. It's really dependent on each structure.

16 There is still substantial margin for
17 these expansion rates or these expansion limits
18 established for the Texas test program. We looked at
19 it in detail back during our November -- well, not
20 November, but our 2023 inspections.

21 And what we did see is that the expansion
22 trends, if they stayed constant -- you can only draw
23 a line through so many points, and it's seasonal
24 fluctuations. Depending on humidity and temperature,
25 crack sizes open and close just slightly, and so you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 get a little bit of scatter on the curve.

2 The best fit was at, I think, four or five
3 locations. They were projected to exceed that upper
4 limit by, basically, ten years at that point, so 2034-
5 2035.

6 VICE CHAIR HALNON: Okay. And when they
7 exceed that, that's not necessarily saying they're
8 going to fail in 2034 or 2035; it's just that's where
9 your calculation is pushing it to this point?

10 MR. FLOYD: Correct. Their testing
11 program has analyzed up to that expansion limit. Now,
12 there is certainly margin past that, but to put a
13 number on it, you can't do it without supporting test
14 programs.

15 VICE CHAIR HALNON: I was looking for more
16 magnitude of --

17 MR. FLOYD: Yes.

18 VICE CHAIR HALNON: -- okay or not.

19 MR. FLOYD: The one positive was through
20 the test program, there was no reduction in capacity
21 up to those limits tested. That tells you there is
22 still more margin and expansion in load demand that
23 that structure can withstand. So that's the positive
24 piece, but the magnitude beyond that, it's hard to
25 say.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 VICE CHAIR HALNON: One last follow-up
2 question. Do those calculations or equations take
3 into effect other mechanisms, such as the
4 Davis-Besse's ice expansion?

5 They would get ice on their containment
6 structure. They had microcracks in the surface and
7 moisture driven into it and, of course, a similar
8 environment during the wintertime, which is just
9 really, really cold.

10 Does that take into consideration, too,
11 the potential for accelerated other mechanisms? Just
12 having ASR doesn't immune you to other stuff.

13 MR. FLOYD: Right. I will have to defer
14 to one of our senior civil structural engineers. I'll
15 let George Thomas chime in on this.

16 I know there's a lot that goes into the
17 load demand side of that equation, but as far as the
18 capacity and what other degradation mechanisms are
19 considered, I'm not sure. We'll have to ask George.

20 MR. THOMAS: This is George Thomas, a
21 senior civil engineer. So the other mechanisms, they
22 are managed by inspections. You have the maintenance
23 load inspection.

24 MR. BURKHART: George, this is Larry. Can
25 you pull the microphone closer, please?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. THOMAS: So the inspections look at
2 any other mechanisms. If any degradation related to
3 other mechanisms are found, then it's evaluated to
4 make sure that it's still within the current licensing
5 basis.

6 VICE CHAIR HALNON: So George, can they
7 distinguish between freeze-thaw cracking and ASR
8 cracking? Are they additive or are they
9 complementary? How do you deal with two, three
10 mechanisms when you're doing a operability evaluation
11 that says I'm good out to 2034 if that's only taking
12 into effect ASR and not other mechanisms?

13 MR. THOMAS: Yes. In that respect, the
14 primary monitoring mechanism is crack indexing at
15 specific locations. There may be cracks due to other
16 mechanisms, too, but they do consider it all due to
17 ASR.

18 VICE CHAIR HALNON: So you're assuming
19 it's all ASR --

20 MR. THOMAS: Yes.

21 VICE CHAIR HALNON: -- which is
22 aggressive? Well, it's not aggressive. It's slow,
23 but comparable to other mechanisms; is that what
24 you're saying?

25 MR. THOMAS: It's correlated. And if

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 there's something out of the ordinary, then they will
2 further evaluate the mechanisms.

3 VICE CHAIR HALNON: Okay. Thank you.

4 MR. FLOYD: And just to add to that real
5 quick, some of the locations in question that do have
6 these higher expansion rates, the ones specific to
7 this trend, they're in below-grade structures.

8 So there really aren't a lot of other
9 damage -- freeze-thaw wouldn't be applicable because
10 you're in indoor, underground structures. The driving
11 mechanism there is ASR.

12 As far as other damage mechanisms, the
13 visual inspections would support that as far as
14 determining is there something else going on. If you
15 have groundwater coming through, is that leaching, is
16 that just groundwater, or is that just ASR deposits?

17 So there are ways they would have to
18 disposition that, and we would verify, but yes. That
19 is correct, but just to that.

20 VICE CHAIR HALNON: Thank you.

21 MR. GRAY: I guess I can't help but add
22 here. Your first question is meeting the limits might
23 not mean the structures are unsafe. You're correct,
24 but as inspectors, we're given a standard to inspect
25 to.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 This is the license conditions and the
2 program that we've approved, so we're keenly focused
3 on the limits of that and to engage in a timely manner
4 to make sure they stay within that. If they see
5 they're not, they're taking action. It's their plan
6 to handle that appropriately.

7 VICE CHAIR HALNON: Thank you, Mel.

8 MR. GRAY: Yes.

9 VICE CHAIR HALNON: I appreciate you
10 bringing it back to the reality of the fact that
11 you're not inspecting up to a design-basis limit.
12 You're inspecting so that you can raise a flag and
13 start a process.

14 MR. GRAY: Right.

15 VICE CHAIR HALNON: So I get that. I
16 appreciate that. Thank you.

17 MR. GRAY: And the second piece, as I
18 understand, maintenance rule is we're looking for if
19 the licensee is responsible to do exams to understand
20 the degradation mechanisms, whether they be
21 freeze-thaw, ASR, or something else.

22 We do look at that regularly. And Nik is
23 all over that. He's right. It's not freeze-thaw down
24 there. Thank you.

25 MEMBER PALMTAG: This is Scott Palmtag.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 I just have a quick question. I'm new to this. Can
2 you tell me a little bit about the Texas tests? Did
3 you accelerate ASR, and then you put it under
4 load-bearing until it failed? Is that how it went?
5 You said there was no load-bearing cracks from ASR?

6 MR. FLOYD: Right. As far as the test
7 program went, they sourced aggregate that was highly
8 reactive, so both the sand and the coarse aggregate.

9 And then after they placed the beams, they
10 put them into -- essentially, you could call them
11 large greenhouses. You want to have higher
12 temperatures and a moist environment to help
13 accelerate the ASR.

14 They just did the limits because they were
15 looking for results. They did that in an accelerated
16 time frame. You could let it go indefinitely and let
17 ASR continue, but they needed results. So they
18 stopped it just shy of the two-and-a-half-year mark so
19 that they could compile the test report.

20 The testing that was done, they did a
21 combination of, basically, a bending moment, a shear
22 beam test -- well, not shear. And they also looked at
23 shear test. George could probably again add to this
24 since he was the technical reviewer.

25 As far as the loading, there was code

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 equations and load limits that they took it up to, and
2 there was no failures observed. As far as did they
3 take it to failure, I'll have to ask George if they
4 actually went beyond their established load values.

5 MR. GRAY: This is George Thomas. The
6 specimens that were used, they were subject to
7 accelerated expansion. And at some point, they were
8 subject to load tests to failure.

9 The load tests to failure were also
10 compared. There were also control specimens that they
11 used, which they tested with no ASR.

12 So the load capacity between control
13 specimens with no ASR and the load tests to failure,
14 there was no reduction in load carrying capacity. It
15 was fine up to the level of expansion that was
16 achieved. The expansions are measured in three
17 directions, two in-plane and through-thickness.

18 MEMBER PALMTAG: This is a question. This
19 might be more for NextEra instead of NRC, but are
20 there any plans to do more testing?

21 MR. GRAY: That is a question for NextEra,
22 but we remain cognizant of what they share with us.

23 Our footnote in red on this slide was our
24 attempt to let the ACRS be aware that we're closely
25 monitoring that situation. They are doing some

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealgross.com

1 exploratory aggregate testing and thinking about what
2 would be needed to support continued plant operation
3 if they choose to do that.

4 So they are laying the groundwork for
5 that, but they're very early and haven't made a
6 decision on that. Whatever they do, we'll follow
7 closely. We would look at any regulatory-related
8 document or process that they identify.

9 They would certainly need to apply the
10 Code of Federal Regulations' 10 CFR 5059 process. We
11 would look at that closely to determine whether that
12 warranted prior NRC approval. And if that's the case,
13 we would engage. If it was otherwise, we still would
14 look at that closely and decide what to do.

15 I'm answering from our purview and our
16 thought, what we're thinking about. We would use the
17 flexibilities in both the inspection product line and
18 the oversight product line to do what's needed for
19 safety.

20 MEMBER PALMTAG: Currently, the way I
21 understand it, there's guardrails in place. And it's
22 possible they could expand those guardrails, but as of
23 right now, we don't know.

24 MR. GRAY: That's correct. They would
25 need to provide the technical basis for that, and we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 would scrutinize that.

2 VICE CHAIR HALNON: All right. Thank you.

3 MEMBER BALLINGER: This is Ron Ballinger.
4 It's later in your slides, but they've already taken
5 mitigated measures in reinforcing things as part of
6 the process.

7 Where there was expansion that was going
8 to violate rules, they've buttressed things up and
9 provided reinforcement already. So there is a
10 solution to that part.

11 VICE CHAIR HALNON: Thank you. That's
12 helpful.

13 MR. DAUN: Okay. Next slide, please.

14 So that was the ASR expansion portion.
15 Now, effects of ASR. We'll move into the building
16 deformation.

17 The previous two slides covered how
18 Seabrook addressed ASR's impact on material properties
19 of concrete or ASR's impact on the capacity of the
20 concrete. The next two discuss building deformation
21 due to ASR and how it impacts the demand or loads on
22 the structures.

23 There's a few pictures here I'll talk
24 about. During routine walk-downs in 2014 and 2015,
25 the NRC resident inspectors observed degraded seismic

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 and fire seals that appeared to have been caused by
2 differential movement between adjoining concrete
3 buildings.

4 It was determined that ASR had caused this
5 additional aging effect through cumulative expansion
6 in ASR-affected structures and from expanding
7 structures pushing on adjacent structures.

8 Many structures at Seabrook are surrounded
9 by concrete backfill, which may also expand and apply
10 additional loads to structures, even if the structures
11 themselves are not experiencing ASR. These effects
12 were not anticipated and were identified as a
13 different consequence of ASR.

14 The large-scale test program did not
15 address how building deformation would affect the
16 ability for the structures to perform their intended
17 functions. Therefore, NextEra subsequently developed
18 an additional program called the Building Deformation
19 Monitoring Program to manage this effect.

20 This program includes a methodology for
21 evaluating ASR-affected structures. The methodology
22 was incorporated into NextEra's license amendment
23 request.

24 Bulk building deformation adds additional
25 loads to impacted structures. You can see in these

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 photos attached equipment. This is equipment spanning
2 two different Category I structures and the different
3 movement between those two structures.

4 The top right one is flexible conduit
5 couplings that had moved at different rates, or one
6 moved and the other didn't. And then the bottom photo
7 is lines that became crimped because of the different
8 movement between the two structures.

9 As resident inspectors, these are the
10 types of things that we're out in the field looking
11 for all the time. Any equipment impacts from building
12 deformation, we're keen to looking for those things,
13 knowing where the structures are, looking at how the
14 structures are impacting each other.

15 Next slide, please.

16 Okay. NextEra developed a three-stage
17 analysis methodology to address ASR loads and
18 associated building deformation along with the
19 original design loads. The methodology uses field
20 measurements to estimate the ASR loads both in the
21 structure itself and in surrounding concrete backfill,
22 and then applies the load to the structure as if it
23 were a design load.

24 The measure becomes more detailed in order
25 to better capture the ASR load as the analysis stages

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 progress. And I'll talk about the three stages here
2 in a second.

3 The analysis identifies quantitative
4 acceptance criteria in the form of monitoring
5 parameters and limits that demonstrate the capacity is
6 greater than or equal to the demand, including the ASR
7 loads. These parameters are monitored against the
8 corresponding limits going forward.

9 If a structure approaches or exceeds the
10 acceptance criteria, it is entered into the Corrective
11 Action Program and may be re-evaluated with a higher
12 stage analysis, or a structural modification may be
13 implemented to add additional margin.

14 So the three stages is, Stage 1, you use
15 the original code equations, plus you add an ASR load
16 factor based on those monitoring results.

17 A Stage 2 evaluation, you do some finite
18 element modeling and then add those original code
19 equations with ASR load.

20 And then a Stage 3, which is the most
21 accurate, there you do a full finite element model.
22 And then you take additional field measurements to try
23 to better quantify that ASR impact.

24 Next slide, please.

25 Here's a methodology life cycle overview

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 for the Structures Monitoring Program or the Building
2 Deformation Program. We already talked about the
3 three stages.

4 The first thing they do, they determine
5 which stage that structure falls within. Is it a
6 Stage 1, Stage 2, Stage 3 structure? They always
7 start at Stage 1 and do original calculations, and
8 then they'll move on to Stage 2 and Stage 3 as
9 appropriate.

10 Then a structural analysis and evaluation
11 of the structure is performed. From these analyses,
12 critical areas based on available margin are
13 identified for additional monitoring.

14 After analyzing the structure, you apply
15 a threshold factor for each structure, which
16 quantifies the remaining margin between the factored
17 loads, which includes the ASR loads, and the capacity
18 of the design acceptance limit.

19 A set of monitoring parameters with
20 corresponding threshold limits are also determined for
21 each structure. Any deviations are then entered into
22 the Corrective Action Program for disposition and
23 resolution. Then the life cycle starts over again.

24 This will continue for the life of the
25 structure. And structures can move from a lower stage

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 to a higher stage, but they continue within -- even
2 after remediation, they'll stay within this life cycle
3 and continue to be monitored and evaluated.

4 Next slide, please.

5 VICE CHAIR HALNON: Travis, the three
6 phases, I assume you enter into the phase 1 because of
7 an observation or inspection that looks like there
8 could be an effect.

9 MR. DAUN: All structures enter as Stage
10 1. And Nik may --

11 VICE CHAIR HALNON: Okay. So all the
12 structures --

13 MR. FLOYD: Just a quick correction there.
14 As far as when you kick into this, this is all part of
15 the Building Deformation because this is when you
16 start recalculating the building load demands to
17 include ASR. You don't enter this process really
18 until you visually see ASR or some other indirect
19 observations of ASR in the structure.

20 I can tell you every single structure at
21 the site, seismic Category I structure, has been
22 evaluated using this process, except for one service
23 water access vault where they determined it does not
24 have ASR.

25 Every other structure, they've gone

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 through this process and determined there's visual
2 indications of ASR, or there's cracking that suggests
3 there's backfill expanding and they've had to go
4 through this process.

5 VICE CHAIR HALNON: Over time, all the
6 structures of concern that have been put in here, how
7 many evaluations do they do? I don't know if you can
8 give a ballpark. In a quarter or a year or whatever,
9 how many evaluations are actually ongoing?

10 MR. FLOYD: They've completed all the
11 initial evaluations. At this point, the only
12 evaluations they're doing are when they have to do a
13 reanalysis for structures that they've determined were
14 outside the revised licensing basis.

15 So those are ones that are still in prompt
16 operability determination space. I'm going to go over
17 that in more detail in a subsequent slide.

18 VICE CHAIR HALNON: Okay. I'm interested
19 in how many are progressing through this. One of the
20 things that hit my mind was we see the headlines.

21 We see a finding, a non-cited violation,
22 or a minor violation in inspection reports, but we
23 don't know how many is a sample. If it's 100 percent
24 of what they do, then that's a problem. If it's one
25 of 10,000, then that's not a problem. We only see the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 peaks of it.

2 So I'm interested in just how many
3 evaluations are done and whether or not the Corrective
4 Action Program is serving where it's supposed to be
5 serving, which is to maintain continuous monitoring
6 and evaluation.

7 MR. FLOYD: Just to give you a ballpark,
8 in the program itself, it's either 28 or 29 structures
9 that they evaluated as a structure. Some of those are
10 grouped together.

11 There's certain groupings for manholes.
12 Rather than just say each manhole is an individual
13 structure, they say, hey, there's a set of manholes
14 here, and here's another set of manholes there. So
15 that's one structure, and that's a second structure.

16 The Diesel Generator Building, albeit two
17 separate structures that share a wall, they evaluate
18 it as a single structure. I've got it on a subsequent
19 slide. It's either 28 or 29. They've completed all
20 those initial evaluations, though.

21 And so now, what we've been looking at is
22 when they're doing monitoring and they approach their
23 established threshold limits -- those are some of
24 those areas they identified to have low margin before
25 they hit that demand-to-capacity ratio.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Once they hit that, they have to reanalyze
2 and say, okay, are you exceeding it? And if you
3 exceed it, put in new limits. And now you have to
4 reduce some conservatism.

5 So maybe reduce a load factor here or take
6 some additional things, like crack section properties,
7 load redistribution, but then you're in operability
8 determination space. You're no longer in conformance
9 with this revised licensing basis. And there's six
10 total structures out of that 28 or 29 that we're
11 monitoring currently.

12 VICE CHAIR HALNON: That are in prompt
13 operability space?

14 MR. FLOYD: Correct.

15 VICE CHAIR HALNON: And corrective actions
16 are in place to --

17 MR. FLOYD: Correct.

18 VICE CHAIR HALNON: -- get those out
19 eventually?

20 MR. FLOYD: Yes.

21 VICE CHAIR HALNON: Thanks.

22 MR. FLOYD: And the only other correction
23 there is not every structure enters through a Stage 1.
24 The Stage 1 is the most basic. You just take the
25 original design load calculations, and then you just

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 add in an ASR load.

2 So for some structures, for example, the
3 one we're going to discuss today, the containment
4 internal structure, they skipped past Stage 1. They
5 went straight to a Stage 2.

6 That's because they wanted to develop the
7 finite element models to more accurately represent and
8 calculate the ASR loads. They weren't sure what the
9 ASR loads were, so they had to go through that
10 progression and process. So they just skipped right
11 past Stage 1.

12 VICE CHAIR HALNON: Okay. Thanks.

13 MEMBER BALLINGER: This is Ron Ballinger
14 again. This was a two-unit site at one time. And a
15 lot of that concrete is in Unit 2. It's been
16 partially constructed.

17 Did anybody take a look and see what's
18 going on over there, just for grins and chuckles, I
19 guess, for information?

20 MR. GRAY: Having been here the longest,
21 maybe George would know, but I recollect that that was
22 discussed by the licensee, whether they would take
23 sections of material out of the canceled Unit 2.

24 MEMBER BALLINGER: Yes.

25 MR. GRAY: It was the weather that was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 uncontrolled for that, exposed continuously. And I
2 think there were industrial concerns with access. So
3 I'm just sharing with you.

4 MEMBER BALLINGER: Okay.

5 MR. GRAY: It was thought about and not
6 acted on for their part.

7 MEMBER BALLINGER: Okay.

8 MR. DAUN: Okay. Next slide, please.

9 This slide just summarizes licensing
10 actions associated with ASR at Seabrook. As stated
11 earlier, ASR degradation was not previously addressed
12 in the Seabrook licensing basis because irrelevant
13 design codes of record did not consider loads
14 resulting from the effects of ASR.

15 Therefore, NextEra submitted a license
16 amendment request to incorporate the expansion limits
17 and to get approval of a methodology to analyze
18 structures affected by ASR.

19 NextEra also updated their license renewal
20 application to include activities to manage the
21 effects of ASR-related aging on structures. Our
22 revisions were based on test results and ASR
23 methodology provided in the license amendment request.

24 Following an extensive review, the NRC
25 approved the license amendment request in March of

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 2019. This review included peer reviews from other
2 offices in the NRC, use of expert contractors from a
3 national lab, as well as reviews by the ACRS, and
4 adjudicated by the Atomic Licensing and Safety Board.

5 Next slide.

6 Here are several examples of various
7 monitoring parameters used at Seabrook and the tools
8 used to measure them. The picture on the left is an
9 example of a pin -- the top left is a pin-to-pin
10 measurement location, where a licensee tracks in-plane
11 expansion.

12 The picture on the right shows a seismic
13 gap that could be monitored based on the output of the
14 analysis so they know where the seismic gap initially
15 was and how that changes.

16 The bottom left is a typical example of an
17 extensometer. I'll note this is just the cover of the
18 extensometer. The extensometer is anchored into the
19 wall. Core bore, anchor the extensometer, and there
20 you can measure through-plane expansion or
21 through-wall expansion.

22 And then the bottom right is a crack gauge
23 used to monitor a specific crack location.

24 VICE CHAIR HALNON: If you have a
25 question, Dennis, go ahead.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 DR. BLEY: Yes, Dennis Bley. I hadn't
2 thought about the seismic gaps. Have any of those
3 narrowed to the point that they invalidate the
4 existing calculations for seismic and you had to
5 somehow mitigate that?

6 MR. FLOYD: Yes. There was one location
7 in the CEVA. That's the Containment Enclosure
8 Ventilation Area annulus region.

9 So between the Containment Enclosure
10 Building and the Primary Containment Building, they
11 have missile shield blocks. They were installed to
12 shield equipment and other things located underneath
13 them, pretty large. They're essentially slabs
14 connected to the CEB.

15 That gap, because of deformation -- bulk
16 building deformation of the CEB actually resulted in
17 contact in some areas and reduced gaps in others of
18 those missile shield blocks. And the licensee,
19 NextEra, went through corrective actions to restore
20 those gaps, which is essentially chipping away -- in
21 their case, they used a hole saw to help restore that
22 gap.

23 DR. BLEY: Okay. So it's always been
24 opening up the gaps again rather than putting in some
25 kind of cushioning material between them?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. FLOYD: No, not necessarily. It just
2 depends on where you're at in the structure. In some
3 cases, the gaps widen. In the case of the CEB and the
4 Containment Building, the gap had closed. So it just
5 depends on the relative movement of the two
6 structures.

7 In all cases, those seismic gaps are
8 established as threshold monitoring limits in their
9 Structures Monitoring Program. And they are monitored
10 on a periodic basis. I have looked at that data many
11 times.

12 DR. BLEY: Okay. Thank you.

13 MR. FLOYD: Yes.

14 MR. DAUN: Okay. Next slide, please.

15 So here is a summary of ASR license
16 conditions. I'm not going to go through each one, but
17 the NRC inspectors verify licensee performance to
18 these conditions. So this is what was added into
19 their operating license.

20 Several conditions ensure that test
21 program results remain applicable to Seabrook,
22 including the licensee to verify that the actual
23 measured expansion at Seabrook aligns with the
24 predicted expansion based on the developed
25 correlation.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Seabrook will complete an initial study no
2 later than 2025 and a follow-up study ten years later
3 to validate that the data that came out of their Texas
4 test program is still valid.

5 I'll note NextEra will be taking cores as
6 part of License Condition B, and those will be subject
7 to petrographic examination. I know that they've
8 already started taking those core bores. It's a large
9 number of core bores. They started that a few months
10 ago.

11 Next slide, please.

12 Okay, and then NRC inspection and
13 assessment of ASR. NRC resident inspectors perform
14 daily on-site oversight of the plant status. That's
15 reviewing corrective action reports, walk-downs. We
16 go through all the accessible areas of the plant,
17 looking at those building deformation signs and ASR
18 signs which are not as obvious as some of the building
19 deformation.

20 Inspectors select risk-informed and
21 performance-based samples, including Maintenance Rule
22 operability determinations, modifications when they do
23 retrofits, and then focused Problem Identification and
24 Resolution samples.

25 Regional specialists at NRR and Research

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 technical staff have performed focused inspections and
2 continue to perform focused inspections. The results
3 have been documented in their inspection report.

4 Even if there's no finding, we tend to put
5 a lot more information into those inspection reports
6 just for continuity. And then results and oversight
7 plans are discussed with Region I senior managers
8 during the end-of-cycle reviews.

9 Resident inspectors do provide real-time
10 feedback on potential ASR issues, such as when we're
11 going through condition reports. It's very easy for
12 me to reach out to Nik, get his thoughts on that. And
13 he can send those condition reports all the way up to
14 George at NRR, if needed.

15 Next slide, please. And I will turn it
16 over to Nik. You're done hearing from me.

17 MR. FLOYD: Thank you, Travis.

18 So since we last met with you all in April
19 of 2022, we have conducted five weeks of on-site
20 inspections. These are inspections with a team of NRC
21 inspectors, including myself. Oftentimes -- actually,
22 every time, I also rely on George Thomas at NRR.

23 We also utilize other technical expertise
24 from other offices. One in particular was from the
25 Office of Research. For those five weeks, we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 performed 11 total inspection samples. Again, these
2 are inspection samples dedicated specific to ASR.

3 And while these numbers seem -- maybe they
4 seem low or maybe they seem high, but they don't
5 reflect the total number of hours spent by the
6 resident inspectors at the site. They're really out
7 there looking at this stuff on a daily basis.

8 And then the same thing with the
9 Corrective Action Program when they're reviewing
10 condition reports. If they see anything that jumps
11 out, they're sharing that information with us.

12 So even though we're only getting five
13 weeks -- it's approximately every six months, so it's
14 actually a pretty good touch point -- we're still
15 getting direct feedback as far as the licensee's
16 activities at the site.

17 While I do spend my time at Seabrook
18 reviewing ASR almost exclusively, there are other team
19 inspections that visit the site, two in particular
20 here. One was the Biennial Problem Identification and
21 Resolution Inspection Team. A second one was one of
22 our focused engineering inspections, the Age-Related
23 Degradation.

24 They're aware of ASR at the site,
25 sometimes through their sampling. In this case, in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 their sampling during the two team inspections, they
2 did review samples related to ASR. And in one of
3 those cases, they identified a corrective action
4 finding, which I'll discuss in a subsequent slide.

5 Next slide, please.

6 So I just want to highlight two things for
7 you. We continue to conduct inspections focused on
8 ASR. I just discussed that on the last slide. Based
9 on those inspections, we have determined that the
10 Seabrook structures remain capable of performing their
11 intended safety functions.

12 What I mean by that is NextEra, they're
13 monitoring the ASR in the structures, and they're
14 updating those structural calculations as necessary to
15 ensure adequate capacity remains in those structures.

16 And the second item here is out of those
17 inspections, we did identify three inspection
18 findings. We documented those in our inspection
19 reports. They were all related to ASR.

20 We did find them to be of very low safety
21 significance. So when you go through the NRC's
22 Significance Determination Process, that would screen
23 out as a green inspection finding.

24 In each case, NextEra has addressed it in
25 their Corrective Action Program. And I am going to go

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 through those three findings in a subsequent slide.

2 Two other things I wanted to highlight
3 here is there's two photos down below. The photo at
4 the bottom left, that's our inspection team from March
5 of 2024. No, it does not look that interesting, but
6 sometimes you get out in the site and sometimes you
7 have to review the detailed design calcs.

8 The other thing I wanted to highlight is
9 there are two staff in there that are there for
10 knowledge transfer purposes. One of the questions
11 that the NRC has received is, how are you going to
12 maintain oversight of ASR at Seabrook? What happens
13 when you move on to your next employment opportunity,
14 whether it's a promotion or otherwise?

15 Well, this is how we do it. They just
16 joined that Civil and Structural Engineering Branch
17 with George. So we brought them at the site to
18 knowledge transfer, knowledge management, and bring
19 them up to speed on ASR.

20 The picture at the bottom right, that was
21 from later in the month that year. And that was a
22 Commissioner Crowell visit to the site.

23 So we do get a series of NRC management
24 that visits the site, including commissioners, and we
25 do tour them around the site. We show them the ASR

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 areas that are affected just to highlight that, yes,
2 this is a damage and degradation mechanism, it's real,
3 and here's what it looks like.

4 Next slide.

5 So to follow up on one of the questions
6 from earlier -- I think this came from you, Greg. You
7 were asking about the total number of structures in
8 the program. Here is just a summary of that.

9 There are 28 total structures. And again,
10 that number can be slightly deceiving because
11 sometimes there are, some could say, two or three
12 structures within one of those numbers. And that's
13 just how the licensee chose to evaluate that.

14 Out of the 28, though, there are six
15 structures that are currently outside the licensing
16 basis. What I mean by that is that when we look at
17 the licensing basis, that's the original concrete
18 design code equations that have been revised in
19 accordance with that license amendment to include ASR
20 loads. And that also includes all the load factors,
21 plus a margin for additional ASR expansion.

22 So you can't put a planned expansion of
23 one for ASR. You have to include ten percent, 20
24 percent, 30 percent. And you have to include margin
25 for that structure to continue to expand because we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 know ASR is not static.

2 We have reviewed all six of those prompt
3 operability determinations. Several of those
4 structures, yes, several of them we have re-reviewed.

5 So they established operability limits.
6 Those are new limits that they increase their margin
7 just slightly. They don't take all the margin away.

8 And maybe, hey, you can tolerate ten
9 percent more expansion, but they still remained well
10 below the demand-to-capacity ratio of 1 even with that
11 margin reduction, and they reanalyzed because they had
12 continued expansion.

13 Well, we wanted to go back and see, how
14 are you managing that? Are you actually approaching
15 your ultimate limit, or do you still have substantial
16 margin for expansion? So that's one of the things
17 we've done when we've looked at some of those
18 reanalyses.

19 We did determine in each one of those
20 cases that they did perform detailed evaluations to
21 confirm that they're able to perform their design
22 functions.

23 And one of the things I wanted to point
24 out here is specifically in our Third Quarter 2023
25 Inspection Report, we tried -- well, we didn't try --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealgross.com

1 we did document the technical approaches used by the
2 NextEra staff for how they demonstrate that continued
3 functionality.

4 So we wanted to highlight, hey, here are
5 those, because again, this was a question we were
6 asked. Now you're outside your code and design
7 equations, what are those technical approaches?

8 Well, many of them are consistent with
9 existing engineering consensus standards. Going back
10 to ACI or the American Society of Civil Engineers,
11 yes, they are consistent.

12 And the last piece of this is when you're
13 in prompt operability determination, how do you
14 continue to monitor that? Well, in many cases,
15 there's supplemental monitoring that's established in
16 conjunction with the existing monitoring.

17 And they're done at an increased
18 frequency. In this case and many of them, they're
19 every two months. In some cases, it's every one
20 month.

21 And then the last piece here is we've
22 looked at the evaluation, but what are they going to
23 do with the structure now? Now we're into the
24 corrective action space. So we look at how the
25 licensee is managing that in their Corrective Action

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Program to bring them back into conformance with the
2 licensing basis.

3 And there's really two options there. You
4 either physically modify the structure to strengthen
5 it or you reanalyze it. In some cases, reanalysis is
6 not an option. You have to do a physical
7 modification.

8 Two structures in particular that have
9 ongoing modifications are the Control and Diesel
10 Generator Building and then the Emergency Feedwater
11 Pumphouse. Those two are planned for physical
12 modification. The other four structures are still up
13 for potential reanalysis.

14 Next slide, please.

15 CHAIR KIRCHNER: For the record, could you
16 just enumerate what the other four structures are?

17 MR. FLOYD: Yes, I can. The other four
18 structures are the Primary Auxiliary Building, the
19 Service Water Cooling Tower, the Containment Enclosure
20 Building, and the Residual Heat Removal Vault.

21 Next slide.

22 VICE CHAIR HALNON: We've got a question
23 from one of our consultants.

24 Steve, do you want to go on?

25 DR. SCHULTZ: Yes. Thank you.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 The question is, you mentioned four of the
2 structures are in consideration for analysis,
3 improvement, and evaluation. What's the time scale of
4 what's being proposed and what will be done there?

5 In other words, if we meet a year from
6 now, are there still going to be six or will there be
7 -- what will happen going forward? Can you provide
8 some detail about what that means in terms of analysis
9 time frame?

10 MR. FLOYD: Yes. One of the items of
11 consideration that we've had from our oversight is
12 timeliness of corrective actions.

13 Defined in our process, or even if you use
14 the licensee's procedure, usually they try to do
15 corrective actions commensurate with safety
16 significance, which is usually on the order of a
17 single operating cycle.

18 For Seabrook, that would be 18 months. I
19 put long-term here because these are not one-year
20 projects. These are on the order of years.

21 The last time that was communicated to us
22 when we reviewed Seabrook's projections for the two
23 structures that are undergoing modifications right
24 now, they were projecting out to 2026 for planned
25 completion of the physical modification with the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealgross.com

1 supporting analysis.

2 Once you complete the modification, you
3 have to ensure that you meet those as-built drawings
4 and it meets your reanalyzed condition for that
5 additional capacity. So for those two structures,
6 again, that was the projected time line. It was 2026.

7 For the other four, when we look at the
8 expansion data -- we're always trying to risk-inform
9 our inspection process. The licensee is trying to do
10 the same thing. It was one of the items when we were
11 saying, what do your expansion trends look like? Can
12 you support operability or functionality for the
13 duration of your corrective actions?

14 In the case of the other four structures,
15 the answer to that is yes. I don't have a specific
16 time line for those structures. They're constantly
17 prioritizing what's the next one to come up. They're
18 using a structural contractor for this, so they have
19 to send that out to the contractor. The contractor is
20 also supporting the modifications.

21 It would be difficult for them to do all
22 six structures at once, so they have to prioritize
23 which structures to do first. So they have the two in
24 progress. They'll probably have a third one coming
25 up.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Essentially, in the future -- we're going
2 to have a meeting soon. And we're going to have to
3 discuss their next time lines because we are moving
4 forward, I would say, the focus from evaluations.
5 That's where we initially had it. And now we're
6 moving forward to looking at the modifications
7 themselves; or if they reanalyze, we'll look at that.

8 So I don't have a specific time line.
9 That was a very long-winded response to your question,
10 but just kind of wanted to cover it from the start to
11 end there.

12 DR. SCHULTZ: When you say you're going to
13 get together soon to have another meeting to discuss
14 time lines and so forth, does that tie into the
15 six-month evaluation that is in the license
16 conditions?

17 MR. GRAY: Let me take that.

18 MR. FLOYD: I think Mel wants to comment.

19 MR. GRAY: It does not. This is our
20 internal plans for inspecting at Seabrook, and we are
21 there about every six months by our own choice. We
22 think that's appropriate for the situation right now.
23 There is a license condition, but it wasn't driven by
24 that.

25 I would add that the focus of our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 inspections, as Nik has stated, is that the licensee
2 maintains margin for these six structures that informs
3 the pace of corrective actions. And we expect them to
4 have a technical basis for the timing of their
5 corrective actions.

6 The two structures that you mentioned have
7 a rather firm 2026 date. The information we've seen
8 on-site is not that much longer than that. It's not
9 many years. It's a few.

10 So we are looking for the licensee's
11 performance to move all of these structures within
12 their licensing basis, and then just demonstrate
13 continued monitoring and corrective actions prior to
14 getting in POD space. That's where we are looking to
15 transition towards. Our oversight would then beyond
16 the safe modifications that restore and increase
17 margin going forward.

18 So I think that was some of the underlying
19 thought processes behind the questions. I'll go back
20 to Nik or open it back to ACRS.

21 DR. SCHULTZ: Thank you. Both the
22 responses are very helpful. Thank you.

23 VICE CHAIR HALNON: One last follow-up.
24 So there's two ways of fixing things: you modify it to
25 get back within the licensing basis or you change the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealrgross.com

1 licensing basis.

2 If that's the case, will these require
3 license amendments if the reanalysis shows that I
4 don't want to modify, but I can safely expand my
5 limits?

6 MR. FLOYD: No. There's been no
7 indication to go outside of the current licensing
8 basis.

9 Reanalysis in some cases -- just to give
10 an example, for the Service Water Cooling Tower, there
11 was a couple areas where it was difficult to get
12 access to monitor the ASR. We're talking very far
13 down. In some cases, it's below water level.

14 And so they made a conservative assumption
15 on the ASR expansion level. Well, because of that,
16 that drives up the load demand in the structure. If
17 and when they're able to actually take that data, the
18 consideration is you can reduce that load demand and
19 then bring it back into conformance. That's one
20 example.

21 It's just getting additional monitoring
22 data to support their underlying assumptions in the
23 original load calcs, but in no case have they
24 indicated to go outside or do something different than
25 that modified code equation that includes ASR.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So there's no process in place right now,
2 or at least no actions in place, by the licensee to go
3 outside of that and submit a license amendment action.

4 VICE CHAIR HALNON: Okay, but it would be
5 subject to your approval if they do go outside?

6 MR. FLOYD: If they deviated from the
7 methodology and declared victory and said, this
8 structure is operable and in conformance, we would
9 differ there. And that would be a full engagement.

10 VICE CHAIR HALNON: Thank you.

11 MR. FLOYD: Yes.

12 MEMBER BALLINGER: I have a clarifying
13 question. We're talking about margin, load demand,
14 and the like.

15 These structures are all designed in
16 accordance with a code of some kind, ACI or something
17 like that. I know the ASME Code that if it's designed
18 in accordance with the code, there's already a factor
19 of 3 margin there.

20 I'm not sure about what it's like for the
21 concrete codes. Is there a built-in margin when you
22 use a code which is not accounted for here, but is
23 present?

24 MR. FLOYD: Yes, that's correct. For each
25 load, there is a load factor applied. So inherently,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 there is margin when you add those up.

2 George, I don't know if you want to add
3 anything to this specific to Seabrook.

4 MR. THOMAS: Yes. There are design
5 margins incorporated into the coding in terms of load
6 factors, best estimate loads for expansion and
7 capacity reduction factors.

8 MEMBER BALLINGER: I didn't hear
9 everything, but you're saying that there's code-
10 built-in margin --

11 MR. THOMAS: Yes.

12 MEMBER BALLINGER: -- which is always
13 there, which doesn't factor into any of this? It's
14 just there because you've designed in accordance with
15 the code?

16 MR. THOMAS: Yes.

17 MEMBER BALLINGER: Thank you.

18 MR. DAUN: One thing that was brought up
19 a little bit earlier was we were talking about when
20 they would exceed their ASR expansion limits. And I
21 think --

22 MR. BURKHART: Just for people out there,
23 please do not mute Sandra Walker's mic as that is the
24 mic for this room.

25 CHAIR KIRCHNER: For the Teams mic.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 MR. DAUN: Nik, I don't know if you want
2 to add in more.

3 Once they hit that expansion limit,
4 they're outside the guardrails. Even if you do
5 modifications to address the building defacement and
6 load-to-capacity ratios, you're still outside the
7 structural bounds of the expansion limits. That was
8 brought up a little bit earlier. I wanted to find a
9 good time to bring it up.

10 MR. FLOYD: This is a perfect segue to the
11 next slide because my next two are going to cover some
12 of these corrective actions, which are really the
13 physical modifications.

14 As we've been describing, there's two
15 options. The physical modification -- and I want to
16 correct something that Travis said. It's not
17 remediation. You can't remediate ASR.

18 Remediate would insinuate that you're
19 removing the ASR and that process for expansion stops.
20 You can't do that unless you completely remove an
21 entire wall or entire floor. You'd have to remove the
22 old concrete and put new concrete in its place.

23 So really, what's happening is it's a
24 retrofit. You're adding a physical modification to
25 the existing structure. So that's option 1.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 I added these three figures here just to
2 kind of show you a schematic representation of what
3 that looks like, what's currently been used at
4 Seabrook Station. And then on the following slide,
5 I'll show you a couple of pictures.


6 The first one, it's called strong backs.
7 What this is is through-wall reinforcement. You have
8 a through-wall anchor that goes to the back wall of
9 the existing reinforcement, and then you have a tie on
10 the outside. You bolt it down, and that provides your
11 shear or through-wall reinforcement.

12 The second example is corner braces. It's
13 as simple as it looks. It is a brace that braces the
14 wall to the floor element.

15 And then the third one is vertical plates.
16 And you can use the vertical plates with the existing
17 strong backs -- that's the easiest way -- or you can
18 do partial through-wall reinforcements to anchor it,
19 but the idea here is you install thick metal plates to
20 resist vertical expansion in the structure.

21 Why would one choose one method over the
22 other? It just depends on what is the challenging
23 demand on the structure that you're trying to resist.

24 Is it a bending moment? Is it vertical
25 expansion due to maybe backfill? Is it maybe shear



1 reinforcement that you need at the bottom of the wall,
2 again, due to the bending moment in the wall? So it
3 just depends on the application.

4 And then as far as the reanalysis, I gave
5 one example. Maybe it's to verify an assumption.
6 Another case would be, let's say, the structure starts
7 off at Stage 1. It's the simplest way to do it. You
8 take your original design code equations, and you just
9 add ASR load.

10 Well, what's the next step? Stage 2 or 3,
11 you develop a finite element model and then calculate
12 the ASR loads. And then in Stage 3, you're redefining
13 some of those original design loads.

14 So now you're actually using in-situ
15 comparisons to formulate those. That takes a lot more
16 effort and a lot more time. And again, that's why you
17 have to prioritize which structure to go after first.

18 So there are those other options that
19 reanalysis will provide for the licensee. And it is
20 all laid out in the NRC-approved methodology, so it's
21 nothing new that they're doing outside the licensing
22 basis. It's all within that approved methodology.

23 Next slide.

24 So real quick, I just wanted to show a
25 couple pictures because these are completed now within

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the plant. The first one are an example of the
2 vertical plates. That is the Fuel Storage Building.

3 Now, this was not a building that was in
4 prompt operability determination space. This was a
5 proactive reinforcement. And you might ask, why be
6 proactive? Well, two reasons.

7 One, it was for -- this is according to
8 the licensee -- this was for proficiency of their
9 maintenance technicians to perform that work. And
10 it's easy to access. This is right on the outside of
11 the building. You can walk right up to it and not
12 have to be around existing operating plant equipment.

13 You can also see here -- I just wanted to
14 illustrate this. You can see the existing monitoring
15 equipment still in the photo. There's an extensometer
16 just outside the plates and then one right in the
17 bottom left of the plates.

18 So again, they're not remediating ASR.
19 They're retrofitting it. You still have to continue
20 to monitor for ASR expansion because that's what the
21 program requires.

22 Just to the right of that is the ASR grid.
23 There's little slots. It's kind of hard to see in
24 this photo, but again, they've retained the ability to
25 continue to monitor the structure.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 The figure on the --

2 MEMBER HARRINGTON: This is Craig
3 Harrington.

4 MR. FLOYD: Yes.

5 MEMBER HARRINGTON: Before you move to
6 that, can you explain why the top of those plates is
7 bolted and the bottom seems to be just free?

8 MR. FLOYD: Yes. I apologize. I should
9 have went into the background on this a little bit.
10 It's actually excavated down about five or six feet.
11 I don't have the exact dimensions.

12 So where you see the black there, that's
13 been backfilled and then tarmacked on top. They're
14 bolted below-grade into the wall. You're only seeing
15 the top, essentially, the top two-thirds.

16 MEMBER HARRINGTON: Thanks.

17 MR. FLOYD: Yes, you're welcome.

18 And then the picture on the right here --
19 actually, that's me in the photo with the scrubs and
20 the hard hat -- this is an example of the corner
21 braces. And then you also see the strong backs. So
22 this was, I want to say, reactive, the opposite of
23 proactive.

24 This was a modification done on the
25 Mechanical Penetration Area to bring that structure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 back into conformance. So there was a couple of load
2 demands that they needed to resist, and these were the
3 two retrofit options that were chosen by the licensee
4 to be installed there.

5 That structure, last time we spoke in
6 2022, was in POD space. It has now been pulled out
7 because it has been restored to conformance in
8 accordance with their licensing basis.

9 VICE CHAIR HALNON: Are those strong backs
10 in addition to --

11 MR. FLOYD: Say that again?

12 VICE CHAIR HALNON: Are those strong backs
13 on the wall in addition to a buttress?

14 MR. FLOYD: Yes. They are separate.

15 VICE CHAIR HALNON: Okay, so we shouldn't
16 take those as isolated. These are obviously working
17 together to bring it back into --

18 MR. FLOYD: They are working in unison.
19 And as you can see -- this is an example -- it's not
20 going to be one or two of the strong backs. There's
21 going to be a number of those as part of that
22 through-wall reinforcement.

23 MR. DAUN: And then on the opposite wall,
24 you've got even other things. We just didn't include
25 it all.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 VICE CHAIR HALNON: You're squeezing it.

2 MR. FLOYD: Next slide, please.

3 Based on a combination of inspections --
4 so this is our ASR-focused inspections, and in one
5 case which I'll point out, it was from our Biennial
6 PI&R Team inspection -- the NRC has identified three
7 findings, all of which were of very low safety
8 significance.

9 In each one of these cases, they were
10 unique performance issues. They were all related to
11 ASR, but for different reasons for why we documented
12 the findings. This does highlight the fact that
13 continued focus is warranted, continued focus by the
14 licensee on implementing their programs as well as
15 continued focus via oversight by the NRC.

16 We did review the three findings at the
17 time and made sure that they were entered in the
18 NextEra Corrective Action Program. I'm going to cover
19 the three of these in more details on the next slide,
20 but just wanted to provide you the summary really
21 quick.

22 Next slide.

23 I'll start with the picture on the right.
24 This was from our Second Quarter 2022 inspection.

25 This was a failure of NextEra to install extensometers

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 in seven ASR Tier III locations.

2 What I mean by Tier III -- we briefly
3 covered it in the ASR background, but they developed
4 three tiers for ASR. The third tier is when you reach
5 one millimeter per meter in-plane expansion. At that
6 point, an extensometer is required to be installed to
7 monitor through-wall expansion.

8 Why that's important is through the test
9 program, what was identified is that in-plane will
10 essentially plateau. And then the remainder of the
11 expansion, because it's only two-way reinforced, will
12 be expansion in the through-wall direction. So it's
13 essential for multiple license conditions to have
14 these extensometers installed in the plant.

15 What we identified going through the
16 program is that there were seven Tier III locations
17 that were identified by the licensee, and they had not
18 installed extensometers. And it had been that way for
19 a number of years.

20 When you review the license conditions, in
21 one instance, they require the through-wall expansion
22 to be monitored on a six-month basis. Well, if you go
23 years, not every six months, that's not timely, hence
24 why we wrote the violation.

25 And I can tell you, to date, all seven

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 have been installed. We followed up on that on a
2 subsequent ASR inspection, so that finding has been
3 corrected.

4 Any questions on that finding before I
5 move to the next one? Okay.

6 DR. SCHULTZ: Sorry, this is Steve
7 Schultz. What was the root cause associated with
8 that?

9 MR. FLOYD: That was -- and I would be
10 speaking on the licensee's behalf for this, but based
11 on discussions and based on the inspection, they had
12 work orders in place for when areas reached the Tier
13 III threshold to install extensometers. At some of
14 the seven locations, they had a work order in place.
15 Somehow they got lost in translation. I don't know.

16 That would be a good question for NextEra.
17 I never did get a good answer on how they got left
18 out. Not so much that they got left out, but the fact
19 that they have a proper tracking mechanism in place.

20 One of the observations I did provide to
21 them at the time is in the Structures Monitoring
22 Program, they have tables which track all their
23 monitoring locations. Well, they had separate tables
24 for the extensometers, and then a second table for
25 their Tier II and Tier III locations.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 I provided the observation that it would
2 be useful to have, basically, a cross-reference for
3 the Tier III and extensometer install locations. So
4 they actually did implement that as a corrective
5 action. I feel certain that will help going into the
6 future, but it doesn't answer your question on why
7 this happened in the past.

8 DR. SCHULTZ: It somewhat identifies the
9 root cause. And what you're saying is that
10 programmatically, they've corrected their approaches
11 so that reoccurrence is not likely?

12 MR. FLOYD: I would feel confident in yes
13 to that response.

14 DR. SCHULTZ: Thank you.

15 VICE CHAIR HALNON: Just a quick time
16 check. It's ten minutes until the end, but we do have
17 some discretion towards the end. A prompt for members
18 to maybe hold your questions to the end unless there's
19 something burning that you need to ask.

20 MR. FLOYD: Okay. I can speak pretty
21 quick. So if I go too fast, just slow me down.

22 VICE CHAIR HALNON: Put on your running
23 shoes and go for it.

24 MR. FLOYD: In the top right, this was a
25 finding identified this year by the Problem

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Identification and Resolution Inspection Team. In
2 fact, they contacted me when they identified this. I
3 provided them technical assistance.

4 What you see here is, this is in their
5 Emergency Feedwater Pumphouse. Circled in blue is the
6 support for the instrumentation tubing. You can see
7 the tube right above the blue circle.

8 Well, due to fault deformation -- again,
9 here we're getting to why that Deformation Program is
10 important. That's the CEB. That's the Containment
11 Enclosure Building.

12 That building had shifted or deformed
13 towards the Emergency Feedwater Pumphouse and resulted
14 in contact with that tube support. Well, you can't
15 have two structures contacting one another. You have
16 to retain a seismic gap. So what we did is we -- the
17 team identified that.

18 The second piece is circled in red. Based
19 on that impact, there are resulting stresses imparted
20 on that square tube support that's welded to the
21 column. You actually see a crack in that tube support
22 piece. It partially cracked down the length there,
23 hence, again, why it's important to monitor these
24 items.

25 When we did a backwards look at this, we

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 saw in the Structures Monitoring Program they had
2 previously -- they being the licensee -- previously
3 identified it and had not taken corrective action in
4 a timely manner. And this was over the order of
5 years. This was what I would consider a relatively
6 easy action to take to restore conformance.

7 So we wrote the corrective action
8 violation. It has since been restored. And the
9 inspection team did look at other supports in that
10 room, just seeing was there any other supports
11 contacting the structure.

12 This is something that does get looked at
13 by the licensee. They actually had documented it in
14 their inspections of the structure as part of the
15 Structures Monitoring Program. They just failed to
16 take corrective actions.

17 And in the bottom right, that was a
18 finding from our First Quarter 2024 Report. This is
19 specific to the containment internal structure. I'm
20 going to save that discussion for a subsequent slide
21 because I have more details on it, but we will circle
22 back to that.

23 Next slide.

24 So here's just a brief time line of the
25 containment internal structure issue. This initially

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 started going back to 2021 during Seabrook's fall
2 refueling outage. The NRC inspectors became aware of
3 cracking and spalling in the reactor cavity pit area
4 of the containment internal structure.

5 Note this is normally an inaccessible area
6 during operation. It's a high-rad area. Actually,
7 it's a locked high-rad area. It's even higher than
8 that. Simply, it just provides an access point for
9 personnel and serves as a support for some reactor
10 ventilation duct work, as well as it provides a
11 pathway for the in-core instrumentation that goes to
12 the vessel.

13 I am going to cover some pictures of those
14 conditions that we observed, and that will be on a
15 subsequent slide. I just wanted to highlight here
16 that, yes, we did document a finding on that. That's
17 actually how we got to where we're sitting right now.

18 The licensee had visual indications of ASR
19 that we considered as possible or likely. We did not
20 see your typical ASR in the concrete itself, but what
21 we did see is that there was potential that what was
22 on the other side of the wall -- again, be it backfill
23 or the containment foundation mat -- something was
24 externally acting or potentially externally acting on
25 the structure that potentially resulted in that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 cracking.

2 As a result of that, the licensee should
3 have entered that into their program and evaluated it
4 for ASR. Therefore, we documented the finding.

5 In response to that, the licensee
6 documented a prompt operability determination. Again,
7 this is in 2021. We reviewed that.

8 And this was a margin argument where they
9 applied reasonable ASR loads and said, yes, the
10 structure is still able to withhold ASR. That's not
11 the Stage 2 evaluation, though, so it was good for the
12 interim.

13 Fast forward, licensee completed root
14 cause studies -- I'm going to cover those in a lot
15 more detail in the next slides -- performed root cause
16 studies to best estimate the amount of ASR in the
17 structure. Since you didn't have your typical ASR in
18 the concrete, it was difficult for them to approximate
19 it, so they had to develop finite element models.

20 They also took a substantial amount of
21 measurements in that area and inputted it into the
22 model to best estimate and understand why they were
23 seeing these structural distresses. They completed
24 that in April 2023, used the results of that root
25 cause study in their official structural evaluations,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 and completed those in November of 2023.

2 And then in March of this year, we were
3 able to go on-site and review those root cause studies
4 as well as the completed structural evaluations. As
5 a result, we did identify one finding, which I will
6 discuss.

7 I know there's going to be questions, but
8 let's just cover a quick overview of the CIS. And
9 then we'll go through each step of that process.

10 So here's the containment internal
11 structures layout. I realize now it's kind of
12 difficult to read on the screen. I apologize for
13 that.

14 In blue at the bottom is the reactor pit
15 area. That is the area that's below the negative-30
16 feet. There's also a four-inch-thick concrete fill
17 mat that begins at elevation 26.

18 And then the superstructure is above that.
19 That is the slab walls, columns, including the primary
20 and secondary shield walls; basically, everything you
21 see in this picture. What is not part of the
22 containment internal structure is the concrete
23 Containment Building foundation.

24 That's that 12-foot thick -- it's ten feet
25 thick. It ranges down to six feet underneath the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 reactor cavity pit area. That's that pink-reddish
2 crosshatch. It does not include that, and it does not
3 include the cylinder or the containment dome. So it's
4 everything else inside of containment.

5 Next slide.

6 NextEra approached this issue with
7 multiple steps. They wanted to understand why they
8 were seeing the distresses that they were seeing in
9 the containment internal structures.

10 It wasn't just in that reactor cavity pit
11 area. What they did see was spalling, cracking in the
12 reactor cavity pit, but there were distresses observed
13 in other areas of the containment internal structure.

14 If you ever walk around a containment,
15 typically on the fill mat, sometimes you'll see cracks
16 in the fill mat slab. Sometimes you'll see cracks in
17 walls. They wanted to understand what was the cause
18 of all the cracking observed throughout the structure.

19 So the first step was to collect data
20 through field measurements. That was locating all the
21 cracks, crack locations, collecting temperature, going
22 back and looking at history of the spalling, really
23 just collecting the full data that's going to inform
24 their model.

25 The second piece of that is they developed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 finite element models. One was specific for heat
2 transfer because the original design calc just had an
3 assumed design temperature. They wanted to better
4 understand the in-situ loads from operating
5 temperatures. And then the second finite element
6 model was an actual stress model.

7 As a result of the models, they performed
8 parametric studies. So what I mean by that -- I'll
9 have a graphical picture as well as a summary table --
10 essentially, they were varying the amount of
11 differential temperature loads throughout the
12 structure, trying to understand.

13 Could it be 100 percent temperature; could
14 it be no temperature? Could it be 100 percent ASR;
15 could it be no ASR? And then varying the amounts of
16 the two in combination to understand, okay, here's the
17 inputs; what's the results?

18 And then compare that to the field
19 measurements that they obtained from their walk-downs.
20 Did it make sense that this amount of thermal and ASR
21 load resulted in this cracking or this spalling?

22 Once they were completed with the
23 parametric studies, they documented the results in
24 root cause reports. There were three specifically.
25 And then they utilized those results as the input to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the Stage 2 structural evaluations.

2 So now, let's go through some of the
3 details here. This is going back to the reactor
4 cavity pit area that caught our attention in 2021.

5 This is step one, the field observations.
6 This goes through a review of the past monitoring
7 program walk-downs. They also did additional walk-
8 downs in 2021, 2023, and then used field observations
9 for the remainder of the CIS.

10 Some of the conditions -- and I'll show a
11 couple more in the next slides -- there was cracking,
12 horizontal cracking along the walls. There was
13 spalling on the pit slab, which is the reddened area.
14 And there was also cracking and bulking of some of the
15 other structures. The next slides will be a little
16 bit more helpful.

17 So again, this goes to 2021, the area that
18 caught our attention. If you look, the left picture
19 is just a schematic. Then there's arrows that point
20 to what was actually observed.

21 So in 2021, we saw that this area had
22 spalled. Licensee discovered and captured it in the
23 CAP. That's what brought our attention.

24 This area was previously repaired due to
25 spalling in 2012. That seems pretty unusual for any

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealgross.com

1 concrete structure at a nuclear power plant, that
2 repeat spalling, which was just one of the indicators
3 that caught our attention.

4 The second item here is the steel grating.
5 That was actually buckled -- and you can see it in the
6 picture on the right -- due to what is some type of
7 deformation. There's something going on specific to
8 this area. So those are some of the observations we
9 were seeing.

10 I do want to note here, this area that
11 spalled, the licensee has installed -- well, one, they
12 repaired the spalled area. They chipped away the old
13 concrete and put new concrete back, but they've
14 installed an encapsulation device on this area, this
15 perforated steel panel that encapsulates it. So if it
16 does resfall again, it will catch any of that spalled
17 concrete.

18 One of the items -- and I'm kind of
19 jumping ahead here -- that was identified in the root
20 cause in addition to thermal loads is that this is a
21 high-stress concentration area. To the right there is
22 a cutaway for the cooling ductwork.

23 Well, you have a one-inch-thick slab in
24 between two large concrete walls. It produced a very
25 high-stress concentration in this area. So that was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 one of the items that they identified in the root
2 cause study, hence why they installed the
3 encapsulation device, because there is a chance in the
4 future it could spall again. And that's not good.

5 Next slide.

6 Other observations observed was this
7 horizontal cracking along the reactor cavity pit
8 walls. This is typical not just in the area
9 highlighted to the left in green, but throughout the
10 bulk of the structure.

11 One of the items that we wanted to know
12 is, is ASR actually a contributor or is it stagnant?
13 What's happening? Normally, ASR would result in
14 continued crack changes.

15 The reason it's important, there have been
16 no apparent changes to date going back to 2017, '21,
17 or '23. Similarly, there was a one-eighth-inch crack
18 in the keyway opening that we documented in our
19 inspection report. That crack has also remained the
20 same, going back to the same time frame.

21 So we're not seeing changes in those crack
22 profiles, which is good for ASR, but it still needed
23 to be explained on why those cracks were occurring.

24 Next slide.

25 So after the compilation of the field

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 walk-downs and the crack data, the licensee developed
2 finite element models. In particular -- I had
3 mentioned this before -- there was two models
4 developed.

5 One was for heat transfer, and this was
6 determined in thermal loads. If you have differential
7 thermal, that's going to create a load on the
8 structure, and then that's computed as a stress.

9 For the global stress model, that utilized
10 all in-situ and design loads, including ASR and
11 thermal. The attempt here was to input different ASR
12 and thermal loads to see what the effects were on the
13 structure.

14 And not just loads, but the licensee also
15 considered in some localized modeling what are the
16 effects of cycling fatigue, particularly for that
17 slab. As you heat up and cool down, what does that
18 look like for concrete fatigue, the stress
19 concentration in the slab due to the cutout, as well
20 as concrete creep?

21 So they approached this from multiple
22 angles to really understand what could be affecting
23 and causing those distresses. And then when they ran
24 the model, they compared it back to what they saw.

25 One of the things I just wanted to bring

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 up was demands were due -- this was a Stage 2
2 evaluation, so the bulk of the demands came from their
3 original design loads. They were obtained from the
4 original design calculations.

5 Some demands were unavailable, so they had
6 to calculate those with this model consistent with the
7 original design calcs. Those demands were from ASR
8 expansion, and then for the reactor cavity pit area,
9 they were for thermal. Again, that was the purpose of
10 these two models.

11 Specific for this review, and this is for
12 the entire containment internal structure, it wasn't
13 just Region I that performed this review. We had
14 assistance from our technical experts from our Office
15 of NRR. That would be George Thomas.

16 And we also had assistance from Jose
17 Perez, who's a senior technical advisor out of our
18 Office of Research. And then as I pointed out in that
19 picture, we had two observers for knowledge transfer
20 purposes.

21 So once the finite element models were
22 done, then the licensee transitioned into what they
23 discussed as a parametric study.

24 Next slide.

25 And what this parametric study is, this is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 just a single example. They did parametric studies
2 for each of the root causes that they performed.
3 Above is thermal, below is ASR, and then there's
4 various scenarios for each. I'll quickly walk through
5 this.

6 The temperature in the reactor cavity pit,
7 as well as the rest of the containment internal
8 structures, that was determined from a steady-state
9 heat transfer analysis.

10 If you look in scenario 1, that's the
11 design-basis temperature input. That's assuming 120
12 degrees design temperature. This came straight from
13 the original design temperature calc.

14 Scenario 2, look at no thermal load. What
15 is the impact on the structure if no thermal loads are
16 considered?

17 And then scenario 3 is the more accurate
18 representation. This is the operating temperature
19 loads to best estimate what the structure was actually
20 seeing.

21 There are some assumptions made for this
22 scenario. The licensee has an understanding of what
23 they believe to be the temperature in the reactor
24 annulus, the reactor cavity pit, the walls, and the
25 slab.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 This is one of the things that is
2 considered an assumption right now that they're going
3 to have to verify based on installed temperature
4 monitoring equipment that they put in last outage. So
5 during this upcoming fall refueling outage, they will
6 collect the temperature data via data loggers that
7 they installed and verify those assumptions.

8 And then for ASR, again, there was
9 multiple scenarios performed here. In scenario 1,
10 this is ASR considered just in the Containment
11 Building, so the Containment Building foundation mat.

12 Scenario 2 is a combination of the
13 building foundation, the reactor pit area, the pit
14 slab. And then 3, it's a variation of just the
15 foundation and the reactor pit.

16 What's not shown here are the relative
17 amounts of ASR variation. It's looked at anywhere
18 from zero ASR up to high amounts of ASR. And again,
19 the idea here is really just to understand what was
20 the impact on the structure.

21 Next slide.

22 So here's a table that summarizes some of
23 the scenarios, the thermal variations, and then
24 whether or not it actually compared to what was
25 observed during the walk-downs. And this is really

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 considered a cause-and-effect table. Does this
2 explain what was observed? I will note this is
3 specific just to the reactor cavity pit area and slab
4 at that elevation negative-44.

5 In red, this is the comparable
6 representative scenarios for the CIS that were
7 determined to be most applicable. That's scenario 3
8 with thermal variation echo.

9 This assumed 0.2 millimeters per meter ASR
10 expansion in the Containment Building foundation.
11 This provided the best estimate and explanation of the
12 spalling that was observed in the slab, as well as the
13 cracking that was observed in the various other areas
14 of the reactor pit walls.

15 Licensee did run a variation of this where
16 they assumed ASR in the Containment Building
17 foundation as well as the reactor pit area walls, but
18 it didn't correlate as well as ASR in just the
19 Containment Building foundation.

20 They did, as part of the conclusion of
21 this and the root cause, determine that the distress
22 in that pit area was primarily attributed to thermal
23 loading and cycling fatigue, as well as stress
24 concentrations.

25 The conclusion was a possible contribution

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 of combined ASR expansion in the foundation of up to
2 0.2 millimeters per meter in each direction. If you
3 add that up volumetrically, that would be 0.6
4 millimeters per meter. And this was the upper bound
5 estimate for ASR expansion that they utilized in the
6 Stage 2 structural evaluation.

7 Now, you might ask, why not higher levels
8 of ASR? Well, they did consider that in their
9 studies. It was one of the questions we had.

10 It did show, when they used ASR expansions
11 beyond that estimate, it would have produced more
12 severe cracking in those reactor pit walls.
13 Considering the in-situ temperature conditions in the
14 CIS, it was determined to be unlikely.

15 Next slide.

16 In addition to the reactor pit area, there
17 were two other parametric studies performed. These
18 were of other distress areas in the CIS.

19 One of the areas was the fill mat and
20 sump. This was a combination of circumferential and
21 radial surface cracking in the fill mat slab and
22 cracking in the adjacent walls.

23 They also looked at some indications of
24 the distress adjacent to the personnel elevator. This
25 is specific to the enclosure plate, some slight

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 buckling and cracking of the grout for the supporting
2 structure.

3 So like the reactor cavity pit area, they
4 did analyze these areas. They performed and utilized
5 the finite element models. In some cases, they
6 utilized localized ASR expansion to study whether or
7 not it was ASR throughout the structure or just ASR
8 occurring locally, and then they compared it to the
9 distress in the plant.

10 The conclusions were, based on the results
11 of this study, that ASR was likely not the cause. It
12 did not explain the conditions that they were
13 observing.

14 Particularly for the fill mat slab at
15 elevation 26, they determined the likely cause of that
16 was concrete shrinkage. And then for the personnel
17 elevator, they determined that it was due to a
18 combination of effects potentially, which could have
19 been inefficient anchor bolts, grout shrinkage,
20 vibration, or even imbalanced loads during ASR
21 operation.

22 In order for ASR -- similar to the reactor
23 cavity pit walls -- to be the cause, you'd have to
24 have very high amounts, which would present prominent
25 signs of ASR cracking in the fill mat slab. There

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 would have been visual indications typical throughout
2 the plant that were just not observed.

3 Now, the ASR so far determined has been
4 concluded, as best the licensee can estimate, to be in
5 the Containment Building foundation mat and not in the
6 fill mat slab itself, but they have implemented
7 monitoring throughout the containment structure in the
8 fill mat to confirm that conclusion of those areas.
9 I'll cover this on the next slide.

10 Those areas are outside the secondary
11 shield wall, otherwise called the bioshield wall.
12 They are accessed quarterly while the reactor is
13 operating. And so they are getting quarterly data to
14 monitor that the effects of ASR are not occurring in
15 that structure, specifically the fill mat slab.

16 One of the things -- and I briefly touched
17 on this -- is that they previously installed data
18 loggers via thermocouples in the reactor pit area to
19 confirm their assumption for the in-situ temperature
20 conditions of that area.

21 They will collect that data during the
22 upcoming refueling outage and confirm those
23 temperature profiles. And this is also to compare
24 against the root cause analysis to determine their
25 judgment that thermal really was the most significant

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 load demand.

2 Next slide.

3 During the NRC review, we did verify that
4 NextEra completed their structural evaluations using
5 the Stage 2 methodology via the NRC-approved
6 methodology document. They developed the finite
7 element models to estimate those ASR loads and
8 recalculated the structural demands using the original
9 design inputs.

10 We did determine that the CIS meets the
11 evaluation criteria for all factored load combinations
12 with ASR loads. And this does include an ASR
13 threshold of 1.3, so that's 30 percent additional
14 expansion in the Containment Building foundation mat.

15 I will caution, even though we said they
16 meet all factored load combinations, the one area --
17 and this was identified in our violation -- was that
18 they didn't include or evaluate the effects for the
19 reactor pit slabs at that elevation in the revised
20 evaluation.

21 It was excluded from their analysis. It
22 was not taken for any credit in the analysis, but it
23 was excluded from the analysis. And I will go into
24 why, but it's safe to say the remainder of the
25 structure did meet their Stage 2 analysis.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 We did review the root cause studies in
2 detail and found they were of appropriate technical
3 details for the licensee to develop those insights as
4 far as what was causing the distresses. It also
5 provided sufficient detail to provide for that upper
6 bound estimate for ASR.

7 And we did verify that they have plans in
8 place -- and this is what we'll verify in subsequent
9 inspections -- to monitor ASR in that structure to
10 verify whether or not they are experiencing any ASR
11 effects.

12 Next slide, please.

13 So circling back, this is the violation
14 that was identified for that reactor pit slab. It is
15 shown in red in the diagram on the right.

16 What we found is that this slab, it is
17 credited for the attached ductwork. And located
18 directly underneath this slab is the in-core
19 instrumentation that goes to the reactor vessel.

20 The licensee failed to verify the adequacy
21 of this pit slab in their revised structural
22 calculations. Although not taking credit for it, they
23 still need to evaluate the effects and loads impacted
24 on that structure because if it were to fail, it could
25 impact the equipment located underneath of it.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Right now, it is just a one-foot-thick
2 slab providing a landing access for personnel.
3 Nevertheless, any failure would result in impact to
4 safety equipment.

5 NextEra, when this was brought up during
6 the inspection, they did perform a prompt operability
7 determination of that reactor pit slab. This was
8 really just to confirm the integrity of the slab
9 during the unusual load combination of a safe-shutdown
10 earthquake to ensure that if an earthquake were to
11 occur, would the slab stay in place. And the answer
12 was yes.

13 As far as corrective actions going
14 further, they do have an engineering change in
15 progress to reclassify this slab as non-seismic
16 Category I, which will include the necessary analysis
17 to look at the seismic Category II-over-I impacts.
18 Basically, that just means for something that's non-
19 seismic, what failure or what failures could occur to
20 impact safety-related equipment.

21 That change is in progress. There are
22 some additional items as far as measurements and runs
23 that they want to do, including verification of the
24 temperature in the area, that they need to have prior
25 to completing that engineering change. So this is an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 action that will be completed during or post this
2 upcoming refueling outage.

3 And then the last piece here is the slab,
4 right now, if you move it to non-seismic category,
5 you've got to look at the results of any failures.
6 We're talking potential spalling or otherwise impacts
7 of degradation of that structure.

8 Licensee has an analysis out right now
9 where they're analyzing the potential impacts of the
10 failure of this slab on the underlying equipment.
11 Pending the results of that analysis, if it's no good,
12 they will move forward with a preventative
13 modification, which will consist conceptually of
14 plates installed above the in-core instrumentation to
15 protect it from falling debris. They have not chosen
16 either option to date.

17 CHAIR KIRCHNER: Is there a time estimate
18 for when that would be effected, the corrective
19 action?

20 MR. FLOYD: The analysis for the
21 reclassification to non-seismic, that will be
22 performed shortly after the refueling outage.

23 The analysis for the impact to the
24 equipment from falling debris, I do not have a time
25 frame. I would assume it would go in concert with the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 non-seismic Category I analysis because it's part of
2 the steps that they have to do.

3 There are plans to obtain measurements
4 during this refueling outage for the future retrofit.

5 If they were to install that modification, it would
6 not occur during this outage. It would occur in the
7 subsequent outage 18 months from now. Well, when's
8 the outage? October 1st, so 19 months from now.

9 I would not anticipate any repeat spalling
10 right now. There's been no spalling from this
11 structure. Going back to their calculation, when you
12 look at fatigue, there is substantial margin there,
13 but you still need to protect it in the event. So
14 that's why this is important.

15 Are there any questions on the containment
16 internal structure? This is my last slide before I
17 wrap it up and turn it over to Mel.

18 MEMBER BIER: This is really a comment,
19 not a question. I'll keep it brief because I'm not
20 really disagreeing with any of the conclusions, but I
21 just think it makes sense to be careful about using
22 the word cause.

23 The analysis that was done may be
24 consistent with the hypothesis that such and such was
25 the cause, but hasn't really demonstrated that. There

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 may be interactions between multiple phenomena or
2 whatever that haven't been modeled accurately or
3 completely.

4 It's a good working hypothesis. It
5 doesn't mean we know it. That was my only
6 observation. Thanks.

7 MR. FLOYD: Thank you.

8 MR. GRAY: All right. Thank you. I'll
9 close succinctly.

10 Our focus has been the capability of
11 structures, that the licensee maintains those. We've
12 done independent inspections which lead us to our
13 conclusions here that the structures are sufficient to
14 perform their safety functions under the most limiting
15 conditions.

16 We did identify three findings of very low
17 safety significance. And really, the first feeds to
18 the second. They are very low safety significance.

19 I think one of the questions was asked in
20 getting at, is that a lot in context for what's
21 required in this situation? I guess I would say that
22 this particular plan has a unique challenge that takes
23 a lot of resources and ongoing attention, where
24 they've had to graft into the normal operating
25 practices and procedures structural activity.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 And three, in my view, very discrete items
2 doesn't make us change our oversight or think we need
3 to focus more on this licensee than what they're doing
4 right now. That's the best I can say as the
5 regulator.

6 And that's a good place to be, actually.
7 They're in column 1 of the action matrix. For this
8 issue, they've maintained their position in that
9 column. So that's a good place to be.

10 Next slide.

11 Next steps; we're going to continue to use
12 the baseline to focus on ASR-related activities at
13 NextEra and their performance.

14 And really, the first bullet, I'm looking
15 for them to bring their structures into the licensing
16 basis in the next several years and move on. Monitor
17 your ASR for ASR expansion on the one side and
18 building deformation just to have a handle on that,
19 and take corrective actions in a time frame to keep
20 all of your structures within the licensing basis.

21 Going back to what was brought up, their
22 conclusions regarding containment internal structures
23 are only a parametric study. They are open to further
24 validation. And we're attuned to that to see what the
25 data shows, to affirm those further or modify them.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Finally, we're focused on licensee
2 performance to show they meet the license conditions.
3 And that feeds into giving us insights on what they
4 may choose to do with their plant that we need to be
5 aware of so we can form our own inspection plans and
6 oversight, whether they choose to perform large-scale
7 testing in the future.

8 So I would just leave that closed and give
9 it back to the ACRS. I'm here for any questions.

10 CHAIR KIRCHNER: Thank you, Mel, Travis,
11 Niklas, George. I appreciate the information. We are
12 well behind schedule, but I thought it was important
13 to make sure we had the entire story that you all
14 wanted to tell.

15 We will take a ten-minute break or
16 thereabouts. We will reconvene at five minutes after
17 3:00.

18 We'll give the C-10 folks time to get
19 their computers up and presentation up, and we'll give
20 them their full time. After that, we'll take public
21 comments and then have some time to talk as a
22 Committee.

23 So at this point, we'll reconvene at five
24 minutes after 3:00 Eastern Time. Thank you.

25 (Whereupon, the above-entitled matter went

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 off the record at 2:53 p.m. and resumed at 3:04 p.m.)

2 CHAIR KIRCHNER: Okay, we're online.

3 VICE CHAIR HALNON: Okay, we're just about
4 at 3:05. If we can get back into session, I'm going
5 to turn the microphones over to Sarah Abramson and Dr.
6 Saouma from C-10.

7 Sarah, if you're ready to go, you have the
8 floor.

9 MS. ABRAMSON: Thank you. And what I will
10 do is I'll take about eight or nine minutes to present
11 the first four slides, and then I will stop sharing,
12 and Victor will pick up sharing and present the
13 remaining slides.

14 VICE CHAIR HALNON: Okay, good. We intend
15 to give you your full time, so please don't worry
16 about the schedule at this point, but certainly take
17 your 30 minutes.

18 MS. ABRAMSON: Okay, great. Can you hear
19 me okay and see the presentation okay?

20 VICE CHAIR HALNON: Yes.

21 MS. ABRAMSON: Excellent. Firstly, I want
22 to thank the NRC and the ACRS for inviting us to
23 present today. It's a really great opportunity to
24 weigh in as the public stakeholder living near the
25 plant and to let you know what our concerns are.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 C-10 Research and Education Foundation
2 stands for citizens within the 10-mile radius, which
3 is the evacuation pathway emergency planning zone of
4 the Seabrook Nuclear Plant. We are a citizen-led
5 organization that is apolitical and totally agnostic
6 on energy policy.

7 We run three programs that support our
8 communities, and that includes real-time radiological
9 monitoring under contract with the Massachusetts State
10 Department of Public Health.

11 We offer public outreach and education on
12 radiological emergency preparedness, and then our
13 third program is research and advocacy work, which is
14 under this category, in pursuit of public and
15 environmental safety relative to Seabrook Station's
16 ongoing operations, so not dissimilar to the NRC's
17 mission.

18 I'm Sarah Abramson. I'm Executive
19 Director of C-10. I have an academic background in
20 environmental science and policy. I've worked with
21 federal and state regulators in aviation and
22 transportation in previous professional roles.

23 I live about eight miles from the plant
24 with my family, and I'm one of about 180,000 people
25 who live inside that 10-mile radius. This ASR issue

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 is of particular concern to C-10, and we have been
2 very lucky to understand this issue better with help
3 from Dr. Victor Saouma, who is an expert in ASR
4 specifically.

5 We come to this meeting with two
6 overarching questions for the NRC in general and for
7 the ACRS to consider when they look at the ASR issue.
8 Firstly, we're interested in what does the NRC and
9 NextEra plan to do to both expand and preserve their
10 technical understanding of the ASR issue.

11 Understanding that NextEra's initial
12 analyses of ASR were overly simplistic, as determined
13 by the Atomic Safety Licensing Board in its ruling, we
14 are remiss to see continued examples of the licensee
15 oversimplifying their analyses, such as their failure
16 to properly analyze the reactor cavity pit force lab,
17 and such shortcomings lead to an underestimation of
18 the risks, and thus a public health and safety
19 concern.

20 We also see just a small group of very
21 smart, but very few NRC employees who are fluent in
22 the ASR issue. They're basically the three gentlemen
23 you just heard from, but realistically they could lead
24 the NRC tomorrow, and we're left wondering what
25 additional internal and external resources can the NRC

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 incorporate into its oversight of the ASR issue to
2 ensure adequate oversight.

3 Secondly, we have examples from many other
4 inspection reports, both pre-dating and since the last
5 2022 ACRS meeting on ASR, that show a pattern of
6 violations on the part of NextEra relative to ASR
7 license amendments and license conditions.

8 That repetition of noncompliance and a
9 pattern of dragging out corrective actions leaves us
10 concerned that the regulatory instruments being used
11 to enforce these ASR license conditions are not
12 compelling enough to prevent this ongoing
13 mismanagement of ASR.

14 Thus, our question is, what can be done to
15 improve the effectiveness of ASR-related regulation
16 and enforcement? We understand and respect the role
17 of the ACRS as an advisory board, it's the A in the
18 name, and primarily informing the commissioners on
19 what you as scientific experts see as relevant
20 information to regulatory decisions. ASR does not
21 have any specific regulation that is applicable to all
22 commercial nuclear plants.

23 C-10 did petition for rulemaking for ASR
24 in 2014, but it was denied in 2019. Instead, we're
25 left with only the specific license conditions at

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Seabrook Station that are static and relatively
2 unchangeable because they're packaged with their
3 license renewal. This is not dynamic enough to allow
4 the NRC to respond to changes in what becomes known
5 about ASR at the plant, and we believe that more
6 robust regulatory instruments are necessary.

7 Of some history with C-10 and our
8 interactions with the ACRS. We did attend the last
9 meeting. I didn't, but other C-10 members did. And
10 in that meeting, we learned a lot from the NRC
11 inspector's presentation, and we were really
12 appreciative of ACRS's probing questions.

13 You zeroed in on a lot of the same things that
14 we had been concerned about.

15 After reading the transcript, in addition
16 to attending, we formulated a list of pressing
17 questions that we thought were really pertinent to
18 public health and safety, and those questions were
19 submitted by C-10 in June of 2022.

20 And I've had a lot of interaction with a
21 lot of different people at the NRC trying to get
22 answers to those questions with little success, but I
23 have had the benefit of meeting with NRC inspectors
24 almost quarterly, in addition to a lot of sporadic
25 phone calls with them as questions come up.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 So the NRC inspectors have helped fill our
2 knowledge gaps, but it does remain to be seen what the
3 specific responses were from NextEra that the NRC
4 inspectors collected, I believe, to answer those
5 technical questions that were asked by ACRS and C-10
6 last time around in 2022.

7 One example on this slide is the seismic
8 considerations and how ASR may impact the
9 probabilistic risk assessment related to seismic
10 activity. We're left wondering where is the
11 visibility for the public about what questions did the
12 NRC inspector, Mr. Newport, then bring back to
13 NextEra? What was NextEra's response? How was that
14 delivered to ACRS? So we're just hoping for a little
15 more transparency on that.

16 Hopefully it wasn't just an IOU for this
17 next meeting, because two years has passed and there's
18 lots of different faces on the ACRS. Hopefully the
19 information flow is more frequent. We also view our
20 role today to offer robust outside subject matter
21 expertise on ASR.

22 We are confident in the ACRS and that you
23 take your role seriously to review this information
24 and advise NRC leadership on how to better regulate
25 the ASR problem. Quite frankly, to ensure that while

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Seabrook Station is in operation, that someone like me
2 who lives near the plant can feel safe.

3 With that, I will pass it off to Dr.
4 Victor Saouma, who comes to this topic with a lot of
5 extensive experience with ASR and structural
6 engineering. There's a saying that they wrote the
7 book on it, and in this case, he wrote not just one,
8 but two books on ASR.

9 So we feel very grateful that Dr. Saouma
10 continues to provide consultation to C-10 on this
11 issue. So I'm going to pass it off to Victor by, I'll
12 stop my sharing, and then hopefully that will enable
13 Victor to pick up his sharing.

14 VICE CHAIR HALNON: We do see your slides,
15 but you're muted, so if you're speaking, we can't hear
16 you.

17 DR. SAOUMA: Okay, can you hear me?

18 VICE CHAIR HALNON: Yes, we hear you now.

19 DR. SAOUMA: Yeah, my apologies. So my
20 name is Victor Saouma, and I'm a C-10 consultant.
21 It's my pleasure to share with you my thoughts
22 regarding Seabrook. I'd like to walk you through the
23 chronological evolution of ASR's impact on Seabrook's
24 safety.

25 This exploration will cover some landmark

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 decisions and allow me to highlight key concerns
2 raised by C-10. The stakes are incredibly high, and
3 while my suggestion may sometime differ from those of
4 NextEra, it is because in this case, and for the sake
5 of public safety, science must take precedence over
6 convoluted engineering. It all began with the
7 unexpected and accidental discovery of ASR at Tunnel
8 Bravo in 2009.

9 This discovery caught everyone at the NRC
10 off guard, as they had not anticipated such a problem
11 occurring in a containment building, despite the
12 existence of hundreds of ASR cases in concrete dams,
13 much more so than in bridges, I may add.

14 Fast forward to 2016, when NextEra filed
15 a license amendment request, along with a request to
16 modify the timetable for the 10-year mandated air
17 leakage test. My critical review of this request has
18 been published, but today I want to focus on some of
19 the underlying assumptions and justifications put
20 forth by NextEra, which are at best questionable.

21 Therefore, I will address two critical
22 aspects; the operational basis earthquake OBE and the
23 safe shutdown earthquake SSE. These are not merely
24 technical details, they are foundational to the safety
25 of the entire facility. NextEra's assertion that this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 parameter did not require modification, despite the
2 presence of ASR, is not only wrong, but potentially
3 dangerous. Such claims demand scrutiny and must be
4 supported by irrefutable evidence.

5 As a structural engineer, I look at safety
6 in terms of demand and capacity. For a structure to
7 be deemed safe, its capacity must unquestionably
8 exceed the demand. The numerical modeling,
9 specifically the finite element analysis employed by
10 NextEra, is grossly inadequate and sophomoric.

11 This analysis is supposed to be the
12 cornerstone of structural safety evaluation, yet what
13 has been used lacks credibility to anyone with even a
14 basic understanding of modern finite element analysis.

15 Keep in mind that we are not bound to 1930
16 technology for this. I will add emphatically that the
17 absence of review by an independent panel of external
18 experts further erodes confidence in this finding.

19 NextEra's second filing also contains an
20 argument that the potential for leakage should not be
21 of concern. This position is quite frankly baffling.
22 Micro cracks are known consequences of ASR, and these
23 cracks compromise the integrity of the structure,
24 allowing for leakage that could have serious
25 implications.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 The idea that reinforcement alone, given
2 that it is three-dimensional only around the base,
3 could mitigate this risk is dangerously optimistic.
4 It is essential to understand that ASR is not just a
5 surface-level issue. It is primarily internal where
6 the moisture is highest.

7 For ASR to progress, we have to have
8 moisture, and moisture is highest inside the walls.
9 By the time we observe surface cracks, we are simply
10 looking at the tip of the iceberg. And let me repeat
11 it. By the time we see surface cracks, we are simply
12 looking at the tip of the iceberg. My stance on
13 NextEra's understanding of ASR has been clear and was
14 largely validated by the Atomic Safety Licensing Board
15 2019 ruling.

16 It's worth noting that 50 percent of the
17 license conditions imposed by the ASLB were the direct
18 result of C-10 intervention. So when I presented the
19 case on behalf of C-10, it was evident that NextEra's
20 grasp of ASR implications was at best superficial.
21 The board concern mirrored my own, highlighting
22 significant gap in NextEra's approach.

23 This ruling is a critical acknowledgement of the
24 complexities involved and the need for a more rigorous
25 approach to ASR management.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Chronologically speaking, the NRC
2 understanding and appreciation of ASR complexity have
3 significantly improved since 2016. Indeed, the NRC
4 has funded three major projects at Northwestern, my
5 university, University of Colorado in Boulder, and at
6 NIST. Yet, indications are that the NRC has ignored
7 some of the major findings that two of them
8 determined.

9 That is the negative impact of ASR on the
10 shear strength of concrete, which is opposite to what
11 was determined in the Texas test. I will develop this
12 in a future report. This progression is crucial, yet
13 it coincides with the troubling spread of ASR beyond
14 the tunnel when it all started. Now to the
15 containment enclosure building itself.

16 A development I personally observed during
17 my visit. It was clear by then when I visited
18 Seabrook, we had crack all around the base of the CEB.
19 By now, as here, we hear that the projected expansion
20 is likely to exceed the limit set for the license.
21 And yet, we continue to hear that the expansion is
22 slow, a term that does not mean anything unless it is
23 substantiated and based on physical tests.

24 So, C-10 strongly advocates also for the
25 reassessment of the OBE and SSE parameters. This

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 critical factor that determines the facility's ability
2 to withstand seismic events.

3 In my professional opinion, the
4 mathematical modeling of ASR, whether in static or
5 dynamic analysis, is fundamentally flawed. Obsolete
6 models are being used for dynamic analysis. And the
7 modeling of ASR is not just flawed, but dangerously
8 so.

9 Furthermore, the computer programs used
10 have not been, to the rest of my knowledge, validated
11 independently or in compliance with Regulatory Guide
12 1.168, which is Verification, Validation, Review, and
13 Audits for Digital Computer Software used in safety
14 systems of nuclear power plants.

15 It is also worth noting that to the best
16 of my understanding, these critical components for the
17 safety assessment have not been subjected to
18 independent peer review by external experts. The
19 assumption that there is no reduction in shear
20 strength due to ASR is not just a misconception, it is
21 a potentially catastrophic error.

22 Multiple researchers, including two funded
23 by the NRC, have debunked this myth, providing ample
24 evidence that ASR does indeed reduce shear strength.

25 Let's not forget that shear strength is what we need

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 to provide the resistance to seismic load, lateral
2 seismic load. Not only was the wrong large-scale test
3 conducted in Texas, but the specimen had cracked and
4 was damaged even before the shear tests were
5 conducted.

6 Ignoring this evidence puts the entire
7 structure at risk. So we must insist on a
8 comprehensive re-evaluation of all the safety
9 parameters considering this reality. The safety of
10 Seabrook facilities depends on it.

11 Revisiting the capacity and demand
12 paradigm, this figure, before you synthesize the case
13 for thorough revision of the parameter, we can follow
14 the sequence of events. First, there is a
15 deterioration of the concrete with time. This has
16 been observed in Seabrook. This would result in a
17 decrease in the concrete capacity.

18 Moving to the next curve, now going to the
19 vulnerability curve, which is this one, and given that
20 the capacity and demand must be at least equal, we
21 will have a decrease in the earthquake magnitude that
22 can be sustained.

23 So if you have a decrease in the magnitude
24 of the earthquake which can be sustained, for
25 illustrative purposes, let's say from 0.7 to 0.55 G,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 then going to the hazard curve, it means that such a
2 decrease in earthquake magnitude will result in an
3 increase in the return period. So all of the above
4 says unequivocally that Seabrook is more vulnerable to
5 earthquake than we are led to believe.

6 I will turn now my attention to the air
7 leakage test issue. I have previously mentioned the
8 prevalence of internal and undetected crack as
9 mentioned by the FHWA.

10 I have also mentioned that above the base,
11 about five feet, we no longer have shear
12 reinforcement. Those are present only close to the
13 surface. So once again, with shear reinforcement only
14 close to the base, three-dimensional reinforcement,
15 but as we move above at a certain elevation, we only
16 have skin reinforcement.

17 Furthermore, the Atomic Safety Licensing
18 Board has implicitly criticized NextEra for its poor
19 and questionable understanding of ASR's internal
20 microcracking. Hence, considering this consideration,
21 C-10 recommends shortening the air tightness test
22 schedule from the current 15-year interval to a
23 performance-based schedule.

24 This recommendation is not made lightly.
25 It is based on the recognition that ASR is an evolving

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 threat that cannot be adequately monitored under the
2 existing schedule. Now the key question here is how
3 performance is defined and who gets to define it.
4 This must be a transparent process involving
5 independent experts.

6 The definition of performance must
7 prioritize safety above all else. I now turn to a
8 related but equally important concern. C-10 advocates
9 here for public rights to know. The safety of the
10 public is not just a matter of engineering. It's a
11 matter of democratic transparency.

12 In an open society, there should be no
13 confidential or proprietary data when it comes to
14 public safety. All relevant information about ASR and
15 its implications should be made public. This is not
16 just a moral imperative. It's a practical necessity.

17 Hence, we assert that through measurement
18 data should be treated as public domain. Yet, we
19 recognize that NextEra modeling should remain
20 proprietary. The comparison may not be perfect, but
21 it is similar to a public utility sharing water
22 quality measurement results with the public.

23 I was specifically referring to crack
24 indices recorded by NextEra which have not been
25 adequately disclosed to the public. These indices are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 critical for understanding the extent of ASR damage.
2 Yet, they remain shrouded in secrecy. This lack of
3 transparency is unacceptable.

4 C-10 is specifically asking that the NRC
5 makes public the date, tier level, crack index value,
6 location, and the reference value of the core
7 compressive strength closer to the location cast to
8 reconstruction. This last indicator is particularly
9 crucial because it is essential to determine the
10 out-of-plane ASR expansion using the method advocated
11 by NextEra once the crack index reaches critical
12 values.

13 Without this data, any assessment of ASR's
14 impact is incomplete and potentially misleading. The
15 public has the right to access this information, and
16 the NRC has the duty to provide it. But having access
17 to data is only the first step.

18 We must also be able to visualize this
19 data in a meaningful way that allows us to quantify
20 its impact on the overall health of the structure.
21 Raw data is not enough. It must be analyzed and
22 presented in a way that reveals the true extent of the
23 risk.

24 This is not just about number, it's about
25 understanding what those numbers mean for the safety

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 of the people within 10 miles radius of Seabrook. C-
2 10 is already fully prepared to collaborate with the
3 NRC in this endeavor. We found that NextEra tool,
4 unless it has changed since then, the one on the upper
5 left, is inadequate, misleading, and confusing, and in
6 the end practically useless.

7 So it's not enough to criticize, we must
8 be proactive. And proactive we have been at C-10 by
9 developing advanced software that can display the
10 spatial and temporal variation of ASR or any other
11 measurement in a containment building, such as shown
12 in here.

13 In this figure, it's easy to visualize the
14 extent of ASR evolution in structure, and the temporal
15 variation and this are shown in the lower two slides.
16 Of course this is for illustrative purposes. The one
17 on the left is at 21. The one at times on the right
18 is at time 22.

19 Finally, one can hover the mouse over any
20 point and get the relevant data, or clip out all the
21 region with an ASR expected to be below a certain
22 threshold, or simply slice the structure to look into
23 the internal expansion. But as I said, this is hard
24 to visualize, we have to be able to have some sort of
25 an analysis approach, that is to take to determine the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 health of the whole structure.

2 So at any given time, based on this data,
3 we can take a snapshot and plot histogram of ASR
4 expansion. These are the number of locations of the
5 surface, which has an expansion below a certain value,
6 and again each one of those bars corresponds to a
7 certain range. So the total area under this histogram
8 serves as a global measurement of the structural
9 health, S times T. This is step 3 and index is 11.3.

10 Finally, we can plot the time evolution of
11 this index, providing decision makers, such as the
12 NRC, with the data they need to make informed choices.
13 This approach also reassures the public about the
14 structural integrity of the facility that provides the
15 electricity.

16 So these last two slides are the
17 references substantiating my assertion, along with
18 hyperlink to key documents. C-10 will always welcome
19 questions and provide further scientific evidence of
20 our assertion.

21 I would like to conclude by saying that
22 this is a particularly complex, very complex problem,
23 unprecedented and not covered by any existing codes.
24 When I heard mention about ACI code and ASCE, none of
25 this code addresses ASR. Once again, none of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 existing code covers ASR. We have tweaked this code
2 to, forgive me for the term, pretend that we can model
3 ASR through a simplistic approach.

4 Therefore, we must first rely on sound,
5 science-based principles. I repeat, science-based
6 principles, and then and only then develop engineering
7 solutions that are directly informed by the scientific
8 foundation.

9 Thank you for attention, and of course,
10 I'd be happy to answer any question.

11 VICE CHAIR HALNON: Thank you, Dr. Saouma.
12 I appreciate that. And I'll look to the members and
13 our consultants if there's any questions for either
14 Sarah or Dr. Saouma.

15 MEMBER MARTIN: Dr. Saouma, this is Bob
16 Martin. And I'm new to this topic, I must admit. But
17 I have to believe that there is some, not necessarily
18 nuclear industry experience, but in structures like
19 bridges and overpasses where this has come up.

20 And that maybe, in fact, they would lead
21 as far as understanding not only the phenomena, but
22 how to address it in a public safety sense. Can you
23 provide a little insight on what others do on this
24 subject?

25 DR. SAOUMA: Yes. ASR was first

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 discovered in the 1940s in the context of dams,
2 concrete dams. We have had hundreds of dams worldwide
3 which have been suffering from ASR. And their safety
4 has been addressed by different means. And by the
5 way, some of them have been decommissioned because it
6 was too dangerous.

7 I recently was involved in a major project
8 with the Bureau of Reclamation to assess the safety of
9 seminal dam which suffered ASR in Wyoming. So, again,
10 there is what I would call the traditional approach
11 and the more modern approach which has been espoused
12 by few, mostly in Canada and in Europe, but very few
13 in the U.S.

14 So, for instance, we have to perform
15 accelerated expansion test which NextEra has
16 absolutely refused to undertake. Accelerated
17 expansion test is when we take a core, we put it in a
18 certain condition, heat it, and monitor the expansion
19 and try to determine how much is going to be the
20 future expansion. And that's an approach that, to the
21 best of my understanding, NextEra refused to do.

22 We can have also to perform certain
23 specific microscopic tests, and that doesn't mean a
24 regular petrographic test that is commonly done, but
25 for instance what is done in Japan to determine what

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 was the past expansion. So, in the area of concrete
2 bridges and dams, the modern approach is to use a
3 numerical modeling where, first of all, the computer
4 program has to be validated.

5 It has to be validated and to prove that
6 it can capture some of the unique features of ASR;
7 that is, three-dimensional expansion, expansion under
8 constraint condition, expansion which depends on
9 temperature, and on moisture. I would say that in
10 Canada, for instance, Hydro-Quebec has done a
11 marvelous study for Gentilly-2 on addressing a
12 modeling ASR.

13 So, I don't know if I was able to properly
14 answer your question here, but the idea of modeling
15 ASR as a temperature load and as a volumetric strain
16 is completely wrong, and erroneous and debunked.

17 MEMBER MARTIN: It's a pretty general
18 statement, not to say it's wrong or right. So, if I'm
19 interpreting what you said correctly, you're saying
20 that generally the maturity of modeling that would be
21 otherwise used to evaluate structures is just immature
22 across the board? Are you saying that there are
23 proven methods that, you know, --

24 DR. SAOUMA: It is mature.

25 MEMBER MARTIN: -- are preferable that are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 there today that have been validated?

2 DR. SAOUMA: Sorry to interrupt you. It
3 is mature. It has been validated, and some people who
4 have been using it. I give the example of -- for the
5 reactor, I give the example of Gentilly-2 in Canada.
6 I give Hydro-Quebec, which is also for other dams,
7 have been using this modern method.

8 I can give multiple examples in Europe
9 where the approaches are essentially variation on the
10 team. You have to have a finite element model which
11 can capture the unique feature of ASR, and this has to
12 be validated. No doubt about that.

13 MEMBER MARTIN: Appreciate that. Thanks.

14 VICE CHAIR HALNON: Others?

15 I just had one clarification. This is Greg. I
16 got confused on the air test issue. It was my
17 understanding from my previous experience that the air
18 test was for a vacancy in the containment vessel. Can
19 you explain?

20 Maybe I'm just got a different model in my
21 head about what this containment looks like. Is the
22 pressure vessel metal, and then the concrete that
23 you're concerned about, is a shield building around
24 that metal, or is it the actual pressure vessel?

25 DR. SAOUMA: We know that there's a liner.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 We don't know whether at some point the anchorage has
2 been affected by ASR, and we might lose tightness. We
3 know that ASR is going to cause micro-cracks.

4 We know that the ASR is going to manifest
5 primarily inside the wall because this is where the
6 moisture is highest. In many cases, we do not see yet
7 manifestation on the surface, yet we have internal
8 micro-cracks. Those micro-cracks can coalesce and
9 eventually cause potential macro-cracks, which would
10 cause leakage.

11 VICE CHAIR HALNON: Through the vessel
12 itself through the metal liner?

13 DR. SAOUMA: Of course.

14 The metal liner, if we assume that it's
15 100 percent perfect, no, there won't be leakage. But
16 do we know what is the impact of ASR on the anchorage
17 of the liner, where we have hundreds of those? I
18 don't know.

19 VICE CHAIR HALNON: I understand now.
20 You're talking about the anchorage from the vessel to
21 the concrete itself.

22 DR. SAOUMA: For instance, related to that
23 question about micro-cracks, when I see the slide
24 number 19 by NRC, where they placed a plate to
25 mitigate the effect of ASR, well, I don't know if it's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 time for me to make a comment on that, but let's not
2 forget that what they are doing is mitigating on the
3 surface, and then simply throwing up the expansion to
4 be through the wall, because ASR is a volumetric
5 expansion.

6 You constrain it in one plane, it's going
7 to go back and expand in the out-of-plane. Expand out
8 of the out-of-plane. You already have micro-cracks.
9 What happens? You have internal delamination. And
10 internal delamination is a brittle failure, and you'll
11 get exactly what happened at Crystal River, all of a
12 sudden.

13 VICE CHAIR HALNON: I understand about
14 that.

15 Another question. Dave Lockbaum, are you
16 representing C-10? Are you part of that organization?
17 Is that why you raised your hand?

18 MR. LOCHBAUM: I'm an advisor for C-10,
19 but my question was as a member of the public.

20 VICE CHAIR HALNON: Okay, we haven't
21 opened up for public comment yet, so hang in there.

22 MR. LOCHBAUM: Okay, I will.
23 Thank you.

24 VICE CHAIR HALNON: Any other questions
25 from members or consultants?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Okay, then at this point, I will open it
2 up for public comments. I think Mr. Lockbaum probably
3 has the first hand up, and others, if you raise your
4 hand and or get my attention somehow by unmuting, I
5 will acknowledge it. Please state your name and
6 affiliation as appropriate. Dave, go ahead.

7 MR. LOCHBAUM: Yeah, this is Dave
8 Lockbaum. I appreciate that. On the issue of the ASR
9 effect on containment integrity and the need for air
10 tests, the slide that the NRC showed of ASR expansion
11 causing a metal grid to buckle, leads me to question
12 whether containment penetrations would be equally
13 vulnerable to ASR expansion causing the penetrate,
14 because it's not a leak right there.

15 So my concern would be about containment
16 penetrations failing due to ASR expansion in that
17 direction, and the less frequent air tests not picking
18 up on those containment penetration failures. That's
19 all. Thank you.

20 VICE CHAIR HALNON: Yeah, I understand.
21 Thanks, Dave.

22 Any other members of the public would like
23 to make a comment? Okay, not hearing any, we will
24 close the public comment session, and now we're into
25 our committee discussion. Any members or consultants

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 have a comment or a question or anything you'd like to
2 say during the deliberations?

3 DR. SAOUMA: Well, if I may ask a
4 question?

5 VICE CHAIR HALNON: Yes.

6 DR. SAOUMA: Victor Saouma.

7 VICE CHAIR HALNON: Yeah, go ahead,
8 please.

9 DR. SAOUMA: Yes, again, my question goes
10 back to the slide I've seen, number 19, I believe, or
11 20 -- 21, sorry. And I'm very concerned by what I
12 saw, because what was presented was an external plate
13 reinforcement aimed at mitigating ASR expansion.

14 In my opinion, and so to use a term, it's
15 nothing else than a band-aid approach, conceptually
16 dangerous, because if you manage to limit the in-plane
17 expansion, ASR being a volumetric phenomenon, it's
18 going to be redirected out of plane and through the
19 thickness, and this can eventually lead to internal
20 and sudden brittle delamination crack. So, I would
21 urge the NRC to look very carefully at this remedy.

22 VICE CHAIR HALNON: I see that they're
23 acknowledging you and they're writing it down, so,
24 yes, thank you.

25 Sarah, I see you raised your hand. I want

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 to give you time, go ahead.

2 MS. ABRAMSON: Thank you. I had a
3 question that came up during the NRC's presentation.
4 It was around slide nine, and a member of the ACRS
5 asked Nik Floyd, or made a comment that the structural
6 modifications are the solution to those five
7 structures that are going to be outside the
8 unacceptable zone, and I was just hoping that maybe
9 Nik could clarify on that.

10 Are there structures that, even with
11 physical modification, are on track to be outside the
12 acceptable zone in that 10-year-ish time frame?

13 VICE CHAIR HALNON: Nik, did you want to
14 clarify?

15 MR. FLOYD: This is Nik Floyd. I don't
16 have the structures as far as the expansion data in
17 front of me. I can't tell you the specific ones. I
18 know at least one of the areas, to the best of my
19 mind, was in the controller diesel generator building.
20 That is one of the structures on track to be modified
21 currently.

22 As far as the other structures that are in
23 POD space, I don't have that data. I'd have to get
24 back to you on that, Sarah.

25 MS. ABRAMSON: Thanks, Nik. And I guess

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 the core of my question is, just to clarify my own
2 understanding, when you talked about that 10-year time
3 frame, and next you're considering doing another
4 large-scale testing program, what would be the trigger
5 for that? Is that when structures that are already
6 modified are outside the zone?

7 VICE CHAIR HALNON: Talking about the
8 licensee's retesting program? Is that what you're
9 talking about?

10 MS. ABRAMSON: Yes.

11 MR. GRAY: Sarah, Mel Gray. I think your
12 first question was regarding retrofits. They are
13 intended to bring these structures into conformance
14 with the licensing basis in those 10 years. So,
15 that's their intended purpose. Is that responsive?
16 What was the second part of that?

17 MS. ABRAMSON: Yeah, I might have to get
18 some additional clarification offline from --

19 MR. GRAY: Any additional large-scale
20 testing by the licensee would be in their estimate.
21 Their current licensing basis only allows for -- it
22 shows that the large-scale testing they did is only
23 valid to a certain level of volumetric expansion.

24 They would need to elect to do more
25 testing if they felt that that expansion was occurring

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 that would require action on their part for further
2 operation of the plant. That's their decision to
3 make.

4 MS. ABRAMSON: Thank you. I think that
5 was the clarity I was looking for because I thought I
6 heard someone jump in and assert that the structural
7 modifications were sort of the cure to that expansion
8 being beyond what the original testing program showed.
9 So, I think I understand better now. Thank you.

10 VICE CHAIR HALNON: Thank you, Sarah.

11 Dr. Saouma:?

12 DR. SAOUMA: Yes, I'm curious about the
13 course extracted from the Seabrook.

14 PARTICIPANT: I mistakenly muted Victor.
15 I'm sorry about that. I meant to lower his hand.

16 So, Victor, can you unmute yourself and
17 restart?

18 DR. SAOUMA: Sorry, I forgot. Can you
19 hear me now?

20 VICE CHAIR HALNON: Yes.

21 DR. SAOUMA: Yes, I'm curious about those
22 locations where NextEra has installed the
23 through-thickness extensometer. So, presumably, of
24 course, core had to be removed. And according to the
25 protocol that it has advocated, their first step was

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

(202) 234-4433

www.nealgross.com

1 to determine the past expansion by determining the
2 Young's modulus of that core and compare it with the
3 Young's modulus of concrete cast in the 70s.

4 How many of those correlations have you
5 made? How many attempts to determine the past
6 expansion have been made so far?

7 MR. FLOYD: Nik Floyd. Victor, I don't
8 have an exact number for you. There has been a
9 numerous amount of cores extracted from Seabrook. For
10 each extensometer that has been removed for the
11 program, they had to perform testing on that core to
12 establish the through-thickness expansion to date and
13 any cores going into the future.

14 Specifically, for those seven tier three
15 areas I mentioned earlier where they need to install
16 extensometers, they removed cores for those as well.
17 So, there will be additional cores removed.

18 DR. SAOUMA: I'm sorry, you're not
19 answering my question. Once you remove the core, you
20 are supposed to measure the Young's modulus of that
21 core and compare it with the Young's modulus of the
22 concrete when it was cast. The difference in the
23 elastic modulus would give you the ASR expansion
24 according to the curve which was determined by the
25 University of Texas.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 Have you performed any of those
2 determinations? This is in the license agreement, the
3 new one, that you extract the core, you measure the
4 compressive, you measure the elastic modulus, you
5 compare it with the elastic modulus of the concrete
6 when it was cast.

7 The decrease in elastic modulus is on the
8 x-axis. On the y-axis, you get the past ASR
9 expansion. Again, that's in the license amendment
10 request. Have you done any of that?

11 VICE CHAIR HALNON: Ron, would you take
12 this and go back and look at your data and provide
13 some information that may be able to be publicly
14 released at that point.

15 Thank you, Dr. Saouma. They're going to
16 work on that to make sure you get the data. I just
17 didn't want to get an incomplete answer on the record.

18 DR. SAOUMA: Thank you.

19 VICE CHAIR HALNON: So, okay, I'm going to
20 close. No more questions. We're in committee
21 deliberation, but I wanted to since additional
22 information was put out, make sure that there was
23 still no public comment.

24 So, I'm just going to quickly open up for
25 other public comments. Okay, given none, in fact, the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1716 14th STREET, N.W., SUITE 200
WASHINGTON, D.C. 20009-4309

1 committee is now in deliberation, so everyone will
2 stay muted other than the committee members and
3 consultants. Is there any other comments?

4 Yes, Scott.

5 MEMBER PALMTAG: Do you want the court
6 reporter to continue?

7 VICE CHAIR HALNON: No, I guess that's it.
8 Thank you.

9 Eric, you're released for the rest of the
10 day. I think for the rest of the meeting, isn't it?
11 Well, did you want to make that statement?

12 CHAIR KIRCHNER: Yes, thank you, Eric. I
13 will not need your services tomorrow for our planning
14 and procedures meeting so I think we're done with your
15 recording for this meeting. Thank you very much.

16 (Whereupon, the above-entitled matter went
17 off the record at 3:48 p.m.)

18

19

20

21

22

23

24

25

C E R T I F I C A T E

This is to certify that the foregoing transcript

In the matter of: 718th ACRS Meeting

Before: NRC

Date: 09-04-24

Place: Rockville, Maryland

was duly recorded and accurately transcribed under my direction; further, that said transcript is a true and accurate complete record of the proceedings.



Court Reporter

NEAL R. GROSS


COURT REPORTERS AND TRANSCRIBERS

1716 14TH ST., N.W., STE. 200

WASHINGTON, D.C. 20009-7831

C-10 RESEARCH & EDUCATION FOUNDATION

Protecting people and the environment across the communities surrounding Seabrook Station



Presentation to:

US Nuclear Regulatory Commission (NRC)
Advisory Committee on Reactor Safeguards (ACRS)

Presented by:

- Sarah Abramson: [C-10](#) Executive Director
- Victor E. Saouma: Professor Emeritus, Department of Civil Engineering, University of Colorado-Boulder

Representing the 180,000 [C](#)itizens within the [10](#)-mile Radius of the Seabrook Nuclear Power Plant.

We Have Two Overarching Public Safety Questions



Learn from the past, prepare for the future, live in the present.

- Thomas S. Monson

1. What does NRC & NextEra plan to do to improve their understanding of the ASR issue?
2. Will NRC continue to find acceptable NextEra's late and incomplete analyses of ASR-impacted areas, especially those in the containment structure?

C-10 Views ACRS Role as Critical in Addressing NextEra's Mismanagement of ASR



- **April 27, 2022:** Last ACRS meeting on ASR
- **June 29, 2022:** C-10 reviews meeting transcript by ACRS members (e.g. seismic PRA), C-10 submits own list of questions to ACRS
- **As of Today, Sept. 4, 2024:** No public record of NRC responses to ACRS or C-10 questions from 2022 meeting
- **C-10 Goals Today:** Offer robust subject-matter expertise to inform on the ASR issue; confident in ACRS to review & advise NRC Commissioners and staff on how to better regulate the ASR problem at Seabrook Station

13	MEMBER BLEY: Just for reference, the
14	design earthquake is never a big contributor to risk,
15	because we design that out. It's the earthquakes that
16	go beyond the design earthquakes that lead to
17	significant damage. And it's kind of disappointing,
18	do we know for sure that Seabrook has not included
19	that in their Seismic PRA?
20	MR. NEWPORT: Let me -- we can verify
21	that, and we can get that back to you for sure.
22	MEMBER BLEY: Okay, it's kind of
23	disappointing that they haven't looked at that,

Excerpt from 2022, April 27 meeting transcript [ML22136A319](#). NRC Advisory Committee on Reactor Safeguards Fuels, Materials, and Structures and Plant Operations, Radiation Protection, and Fire Protection Joint Subcommittees.

Victor E. Saouma, Professor Emeritus, Dept of Civil Engineering, University of Colorado/Boulder

- Conducted theoretical, experimental, numerical, engineering research on ASR (11 major funded projects, two books, 9 major reports, 9 short courses, 15 peer-reviewed publications).
- Past President and Fellow of the International Association of Fracture Mechanics for Concrete and Concrete Structures.
- Past Chair of an International Committee focusing on the diagnosis and prognosis of structures affected by ASR
- Research on ASR funded by the ORNL, NRC, Bureau of Reclamation, Tokyo Electric Power Company.
- Past member of the Materials Aging and Degradation (MAaD) External Review Committee (ORNL, Light Water Reactor Sustainability R&D Program) and of the Expanded Proactive Materials Degradation Analysis Expert Panel (PMDA) for concrete in nuclear reactors; Nuclear Regulatory Commission.
- Published extensively:
<https://ceae.colorado.edu/~saouma/index.php/alkali-aggregate-reactions/>



1

Chronology

2

Q1: Revisit Operating Basis Earthquake (OBE) & Safe Shutdown Earthquake (SSE); Correct Analysis Model

3

Q2: Air Leakage Test; Revisit Testing Frequency

4

Q3: Crack Indices (CI), Public Right to Know

Chronology

- 2009** ASR discovered in Tunnel (Bravo-1) at Seabrook.
- 2010** Seabrook placed under [special NRC oversight](#).
- 2012** [Nuclear Energy Institute](#) suggests an (up to) 15 years intervals (in lieu of 10) for type A performance leakage rate tests of CBE.
- 2016** NextEra files a [License Amendment Request](#) (LAR)16-03. Regarding seismic analysis, we note the following:

Earthquake levels: No change of OBE & SSE

[W]hen ASR loads are amplified by a threshold factor of 1.2 to account for future ASR expansion[, t]he as deformed condition does not **significantly** impact the dynamic properties of the structure, and therefore the **maximum seismic acceleration profiles for OBE and SSE excitation used in original design of the CEB remain valid.**

[Seabrook, License Amendment Request 16-03 - Revise Current Licensing Basis to Adopt a Methodology for the Analysis of Seismic Category I Structures with Concrete Affected by Alkali-Silica Reaction.](#)

NextEra-ML16216A240 ([2016](#))

Chronology

Oversimplified Analysis

Seismic loads are applied using a **static equivalent method** utilizing the design-basis maximum acceleration profiles, which were computed during original design from response spectra analysis. **Amplify ASR loads by a threshold** factor to account for potential future ASR expansion.

...

Response spectra analysis was performed using a **simplified** “stick” model.

[Evaluation and Design Confirmation of As-Deformed CEB. 150252CA-02.” Revision 0. July 2016](#)
[\(Seabrook FP#100985\)](#)

Simpson Gumpertz & Heger-ML16279A049 ([2016](#))

Comments Below

2016 NextEra files a [Request to Extend to 15 years](#) leakage test of CBE.
It alleges that

Chronology

NextEra's justification



- Containment's three directional steel reinforcement arrangements, which inhibits ASR expansion,
- The very limited localized areas of ASR detected on the containment surface, and
- Previous UT inspections of the containment liner local to areas of ASR in which no anomalies or corrosion were identified

Supplement to License Amendment Request 16-01 Request to Extend Containment Leakage Test Frequency

NextEra Energy ([2016](#))

C-10 Comments

- ASR causes cracks and microcracks, which **not always visible**. These may coalesce and **create a continuous pathway** for gas release.
- There is three-directional reinforcement **only around the base**, while “skin” **reinforcement is applied only on the intrados and extrados**.



[Report on the Diagnostis. Prognosis. and Mitigation of Alkali-Silica Reaction \(ASR\) in Transportation Structures](#) FHWA ([2010](#))

Chronology

- 2019 Professor Saouma [visits Seabrook](#).
- 2019 [Consolidated documents](#) filed by Dr. Victor Saouma
- 2019 Proposed Findings of Fact and Conclusions of Law: [C-10](#), [NRC](#), and [NextEra](#).

2020 Atomic Safety Licensing Board (ASLB) Ruling (includes):

... NextEra has not persuaded us that it is properly accounting for the possibility of delamination.

The Board finds that NextEra **does not have an adequate screening procedure to detect internal cracking** and delamination in Seabrook's concrete."(pg 184)

...[t]he Board is **concerned about the potential for sudden significant, localized damage due to shear failure**, given that all parties agreed that there may be localized excursions of Seabrook Unit 1 into the nonlinear structure plastification regime."(pg 184)

Thus, the Board finds that **NextEra has not shown, by a preponderance of the evidence, that there is reasonable assurance that the continued operation of Seabrook Unit 1 will not endanger the health and safety of the public with regard to this particular issue of delamination.**" (pg 185)

[In the Matter of NEXTERA ENERGY SEABROOK, LLC \(Seabrook Station, Unit 1\): Initial Decision](#)

Atomic Safety License Board ([2020](#))

Observations

- In 2010, knowledge about ASR was insufficient, but significant advancements were made by 2020.
- Some premises that initially supported the license renewal were later shown to be incorrect.
- The ASLB comments partially validated this assertion.
- Given the stakes, it is urgent to reconsider two key issues.
 - OBE & OSE
 - Air leakage test

Explanation follows

**Q I:Revisit Operating Basis
Earthquake (OBE) & Safe
Shutdown Earthquake (SSE);
Correct Analysis Model**

- We have reviewed the dynamic analysis procedure performed by SGH and found it dangerously simplistic.
- The term *significantly* is too vague given the potential impact on the safety of the CEB.
- The reliance on the stick model, a method from the 1970s, is not only outdated but also inadequate; In the 21st century the NRC must demand the adoption of a more accurate model.
- The ASR modeling blatantly disregards well-established principles, directly conflicting with what is universally accepted in the field of modeling.
- Program to simulate ASR not validated.
- **The Capacity is grossly miscalculated.**

The Myth of No Shear Strength Loss from AAR


Results from the Shear Test Program indicate that there is no reduction of shear capacity in ASR-affected concrete with through-thickness expansion levels up to █% or volumetric expansion levels █%, which are the maximum expansion levels exhibited by the test specimens.

[Seabrook Station - Approach for Determining Through-Thickness Expansion from Alkali-Silica Reaction](#)

NextEra-ML18141A785 ([2016](#))

- The persistent myth that there is no shear reduction due to AAR in the CEB has been **conclusively disproven** by findings from two separate NRC-funded research programs.
- AAR will lead to significant shear reduction, critically **undermining resistance to earthquake excitation**.
- The **Demand** is grossly underestimated

Why the SSE should be updated



Q2: Air Leakage Test; Revisit Testing Frequency

Air Leakage Test

- The ASLB firmly asserts that NextEra has no reliable control over where and when cracking will occur.
- This directly undermines NextEra's claim that 15 years cycles for leakage testing are sufficient.
- By 2020, ASR has not only been identified as a critical threat to Seabrook, with hidden cracks often going undetected, but NextEra has also demonstrated a consistently poor record in managing ASR.
- As the years pass areas known to have ASR, and countless unknown areas are experiencing ASR degradation.
- Consequently, we **strongly recommend that the full air tightness test schedule be drastically shortened from the current 15 years to a performance-based schedule.**

Q3:Crack Indices (CI), Public Right to Know

Public Right to Know Some Data

- The public has a **fundamental right to access information that affects their safety and well-being.**
- Transparency in sharing data helps **build trust between the reactor operator, regulatory agencies, and the public.** When data is openly available, it demonstrates that the operator is committed to safety and is accountable for maintaining the highest standards.
- Public access to safety data enables **independent experts**, researchers, and advocacy groups **to analyze the information**, potentially identifying issues that may be overlooked by the operator or regulators.
- We understand that NextEra may consider the data confidential; however, we assert that **we assert that raw measurement data should be treated as public domain, however we recognize that NextEra's modeling is proprietary.**

What Data?

Acceptance criteria for CI measurements

Tier	Structures monitoring program	Recommendation for individual concrete components	Criteria
3	Unacceptable (requires further evaluation)	<ul style="list-style-type: none"> Structural evaluation Implement enhanced ASR monitoring such as through-wall expansion monitoring using Extensometers 	1.0 mm/m (0.1%) or greater strain measurement (CCI or pin-pin)
2	Acceptable with deficiencies	Quantitative monitoring and trending	<ul style="list-style-type: none"> 0.5 mm/m (0.05%) or greater strain measurement (CCI or pin-pin) CI or pin-pin measurement of greater than 0.5 mm/m (0.05%) in the vertical and horizontal direction
		Qualitative monitoring	Any area with visual presence of ASR (as defined in [930]) accompanied by a CI of less than 0.5 mm/m (0.05%) in the vertical and horizontal directions
1	Acceptable	Routine inspection as prescribed by the Structural Monitoring Program	Area has no indication of pattern cracking or water ingress; No visual symptoms of ASR

[Seabrook Station - Approach for Determining Through-Thickness Expansion from Alkali-Silica Reaction](#)

NextEra-ML18141A785 ([2016](#))

Need to Communicate with the Public





- We ask the NRC to obtain from NextEra and share with the public **all** measurements related to the crack index

Date	Tier	CI	Location	Ref Values
------	------	----	----------	------------






Ref Value: Location of the closest concrete sample cast during construction with known compressive strength f'_c

- C-10 has built a **data visualizer** that we would like to share with the NRC. It is based on the premises that
 - ASR has both a spatial and temporal variation.
 - It is measured pointwise, yet its impact is spread over volumes
 - We only have limited point measurements at discrete times.
 - Need to
 - Map
 - Visualize
 - Analyze (and Predict)

Visualize



Analyze



Can Quantify structural damage over time.



Atomic Safety License Board (2020). [In the Matter of NEXTERA ENERGY SEABROOK, LLC \(Seabrook Station, Unit 1\); Initial Decision](#). Docket No. 50-443-LA-2, ASLB No 17-953-02-LA-BD01.



FHWA (2010). [Report on the Diagnostis, Prognosis, and Mitigation of Alkali-Silica Reaction \(ASR\) in Transportation Structures](#). Tech. rep. FHWA-HIF-09-004. Federal Highway Administration.



NextEra Energy (May 2016). *Supplement to License Amendment Request 16-01 Request to Extend Containment Leakage Test Frequency*.



NextEra-ML16216A240 (2016). [Seabrook, License Amendment Request 16-03 - Revise Current Licensing Basis to Adopt a Methodology for the Analysis of Seismic Category I Structures with Concrete Affected by Alkali-Silica Reaction](#). ADAMS access number ML16216A250.





NextEra-ML18141A785 (2016). [Seabrook Station - Approach for Determining Through-Thickness Expansion from](#)



[Alkali-Silica Reaction](#). Redacted Document.

Simpson Gumpertz & Heger-ML16279A049 (2016). [Evaluation and Design Confirmation of As-Deformed CEB, 150252CA-02," Revision 0, July 2016 \(Seabrook FP#100985\)](#). Online; accessed 2024-07-16.

Advisory Committee on Reactor Safeguards Full Committee Meeting

Seabrook Alkali Silica Reaction (ASR) Update / Information Briefing

Division of Operating Reactor Safety


U.S. NRC Region I

September 4, 2024

NRC Staff Presenters

Niklas Floyd

Senior Reactor Inspector
Region I



Travis Daun

Senior Resident Inspector, Seabrook
Region I





Agenda


- Alkali-Silica Reaction (ASR) Background
- NRC Inspection and Assessment of ASR
- Review of Containment Internal Structures
- Summary

ASR Background

- ASR is a slow, expansive chemical reaction in hardened concrete which occurs in the presence of water, between the alkaline cement and reactive silica found in some aggregates
- The expansion can cause various material impacts
- ASR is a very slow-moving phenomenon



ASR Background



Micro-cracking in the aggregate



Visual signs of cracking on the surface of the concrete

ASR Background

- 2009 – 2010: Degradation in Seabrook concrete exposed to groundwater identified during license renewal audit walkdowns
 - Testing confirmed the presence of ASR
 - Codes of record in the Seabrook current licensing basis did not account for ASR
 - NextEra initiated prompt operability determination (POD) and extent-of-condition (early 2011)
- Why ASR occurred and was not identified earlier:
 - Seabrook unknowingly used a slow-reactive aggregate in the concrete
 - Ineffective ASTM Standards at the time of construction
 - ASR development was not expected
 - Inspections were not looking for ASR

ASR Background

- NextEra concluded that ASR-affected structures were operable but degraded and non-conforming
- NRC regional inspectors and headquarters staff reviewed operability determinations and concluded that ASR-affected structures remained capable of performing their safety functions
- 2012: NRC increased oversight to ensure structures remained functional while NextEra developed corrective actions

ASR Background

Large-Scale Testing Program:

- NextEra test program at The University of Texas at Austin
- 2013 – 2016: NRC conducted inspections at the test facility to ensure NRC requirements for quality test standards were met



ASR Background

Large-Scale Testing Program Results:


- Showed no reduction in structural capacity up to the expansion levels tested, and code equations can be used up to the tested limits
- Determined through-wall expansion was best way to track ASR progression after in-plane expansion plateaus
- Data was used to develop a correlation between measured modulus-of-elasticity and through-wall expansion; used to estimate expansion until extensometer installation
- Expansion levels* from the testing were added to Seabrook's CLB as expansion limits for capacity limit states

**During 1Q2023, NextEra communicated to inspectors that expansion trends were projected to exceed the limits prior to license expiration and would likely require additional large-scale testing to support increased expansion levels (ML23129A193)*

ASR Background

Building Deformation Program:

- 2014 – 2015: NRC identified bulk structural deformation in the following Seismic Category 1 structures on site:
 - Containment Enclosure Building
 - Residual Heat Removal vaults
 - Spent Fuel Building
- Bulk deformation results in additional loading and can impact equipment
- Building deformation was incorporated into NextEra's license amendment request




ASR Background

Building Deformation Program:

- 3-stage analysis methodology to address ASR loads
 - More detailed and accurate as stages progress from 1 to 3
- Estimates ASR loads based on field measurements
 - Also accounts for future ASR progression
- Demonstrates Capacity \geq Demand (including ASR)
- Identifies quantitative acceptance criteria (threshold monitoring parameters, limits) for each structure based on analysis; triggers corrective action when approached or exceeded
- Allows for structural modifications or further evaluation
- Methodology described in the license amendment and incorporated into Seabrook's Structures Monitoring Program

ASR Background

Methodology Overview:




ASR Background


- License Amendment Request:
 - Incorporated test program expansion limits for capacity
 - Detailed methodology for evaluating the effects of ASR on Seabrook structures (incorporates ASR load/demand, acceptance criteria)
 - Monitoring provides for timely corrective action
- License Renewal Application:
 - Aging management programs (AMPs) identify and manage future effects of aging
 - License renewal application supplemented to include ASR monitoring and evaluation programs as AMPs
- NRC approved and issued both the license amendment and renewed license in March 2019.
 - ACRS meetings and ASLB hearing completed

ASR Background


Examples of Monitoring ASR at Seabrook:




Combined crack indexing (CCI)
and pin-to-pin distance



Seismic gap widths between buildings



Extensometers



Crack gauges

ASR Background

Summary of ASR License Conditions:

- a) Assess expansion behavior to confirm it is comparable to the large-scale test program and check margin for future expansion.
- b) Corroborate, using Seabrook field data, the concrete modulus to expansion correlation used to calculate pre-instrument through-thickness expansion.
- c) Conduct a volumetric expansion check for control extensometers every six months.
- d) Develop a monitoring program to ensure that rebar failure or yielding does not occur, or is detected if it has already occurred, if the structural evaluations indicate rebar stress may exceed yield.
- e) If the ASR expansion rate significantly exceeds 0.2 mm/m (0.02%) through-thickness expansion per year, NextEra will perform an engineering evaluation focused on the continued suitability of the six-month monitoring interval.
- f) Each core extracted from Seabrook Unit 1 will be subjected to a petrographic analysis to detect internal microcracking and delamination.

NRC Inspection and Assessment of ASR

- NRC resident inspectors performed daily onsite oversight via plant status (corrective action report review and walk downs)
- Inspectors selected risk-informed and performance-based samples, including maintenance rule, operability determinations, modifications, and focused PI&R samples
- Regional specialists and NRR / RES technical staff performed focused inspections
- Results documented in inspection reports
- Results and oversight plans discussed with Region I senior managers and during end-of-cycle reviews

NRC Inspection and Assessment of ASR

- Oversight of ASR since last ACRS update in April 2022:
 - 5 weeks of on-site inspections by team of regional inspectors and NRR/RES technical staff
 - 11 total inspection samples focused specifically on ASR related activities
- Two other team inspections reviewed ASR-related items during baseline ROP inspections. These included the Biennial Problem Identification and Resolution and the Age-Related Degradation team inspections.

NRC Inspection and Assessment of ASR

- NRC inspections determined Seabrook structures remained capable of performing their intended safety functions
- NRC inspectors identified three findings involving ASR activities since 2022. The violations were found to be of very low safety significance and have been addressed in NextEra's corrective action program




NRC Inspection and Assessment of ASR

- Determined NextEra reviewed Seismic Category I structures using approved Methodology Document
 - **28** total structures in program
 - **6** structures remained outside of the licensing basis
- Determined functionality of six structures is documented in Prompt Operability Determination with supporting analyses
 - Additional monitoring/trending (typically every 2 months)
 - Long-term corrective actions via modification and/or reanalysis


NRC Inspection and Assessment of ASR

Corrective Actions Planned for Structures Approaching or Outside of Licensing Basis Limits:


- Physical Modification and/or Re-analysis
- Physical modification process described in the NRC-approved methodology to evaluate and manage the effects of ASR



**Example 1 -
Strong Backs**



**Example 2 -
Corner Braces**



**Example 3 -
Vertical Plates**

NRC Inspection and Assessment of ASR

Examples of Modifications:




Figure 1. Vertical plates



Figure 2. Corner braces and strong backs


NRC Inspection and Assessment of ASR

Inspection Findings:


- NRC inspectors identified 3 findings of very low safety significance involving NextEra's performance and ASR
 - *NCV 2022002-01* Did not install extensometers in 7 ASR Tier 3 locations
 - *NCV 2024010-02* Did not correct an adverse condition associated with a tubing support from ASR deformation
 - *NCV 2024001-02* Did not analyze the reactor cavity pit slab in the revised CIS structural evaluation
- Determined the 3 findings were addressed in NextEra's corrective action program

NRC Inspection and Assessment of ASR


Inspection Findings:



NCV 2022002-01



NCV 2024010-02



NCV 2024001-02

Review of Containment Internal Structures

- **Nov 2021:** NRC identification of possible ASR cracking in reactor cavity pit of the containment internal structures (CIS) documented as Green finding in 4Q2021.
- **April 2023:** NextEra completed root cause studies to best estimate the amount and location of ASR based on observed distress (cracks and spalling).
- **Nov 2023:** NextEra completed the "stage 2" structural evaluations in accordance with NRC-approved methodology.
- **Mar 2024:** NRC reviewed the CIS root causes and structural evaluations. NRC identified one finding because NextEra staff did not analyze a particular element in the reactor pit slab in their CIS structural evaluation.


Review of Containment Internal Structures

NextEra's Approach for Analysis:

- Collected data from field measurements (crack sizes, crack locations, temperatures, spalling) inside the CIS
- Developed finite element models for heat transfer and stress from "in situ" loads
- Performed parametric studies varying the amount of ASR expansion and thermal loads to understand the observed distresses
- Documented the results in root cause reports
- Utilized the results as an input into the CIS stage 2 structural evaluations:
 - Reactor cavity pit area
 - Superstructure (areas above the reactor cavity pit, including the fill mat)

Review of Containment Internal Structures


CIS Field Observations:



*Cracking patterns on west side walls (not shown) are similar to those on east side walls (#5)

Review of Containment Internal Structures

CIS Field Observations:



Area repaired in 2012

Spalling observed in 2021

After loose concrete removed

2021 Inspection

2021 Inspection

2021 Inspection


- In 2021, failure of 2012 repair was observed, and second repair was performed
- In 2023 outage, an encapsulation was installed for spalling concrete

The image shows a 3D cutaway diagram of a containment structure on the left. A red circle highlights a specific area on the floor. Three red arrows point from this circle to three photographs on the right. The top photograph shows a concrete area with a metal grate, labeled '2021 Inspection', with a red arrow pointing to a 'Area repaired in 2012'. The middle photograph shows the same area after the loose concrete has been removed, labeled '2021 Inspection', with a red arrow pointing to 'Spalling observed in 2021'. The bottom photograph shows a close-up of the concrete surface, labeled '2021 Inspection', with a red arrow pointing to the 'Area repaired in 2012'.

Review of Containment Internal Structures

CIS Field Observations:

- No apparent changes in 2017, 2021, or 2023 inspections



2017 Inspection




2021 Inspection

Typical Cracking Patterns Along Pit Walls


Review of Containment Internal Structures

Finite Element Models:

- NextEra developed models and completed parametric studies to identify the likely causes of observed structural conditions in CIS:
 - Scenarios analyzed concrete expansion due to thermal, ASR, and varying combinations
 - Other effects analyzed such as cycling fatigue, stress concentrations, and creep
- The studies used best estimated actual loads (in-situ loads) to simulate the observed conditions




Heat Transfer Model




Global Stress Model

Review of Containment Internal Structures


Thermal



Scenario 1, Variation A
(Design basis thermal)




Scenario 2
(no thermal)




Scenario 3, Variation E
(operating thermal)

$\Delta T^{\circ}F$




Parametric Study Example Scenarios


ASR




Scenario 1
(representative case)



Scenario 2
(representative case)



Scenario 3
(representative case)



Review of Containment Internal Structures

Parametric Study Example:

	Thermal Variation	Thermal Load Boundary Conditions						ASR	Compare to Observed Conditions?
		<i>Steady-State Operation</i>		<i>Shutdown</i>		<i>Reference</i>			
		Inside CIS	Bedrock Interface	Inside CIS	Bedrock Interface	Inside CIS	Bedrock Interface		
Scenario One	A	120 °F	40 °F	80 °F	40 °F	70 °F	40 °F	CB foundation only	No
	B	110 °F	40 °F			60 °F	40 °F		
	C	120 °F	40 °F						
	D	110 °F	40 °F						
Scenario Two	NO Thermal Load	N/A		N/A		N/A		CB foundation only	No
								CB foundation and reactor pit	No
								CB foundation, reactor pit, and slab at EL. (-) 44'	No
Scenario Three	E	<ul style="list-style-type: none"> 90°F inside CIS reactor pit 150°F on the inside face of the primary shield wall 90°F on the outside face of the primary shield wall 77°F on the top surface of the fill mat slab at EL. (-) 26' 40°F at bedrock interface 		80 °F	40 °F	60 °F	40 °F	CB foundation only	Yes
								CB foundation and fill mat slab at EL. (-) 26'	No
	F					70 °F	40 °F	CB foundation and reactor pit	Yes
							CB foundation only	No	

Review of Containment Internal Structures

Additional Parametric Studies:

- NextEra reviewed conditions in other areas of the CIS to determine the cause of the observed distress:
 - El. (-) 26ft fill mat slab and adjacent to the sump at azimuth 80°
 - Personnel elevator with base at El. (-) 26 ft azimuth 335°
- Studies analyzed combinations of in-situ load conditions (thermal and ASR) with results documented in two root cause reports
- NextEra concluded the conditions were likely due to effects other than ASR

Review of Containment Internal Structures

Ongoing Monitoring

- Continued monitoring inside the CIS to see whether any ASR expansion is occurring:
 - Fill Mat Slab at EL (-) 26 ft
 - Secondary Shield Wall at EL (-) 26 ft
 - Walls adjacent to Sump at AZ 80° on EL(-) 26 ft
 - Elevator at AZ 335° on EL (-) 26 ft and 0 ft
 - Reactor Cavity Pit Area
- Retrieve reactor pit temperature data during the upcoming fall 2024 refueling outage

Review of Containment Internal Structures

NRC Review:

- Inspectors verified that NextEra completed the CIS structural evaluation in accordance with their revised licensing basis and the Stage 2 analysis process in the NRC-approved methodology document
- The inspectors concluded that root cause studies were of appropriate technical detail to develop insights and provide for upper limit estimates of possible ASR/swelling expansion that reasonably correlated with CIS field observations. Plans were in place to continue to monitor and refine results.
- Inspectors noted there was an upper limit of ASR expansion of 0.2mm/m in foundation mat with 30% margin for expansion
- NRC identified one violation because NextEra did not evaluate the reactor pit slab in the revised structural evaluation


Review of Containment Internal Structures

Violation:

NextEra did not verify the adequacy of the reactor pit slab at el. (-) 44'-9" for the applicable design loads, including ASR, in the revised structural evaluation for the CIS.

Corrective Actions:

- NextEra performed a prompt operability determination to confirm the integrity of the reactor pit slab for the unusual load combination with a safe shutdown earthquake
- Engineering change in-progress to reclassify the slab as non-Seismic Category I and perform the necessary analysis for SC II over I
- Designed a preventative modification as contingency for protection of components below the slab in the event of concrete spalling



Summary

- NRC inspections determined Seabrook structures remained capable of performing their safety functions as intended, including under limiting conditions
- NRC inspections identified some findings and violations of very low safety significance which have been addressed in the corrective action program

Summary

Next Steps:

- NRC will continue inspections under the Reactor Oversight Process that includes NextEra's ASR-related activities to:
 - Bring structures into compliance with licensing basis
 - Monitor ASR and building deformation
 - Complete modifications (physical and/or reanalyze) on affected structures.
 - Validate thermal and ASR loads in CIS
 - Implement ASR related license conditions
- Monitor NextEra's plans that may potentially involve large-scale testing



Summary

Public References:

NRC Webpage on Concrete Degradation at Seabrook

<https://www.nrc.gov/reactors/operating/ops-experience.html>

NRC Webpage on Seabrook License Renewal

<https://www.nrc.gov/reactors/operating/licensing/renewal/applications.html>

Documents Available are at <https://adams.nrc.gov/wba/>:

- ASR license amendment request
 - NRC staff safety evaluation: [ML18204A291](#)
 - ACRS letter: [ML18348A951](#)
- License renewal application
 - NRC staff safety evaluation report: [ML18362A370](#)
 - ACRS letter: [ML18353A954](#)

End of Staff Presentation