

Advisory Committee on Reactor Safeguards

C-10 Presentation; Technical

Victor E. Saouma

Prof. Emeritus, Univ. of Colorado, Boulder
C-10 Consultant

Sept. 4, 2024



- 1 Chronology
- 2 Q1: Revisit Operating Basis Earthquake (OBE) & Safe Shutdown Earthquake (SSE); Correct Analysis Model
- 3 Q2: Air Leakage Test; Revisit Testing Frequency
- 4 Q3: Crack Indices (CI), Public Right to Know



Chronology

- 2009** ASR discovered in Tunnel (Bravo-1) at Seabrook.
- 2010** Seabrook placed under [special NRC oversight](#).
- 2012** [Nuclear Energy Institute](#) suggests an (up to) 15 years intervals (in lieu of 10) for type A performance leakage rate tests of CBE.
- 2016** NextEra files a [License Amendment Request \(LAR\)](#)16-03.
Regarding seismic analysis, we note the following:

Eathquake levels: No change of OBE & SSE

[W]hen ASR loads are amplified by a threshold factor of 1.2 to account for future ASR expansion[, t]he as deformed condition does not **significantly** impact the dynamic properties of the structure, and therefore the **maximum seismic acceleration profiles for OBE and SSE excitation used in original design of the CEB remain valid.**

Seabrook, License Amendment Request 16-03 - Revise Current Licensing Basis to Adopt a Methodology for the Analysis of Seismic Category I Structures with Concrete Affected by Alkali-Silica Reaction.

NextEra-ML16216A240 (2016)



Chronology

Oversimplified Analysis

Seismic loads are applied using a **static equivalent method** utilizing the design-basis maximum acceleration profiles, which were computed during original design from response spectra analysis. **Amplify ASR loads by a threshold** factor to account for potential future ASR expansion.

...

Response spectra analysis was performed using a **simplified** "stick" model.

*Evaluation and Design Confirmation of As-Deformed CEB, 150252CA-02," Revision 0, July 2016
(Seabrook FP#100985)*

Simpson Gumpertz & Heger-ML16279A049 (2016)

Comments Below

2016 NextEra files a [Request to Extend to 15 years](#) leakage test of CBE. It alleges that



Chronology

NextEra's justification

- Containment's three directional steel reinforcement arrangements, which inhibits ASR expansion,
- The very limited localized areas of ASR detected on the containment surface, and
- Previous UT inspections of the containment liner local to areas of ASR in which no anomalies or corrosion were identified

Supplement to License Amendment Request 16-01 Request to Extend Containment Leakage Test Frequency


NextEra Energy (2016)



Chronology

C-10 Comments

- ASR causes cracks and microcracks, which **not always visible**. These may coalesce and **create a continuous pathway** for gas release.
- There is three-directional reinforcement **only around the base**, while “skin” reinforcement is applied **only on the intrados and extrados**.



Report on the Diagnostics, Prognosis, and Mitigation of Alkali-Silica Reaction (ASR) in Transportation Structures
FHWA (2010)

Chronology

- 2019 Professor Saouma [visits Seabrook](#).
- 2019 [Consolidated documents](#) filed by Dr. Victor Saouma
- 2019 Proposed Findings of Fact and Conclusions of Law: [C-10](#), [NRC](#), and [NextEra](#).

2020 Atomic Safety Licensing Board (ASLB) Ruling (includes):

... NextEra has not persuaded us that it is properly accounting for the possibility of delamination.

The Board finds that NextEra **does not have an adequate screening procedure to detect internal cracking** and delamination in Seabrook's concrete." (pg 184)

...[t]he Board is **concerned about the potential for sudden significant, localized damage due to shear failure**, given that all parties agreed that there may be localized excursions of Seabrook Unit 1 into the nonlinear structure plastification regime." (pg 184)

Thus, the Board finds that **NextEra has not shown, by a preponderance of the evidence, that there is reasonable assurance that the continued operation of Seabrook Unit 1 will not endanger the health and safety of the public with regard to this particular issue of delamination.**" (pg 185)

In the Matter of NEXTERA ENERGY SEABROOK, LLC (Seabrook Station, Unit 1); Initial Decision
Atomic Safety License Board (2020)

Observations

- In 2010, knowledge about ASR was insufficient, but significant advancements were made by 2020.
- Some premises that initially supported the license renewal were later shown to be incorrect.
- The ASLB comments partially validated this assertion.
- Given the stakes, it is urgent to reconsider two key issues.
 - OBE & OSE
 - Air leakage test

Explanation follows



Q1: Revisit Operating Basis
Earthquake (OBE) & Safe
Shutdown Earthquake (SSE);
Correct Analysis Model



- We have reviewed the dynamic analysis procedure performed by SGH and found it dangerously simplistic.
- The term *significantly* is too vague given the potential impact on the safety of the CEB.
- The reliance on the stick model, a method from the 1970s, is not only outdated but also inadequate; In the 21st century the NRC must demand the adoption of a more accurate model.
- The ASR modeling blatantly disregards well-established principles, directly conflicting with what is universally accepted in the field of modeling.
- Program to simulate ASR not validated.
- **The Capacity is grossly miscalculated.**



The Myth of No Shear Strength Loss from AAR


Results from the Shear Test Program indicate that there is no reduction of shear capacity in ASR-affected concrete with through-thickness expansion levels up to █% or volumetric expansion levels █%, which are the maximum expansion levels exhibited by the test specimens.

Seabrook Station - Approach for Determining Through-Thickness Expansion from Alkali-Silica Reaction
NextEra-ML18141A785 (2016)

- The persistent myth that there is no shear reduction due to AAR in the CEB has been **conclusively disproven** by findings from two separate NRC-funded research programs.
- AAR will lead to significant shear reduction, critically **undermining resistance to earthquake excitation**.
- The **Demand** is grossly underestimated



Why the SSE should be updated



Q2: Air Leakage Test; Revisit Testing Frequency



Air Leakage Test

- The ASLB firmly asserts that NextEra has no reliable control over where and when cracking will occur.
- This directly undermines NextEra's claim that 15 years cycles for leakage testing are sufficient.
- By 2020, ASR has not only been identified as a critical threat to Seabrook, with hidden cracks often going undetected, but NextEra has also demonstrated a consistently poor record in managing ASR.
- As the years pass areas known to have ASR, and countless unknown areas are experiencing ASR degradation.
- Consequently, we **strongly recommend that the full air tightness test schedule be drastically shortened from the current 15 years to a performance-based schedule.**



Q3: Crack Indices (CI), Public Right to Know



Public Right to Know Some Data

- The public has a **fundamental right to access information that affects their safety and well-being.**
- Transparency in sharing data helps **build trust between the reactor operator, regulatory agencies, and the public.** When data is openly available, it demonstrates that the operator is committed to safety and is accountable for maintaining the highest standards.
- Public access to safety data enables **independent experts, researchers, and advocacy groups to analyze the information,** potentially identifying issues that may be overlooked by the operator or regulators.
- We understand that NextEra may consider the data confidential; however, we assert that **we assert that raw measurement data should be treated as public domain, however we recognize that NextEra's modeling is proprietary.**



What Data?

Acceptance criteria for CI measurements

Tier	Structures monitoring program	Recommendation for individual concrete components	Criteria
3	Unacceptable (requires further evaluation)	<ul style="list-style-type: none"> Structural evaluation Implement enhanced ASR monitoring such as through-wall expansion monitoring using Extensometers 	1.0 mm/m (0.1%) or greater strain measurement (CCI or pin-pin)
2	Acceptable with deficiencies	Quantitative monitoring and trending	<ul style="list-style-type: none"> 0.5 mm/m (0.05%) or greater strain measurement (CCI or pin-pin) CI or pin-pin measurement of greater than 0.5 mm/m (0.05%) in the vertical and horizontal direction
		Qualitative monitoring	Any area with visual presence of ASR (as defined in [930]) accompanied by a CI of less than 0.5 mm/m (0.05%) in the vertical and horizontal directions
1	Acceptable	Routine inspection as prescribed by the Structural Monitoring Program	Area has no indication of pattern cracking or water ingress; No visual symptoms of ASR

Seabrook Station - Approach for Determining Through-Thickness Expansion from Alkali-Silica Reaction
NextEra-ML18141A785 (2016)



Need to Communicate with the Public

- We ask the NRC to obtain from NextEra and share with the public **all** measurements related to the crack index





Date	Tier	CI	Location	Ref Values
------	------	----	----------	------------

Ref Value: Location of the closest concrete sample cast during construction with known compressive strength f'_c






- C-10 has built a **data visualizer** that we would like to share with the NRC. It is based on the premises that
 - ASR has both a spatial and temporal variation.
 - It is measured pointwise, yet its impact is spread over volumes
 - We only have limited point measurements at discrete times.
 - Need to
 - 1 Map
 - 2 Visualize
 - 3 Analyze (and predict)



Visualize







Analyze



Can Quantify structural damage over time.



-  Atomic Safety License Board (2020). *In the Matter of NEXTERA ENERGY SEABROOK, LLC (Seabrook Station, Unit 1); Initial Decision*. Docket No. 50-443-LA-2, ASLB No 17-953-02-LA-BD01.
-  FHWA (2010). *Report on the Diagnostis, Prognosis, and Mitigation of Alkali-Silica Reaction (ASR) in Transportation Structures*. Tech. rep. FHWA-HIF-09-004. Federal Highway Administration.
-  NextEra Energy (May 2016). *Supplement to License Amendment Request 16-01 Request to Extend Containment Leakage Test Frequency*.
-  NextEra-ML16216A240 (2016). *Seabrook, License Amendment Request 16-03 - Revise Current Licensing Basis to Adopt a Methodology for the Analysis of Seismic Category I Structures with Concrete Affected by Alkali-Silica Reaction*. ADAMS access number ML16216A250.

-  NextEra-ML18141A785 (2016). *Seabrook Station - Approach for Determining Through-Thickness Expansion from Alkali-Silica Reaction*. Redacted Document.
-  Simpson Gumpertz & Heger-ML16279A049 (2016). *Evaluation and Design Confirmation of As-Deformed CEB, 150252CA-02," Revision 0, July 2016 (Seabrook FP#100985)*. Online; accessed 2024-07-16.